Tentative Interim Amendment

NFPA® 1

Fire Code

2027 Edition

Reference: (NFPA 70 extracts) 2.4, 3.3.101, Various paragraphs in Chapter 11
TIA 27-1
(SC 26-8-14 / TIA Log #1905)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

See attached for text changes.

Issue Date: August 20, 2026

Effective Date: September 9, 2026

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo**)**
Copyright © 2026 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION

2.4 References for Extracts in Mandatory Sections.
NFPA 70®, *National Electrical Code®*, ~~2023~~ 2026 edition.

3.3.101 Electric Vehicle Power Export Equipment (EVPE).
The equipment, including the outlet on the electric vehicle, that is used to provide electrical power at voltages greater than or equal to 30 Vac or 60 Vdc to loads external to the electric vehicle, using the electric vehicle as the source of supply. [**70,** ~~2023~~2026] (FCC-FUN)

Chapter 11 Building Services
11.2 Electrical Fire Safety.
11.2.6 Temporary Installations.
11.2.6.1 Scope.
The provisions of 11.2.6 apply to temporary electric power and lighting installations. [**70:**590.1]
11.2.6.2 All Wiring Installations.
11.2.6.2.1 Other Articles.
Except as specifically modified in Article 590 of *NFPA 70*, all other requirements of *NFPA 70* for permanent wiring shall apply to temporary wiring installations. [**70:**590.~~2~~4(A)]
11.2.6.2.2 Approval.
Temporary wiring methods shall be acceptable only if approved based on the conditions of use and any special requirements of the temporary installation. [**70:**590.~~2~~4(B)]
11.2.6.3 Time Constraints.
11.2.6.3.1 During the Period of Construction.
Temporary electric power and lighting installations shall be permitted during the period of construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment, or similar activities. [***70*:**590.~~3~~5(A)]
11.2.6.3.2 90 Days.
Temporary electric power and lighting installations shall be permitted for a period not to exceed 90 days for holiday decorative lighting and similar purposes. [**70:**590.~~3~~5(B)]
11.2.6.3.3 Emergencies and Tests.
Temporary electric power and lighting installations shall be permitted during emergencies and for tests, experiments, and developmental work. [**70:**590.~~3~~5(C)]
11.2.6.3.4 Removal.
Temporary wiring shall be removed immediately upon completion of construction or purpose for which the wiring was installed. [**70:**590.~~3~~5(D)]
11.2.7 Building Disconnect.
11.2.7.1*
Means shall be provided for the fire department to disconnect the electrical service to a building, structure, or facility when the electrical installation is covered under the scope of *NFPA 70*.
11.2.7.3 Identification of Disconnecting Means.
11.2.7.3.1
General. Each disconnecting means shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. In other than one- or two-family dwellings, the marking shall include the identification and location of the circuit source that supplies the disconnecting means unless located and arranged so the identification and location of the circuit source is evident. The marking shall be of sufficient durability to withstand the environment involved. [**70:**110.22(A)]