First Revision No. 6617-NFPA 101-2024 [Section No. 11.9.5.1]

11.9.5.1 ~~Fired Heaters~~ Fuel-Burning Appliances .

11.9.5.1.1

Only labeled heating devices shall be used.

11.9.5.1.2

Fuel-~~fired heaters~~ burning appliances and their installation shall be approved by the authority having jurisdiction.

11.9.5.1.3

Containers for liquefied petroleum gases shall be installed not less than 60 in. (1525 mm) from any temporary membrane structure and shall be in accordance with the provisions of NFPA 58.

11.9.5.1.4

Tanks shall be secured in the upright position and protected from vehicular traffic.

11.9.5.1.5

The AHJ shall be permitted to require carbon monoxide alarms where fuel-burning appliances are used.

Submitter Information Verification

Committee: SAF-IND

Submittal Date: Wed Jul 17 14:46:22 EDT 2024

Committee Statement

Committee Statement: The term "fuel-fired heater" was changed to "fuel-burning appliance" as this is a defined term and better encompasses all devices which pose a similar risk of fire or producing carbon monoxide. The AHJ should have the ability to require CO alarms within permanent membrane structures where they deem a CO hazard exists.

Response Message: FR-6617-NFPA 101-2024

First Revision No. 6616-NFPA 101-2024 [Section No. 11.10.7.1]

11.10.7.1 ~~Fired Heaters~~ Fuel-Burning Appliances .

11.10.7.1.1

Only labeled heating devices shall be used.

11.10.7.1.2

Fuel-~~fired heaters~~ burning appliances and their installation shall be approved by the authority having jurisdiction.

11.10.7.1.3

Containers for liquefied petroleum gases shall be installed not less than 60 in. (1525 mm) from any temporary membrane structure and shall be in accordance with the provisions of NFPA 58.

11.10.7.1.4

Tanks shall be secured in the upright position and protected from vehicular traffic.

11.10.7.1.5

The AHJ shall be permitted to require carbon monoxide alarms where fuel-burning appliances are used.

Submitter Information Verification

Committee: SAF-IND

Submittal Date: Wed Jul 17 14:42:12 EDT 2024

Committee Statement

Committee Statement: The term "fuel-fired heater" was changed to "fuel-burning appliance" as this is a defined term and better encompasses all devices which pose a similar risk of fire or producing carbon monoxide. The AHJ should have the ability to require CO alarms within temporary membrane structures where they deem a CO hazard exists.

Response Message: FR-6616-NFPA 101-2024

First Revision No. 6669-NFPA 101-2024 [Section No. 11.11.6.1]

11.11.6.1 ~~Fired Heaters~~ Fuel-Burning Appliances .

11.11.6.1.1

Only labeled heating devices shall be used.

11.11.6.1.2

Fuel-~~fired heaters~~ burning appliances and their installation shall be approved by the authority having jurisdiction.

11.11.6.1.3

Containers for liquefied petroleum gases shall be installed not less than 60 in. (1525 mm) from any tent and shall be in accordance with the provisions of NFPA 58.

11.11.6.1.4

Tanks shall be secured in the upright position and protected from vehicular traffic.

11.11.6.1.5

The AHJ shall be permitted to require carbon monoxide alarms where fuel-burning appliances are used.

Submitter Information Verification

Committee: SAF-IND

Submittal Date: Fri Jul 19 10:26:28 EDT 2024

Committee Statement

Committee Statement: The term "fuel-fired heater" was changed to "fuel-burning appliance" as this is a defined term and better encompasses all devices which pose a similar risk of fire or producing carbon monoxide. The AHJ should have the ability to require CO alarms within tents where they deem a CO hazard exists.

Response Message: FR-6669-NFPA 101-2024

Public Input No. 135-NFPA 101-2024 [New Section after 11.11.6.1]

First Revision No. 6593-NFPA 101-2024 [Section No. 40.3.4.3.1]

40.3.4.3.1

The required fire alarm system shall meet one of the following criteria:

(1) It shall provide occupant notification in accordance with 9.6.3.

(2) It shall sound an audible and ~~visible~~ visual signal in a constantly attended location for the purposes of initiating emergency action.

Submitter Information Verification

Committee: SAF-IND

Submittal Date: Wed Jul 17 09:30:14 EDT 2024

Committee Statement

Committee Statement: Changing the terminology to be consistent with NFPA 72 as directed by the Correlating Committee in their February 2024 Pre-First Draft Meeting Minutes.

Response Message: FR-6593-NFPA 101-2024

First Revision No. 6670-NFPA 101-2024 [Section No. 42.3.4.3.1]

42.3.4.3.1

The required fire alarm system shall meet one of the following criteria:

(1) It shall provide occupant notification in accordance with 9.6.3.

(2) It shall sound an audible and ~~visible~~ visual signal in a constantly attended location for the purposes of initiating emergency action.

Submitter Information Verification

Committee: SAF-IND

Submittal Date: Fri Jul 19 10:40:17 EDT 2024

Committee Statement

Committee Statement: Changing the terminology to be consistent with NFPA 72 as directed by the Correlating Committee in their February 2024 Pre-First Draft Meeting Minutes.

Response Message: FR-6670-NFPA 101-2024