



Committee Input No. 6628-NFPA 101-2024 [New Section after 28.7.8]

28.8 Sleeping Pods

28.8.1 Where sleeping pods do not exceed 36 square feet, the requirements of section 28.8 apply.

28.8.2 Sleeping pods shall be permitted in buildings equipped with an automatic sprinkler system in accordance with 9.13.

28.8.3 Sleeping pods shall comply with section 10.7

28.8.4 A single means of escape shall be permitted in sleeping pods.

28.8.5 Sleeping pods shall comply with the detection, alarm, and communication systems in accordance with chapter 24 and the applicable occupancy.

28.8.5.1 Each sleeping pod shall be equipped with an alarm button for emergencies.

28.8.5.2 Each sleeping pod shall be equipped with an occupied indicator visible outside of the pod.

28.8.6 Sleeping pods shall comply with the means of egress in accordance with chapter 24 and the applicable occupancy.

28.8.7 Emergency lighting shall be installed in sleep pods.

28.8.8 Sleeping pods shall comply with the requirements of special hazards in accordance with chapter 24 and the applicable occupancy.

-

Submitter Information Verification

Committee: SAF-RES

Submittal Date: Wed Jul 17 17:39:21 EDT 2024

Committee Statement

Committee Statement: The committee on residential occupancies is looking for public comment regarding requirements regarding sleep pods. Including requirements of the sleeping pods themselves and the location of the sleeping pod.

Response Message: CI-6628-NFPA 101-2024