Tentative Interim Amendment

NFPA® 101®

Life Safety Code®

2027 Edition

Reference: 18.2.2.2.14(new), 19.2.2.2.14(new), 20.2.2.2.14(new), 21.2.2.2.15(new)
TIA 27-1
(SC 26-4-14 / TIA Log #1869)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Add new paragraph 18.2.2.2.14 to read as follows:

18.2.2.2.14 Weapons detection systems shall be permitted within the required means of egress where all of the following requirements are met:

1) The weapons detection system shall provide a minimum clear width required for minimum door leaf width in 7.2.1.2.3 or as modified by 18.2.3.4(6) through 18.2.3.4(8), 18.2.3.5(6), 18.2.3.6, or 18.2.3.7.
2) Floor level at the weapons detection system opening shall meet the requirements of 7.2.1.3.
3) If the weapons detection system is portable, the written fire safety plan required by 18.7.2.2 shall address the possible relocation of the equipment during a fire or similar emergency.

2. Add new paragraph 19.2.2.2.14 to read as follows:

19.2.2.2.14 Weapons detection systems shall be permitted within the required means of egress where all of the following requirements are met:

1) The weapons detection system shall provide a minimum clear width required for minimum door leaf width in 7.2.1.2.3 or as modified by 19.2.3.6 and 19.2.3.7.
2) Floor level at the weapons detection system opening shall meet the requirements of 7.2.1.3.
3) If the weapons detection system is portable, the written fire safety plan required by 19.7.2.2 shall address the possible relocation of the equipment during a fire or similar emergency.

3. Add new paragraph 20.2.2.2.14 to read as follows:

20.2.2.2.14 Weapons detection systems shall be permitted within the required means of egress where all of the following requirements are met:

1) The weapons detection system shall provide a minimum clear width required for minimum door leaf width in 7.2.1.2.3 or as modified by 20.2.3.4.
2) Floor level at the weapons detection system opening shall meet the requirements of 7.2.1.3.
3) If the weapons detection system is portable, the written fire safety plan required by 20.7.2.2 shall address the possible relocation of the equipment during a fire or similar emergency.

4. Add new paragraph 21.2.2.2.15 to read as follows:

21.2.2.2.15 Weapons detection systems shall be permitted within the required means of egress where all of the following requirements are met:

1) The weapons detection system shall provide a minimum clear width required for minimum door leaf width in 7.2.1.2.3 or as modified by 21.2.3.4.
2) Floor level at the weapons detection system opening shall meet the requirements of 7.2.1.3.

3) If the weapons detection system is portable, the written fire safety plan required by 21.7.2.2 shall address the possible relocation of the equipment during a fire or similar emergency.

Issue Date: April 15, 2026

Effective Date: May 5, 2026

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo**)**
Copyright © 2026 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION