Tentative Interim Amendment

NFPA® 101®

Life Safety Code®

2027 Edition

Reference: 4.6.13.3(new), A.4.6.13, and A.4.6.13.1(1)
TIA 27-2
(SC 26-8-53 / TIA Log #1909)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Add new paragraph 4.6.13.3 to read as follows:

4.6.13.3 The following materials shall not be required to be tested to be acceptable as noncombustible materials, provided they do not contain any combustible components:
1. Glass
2. Steel
3. 3xxx, 5xxx, and 6xxx series aluminum alloys
4. Concrete
5. Masonry

[**5000:**7.1.4.1.3]

*2. Delete Annex paragraphs A.4.6.13 and A.4.6.13.1(1) [including the * at 4.6.13 and 4.6.13.1(1)] as follows:*

~~**A.4.6.13** The provisions of 4.6.13 do not require inherently noncombustible materials to be tested in order to be classified as noncombustible materials. [**5000:**A.7.1.4.1]~~

~~**A.4.6.13.1(1)** Examples of such materials include steel, concrete, masonry, and glass. [**5000:**A.7.1.4.1.1(1)]~~

Issue Date: August 20, 2026

Effective Date: September 9, 2026

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo**)**

Copyright © 2026 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION