

**First Revision No. 4-NFPA 12-2019 [ Chapter 2 ]****Chapter 2** Referenced Publications**2.1** General.

The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

**2.2** NFPA Publications.

National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 4, *Standard for Integrated Fire Protection and Life Safety System Testing*, 2018 2021 edition.

NFPA 70<sup>®</sup>, *National Electrical Code*<sup>®</sup>, 2017 2020 edition.

NFPA 72<sup>®</sup>, *National Fire Alarm and Signaling Code*<sup>®</sup>, 2016 2019 edition.

**2.3** Other Publications.**2.3.1** ANSI Publications.

American National Standards Institute, Inc., 25 West 43rd Street, 4th Floor, New York, NY 10036.

ANSI Z535.2, *Standard for Environmental and Facility Safety Signs*, 2011, reaffirmed 2017 .

**2.3.2** API Publications.

American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005-4070.

API-ASME *Code for Unfired Pressure Vessels for Petroleum Liquids and Gases*, Pre-July 1, 1961.

**2.3.3** ASME Publications.

American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990.

ASME B31.1, *Power Piping-Code* , 2016 2018 .

**2.3.4** ASTM Publications.

ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM A53/A53M, *Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless*, 2012 2018 .

ASTM A106/A106M, *Standard Specification for Seamless Carbon Steel Pipe for High-Temperature Service*, 2015 2018 .

ASTM A120, *Specification for Pipe, Steel, Black and Hot-Dipped Zinc-Coated (Galvanized) Welded and Seamless for Ordinary Uses*, 1984 (withdrawn 1987).

ASTM A182/A182M, *Standard Specification for Forged or Rolled Alloy and Stainless Steel Pipe Flanges, Forged Fittings, and Valves and Parts for High-Temperature Service*, 2016 2018 .

**2.3.5** CGA Publications.

Compressed Gas Association, 14501 George Carter Way, Suite 103, Chantilly, VA 20151-2923.

CGA G-6.2, *Commodity Specification for Carbon Dioxide*, 2011 2013 .

**2.3.6** CSA Group Publications.

CSA Group, 178 Rexdale Blvd., Toronto, ON M9W 1R3, Canada.

CSA C22.1, *Canadian Electrical Code*, 2015 2018 .

**2.3.7** IEEE Publications.

IEEE, 3 Park Avenue, 17th Floor, New York, NY 10016-5997.

ANSI/IEEE C2, *National Electrical Safety Code*, 2017.

**2.3.8** U.S. Government Publications.

U.S. Government Publishing Office, 732 North Capitol Street, NW, Washington, DC 20401-0001.

Coward, H. F., and G. W. Jones, *Limits of Flammability of Gases and Vapors*, U.S. Bureau of Mines Bulletin 503, 1952.

Title 46, Code of Federal Regulations, Part 58.20.

Title 46, Code of Federal Regulations, Part 72.

Title 49, Code of Federal Regulations, Parts 171–190 (Department of Transportation).

Zabetakis, Michael G., *Flammability Characteristics of Combustible Gases and Vapors*, U.S. Bureau of Mines Bulletin 627, 1965.

**2.3.9** Other Publications.

*Merriam-Webster's Collegiate Dictionary*, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

**2.4** References for Extracts in Mandatory Sections.

NFPA 1, *Fire Code*, 2018 edition.

NFPA 122, *Standard for Fire Prevention and Control in Metal/Nonmetal Mining and Metal Mineral Processing Facilities*, 2015 edition.

NFPA 820, *Standard for Fire Protection in Wastewater Treatment and Collection Facilities*, 2016 edition.

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Thu Apr 25 16:58:26 EDT 2019

**Committee Statement**

**Committee Statement:** Referenced updated editions.

**Response Message:** FR-4-NFPA 12-2019

[Public Input No. 2-NFPA 12-2018 \[Chapter 2\]](#)

**First Revision No. 13-NFPA 12-2019 [ Section No. 3.3.6 ]****3.3.6 Normally Occupied Enclosure or Space.**

An enclosure or space where one or more persons are present under normal circumstances conditions .

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Tue Apr 30 18:46:40 EDT 2019

**Committee Statement**

**Committee Statement:** The definition is revised to match the one used in NFPA 2001.

**Response Message:** FR-13-NFPA 12-2019

**First Revision No. 1-NFPA 12-2019 [ Section No. 4.4.3.3.4 ]**

**4.4.3.3.4\*** Full Discharge Test.

**4.4.3.3.4.1**

A full discharge test shall be performed on ~~all systems~~ each installed system .

**4.4.3.3.4.2**

Where multiple hazards are protected from a common supply, a full discharge test shall be performed for each hazard.

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Thu Apr 25 16:11:11 EDT 2019

**Committee Statement**

**Committee Statement:** This revision clarifies that the full discharge test must be performed for each installed system to eliminate confusion that identical systems do not require testing.

**Response Message:** FR-1-NFPA 12-2019

**First Revision No. 2-NFPA 12-2019 [ Section No. 4.5.5.2 ]****4.5.5.2**

~~Supervision of automatic systems shall be provided, and the lockout required by 4.3.3.4 shall be supervised for both automatic and manual systems unless specifically waived by the authority having jurisdiction.~~

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Thu Apr 25 16:23:02 EDT 2019

**Committee Statement**

**Committee Statement:** The deleted sentence was redundant to 4.5.5.1.

**Response Message:** FR-2-NFPA 12-2019



## First Revision No. 3-NFPA 12-2019 [ Section No. 5.2.3 ]

### 5.2.3\* Types of Fires.

Fires that can be extinguished by total flooding methods shall be divided into the following two categories:

- (1) Surface fires involving flammable liquids, gases, and solids
- (2) Deep-seated fires involving solids subject to smoldering

#### 5.2.3.1\* Surface Fires.

~~Carbon dioxide~~ For surface fires, carbon dioxide shall be quickly introduced into the enclosure in a quantity to overcome leakage and provide an extinguishing concentration for the particular specific materials involved ~~for surface fires that are subject to prompt extinguishment~~.

#### 5.2.3.2\* Deep-Seated Fires.

For deep-seated fires, the ~~required extinguishing design~~ concentration shall be maintained for a period of time to allow the smoldering to be extinguished and the material to cool to a point at which re-ignition will not occur when the inert atmosphere is dissipated.

#### A.5.2.3.2

In any event, it is necessary to inspect the hazard immediately after a deep-seated fire to make certain that extinguishment is complete and to remove any material involved in the fire.

~~Where there is an explosive atmosphere of flammable vapors or combustible dust within an enclosure, discharge of liquid CO<sub>2</sub> could produce a static spark thereby causing an explosion. The danger of explosion can be mitigated by injecting CO<sub>2</sub> vapor into the hazard to build an inert atmosphere. The CO<sub>2</sub> vapor injection should be done gently to minimize turbulence that could raise and suspend combustible dust within the enclosure. An example of such a hazard is a coal storage silo. (NOTE: Fire protection and inerting of coal silos is beyond the scope of this standard.) See A.4.2.1.~~

### Submitter Information Verification

**Committee:** GFE-AAA

**Submittal Date:** Thu Apr 25 16:40:37 EDT 2019

### Committee Statement

**Committee Statement:** Section 5.2.3.2 is revised to clarify that it is the design concentration that must be maintained, not the minimum extinguishing concentration.

The additional annex material gives advice on the application of CO<sub>2</sub> to coal silos and similar applications, which are outside the scope of this document.

**Response Message:** FR-3-NFPA 12-2019

[Public Input No. 1-NFPA 12-2018 \[Global Input\]](#)

[Public Input No. 11-NFPA 12-2018 \[Section No. A.5.5.2\]](#)

**First Revision No. 6-NFPA 12-2019 [ Section No. 5.4.4.2 ]****5.4.4.2**

If leakage is appreciable, consideration shall be given to an extended discharge system ~~as covered in 5.5.3~~. (See also A.5.5.2 5.2.4.3.)

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submission Date:** Thu Apr 25 17:54:38 EDT 2019

**Committee Statement**

**Committee Statement:** This revision eliminates confusion with regard to extended discharge requirements for leaky systems that are not "enclosed rotation electrical equipment". The reference to the annex is updated to a more appropriate section.

**Response Message:** FR-6-NFPA 12-2019

[Public Input No. 10-NFPA 12-2018 \[Section No. 5.4.4.2\]](#)



**First Revision No. 7-NFPA 12-2019 [ Section No. 5.5.3 ]**

**5.5.3\* Enclosed Rotating Electrical Equipment.**

For enclosed rotating electrical equipment, a minimum concentration of 30 percent shall be maintained for the deceleration period, but not less than 20 minutes.



A.5.5.3

Protection of stationary combustion engines and gas turbines is addressed in NFPA 37.

For enclosed recirculating-type electrical equipment, the initial discharge quantity should not be less than 1 lb (0.45 kg) of gas for each 10 ft<sup>3</sup> (0.28 m<sup>3</sup>) of enclosed volume up to 2000 ft<sup>3</sup> (56.6 m<sup>3</sup>). For larger volumes, 1 lb (0.45 kg) of gas for each 12 ft<sup>3</sup> (0.34 m<sup>3</sup>) or a minimum of 200 lb (90.8 kg) should be used. Table A.5.5.3(a) and Table A.5.5.3(b) can be used as a guide to estimate the quantity of gas needed for the extended discharge to maintain a minimum concentration of 30 percent for the deceleration time. The quantity is based on the internal volume of the machine and the deceleration time, assuming average leakage. For damped, non-recirculating-type machines, add 35 percent to the indicated quantities in Table A.5.5.3(a) and Table A.5.5.3(b) for extended discharge protection.

Table A.5.5.3(a) Extended Discharge Protection for Enclosed Recirculating Rotating Electrical Equipment (Cubic Feet Protected for Deceleration Time)

| lb CO <sub>2</sub> | Time (minutes) |        |        |        |        |        |        |        |
|--------------------|----------------|--------|--------|--------|--------|--------|--------|--------|
|                    | 5              | 10     | 15     | 20     | 30     | 40     | 50     | 60     |
| 100                | 1,200          | 1,000  | 800    | 600    | 500    | 400    | 300    | 200    |
| 150                | 1,800          | 1,500  | 1,200  | 1,000  | 750    | 600    | 500    | 400    |
| 200                | 2,400          | 1,950  | 1,600  | 1,300  | 1,000  | 850    | 650    | 500    |
| 250                | 3,300          | 2,450  | 2,000  | 1,650  | 1,300  | 1,050  | 800    | 600    |
| 300                | 4,600          | 3,100  | 2,400  | 2,000  | 1,650  | 1,300  | 1,000  | 700    |
| 350                | 6,100          | 4,100  | 3,000  | 2,500  | 2,000  | 1,650  | 1,200  | 900    |
| 400                | 7,700          | 5,400  | 3,800  | 3,150  | 2,500  | 2,000  | 1,600  | 1,200  |
| 450                | 9,250          | 6,800  | 4,900  | 4,000  | 3,100  | 2,600  | 2,100  | 1,600  |
| 500                | 10,800         | 8,100  | 6,100  | 5,000  | 3,900  | 3,300  | 2,800  | 2,200  |
| 550                | 12,300         | 9,500  | 7,400  | 6,100  | 4,900  | 4,200  | 3,600  | 3,100  |
| 600                | 13,900         | 10,900 | 8,600  | 7,200  | 6,000  | 5,200  | 4,500  | 3,900  |
| 650                | 15,400         | 12,300 | 9,850  | 8,300  | 7,050  | 6,200  | 5,500  | 4,800  |
| 700                | 16,900         | 13,600 | 11,100 | 9,400  | 8,100  | 7,200  | 6,400  | 5,600  |
| 750                | 18,500         | 15,000 | 12,350 | 10,500 | 9,150  | 8,200  | 7,300  | 6,500  |
| 800                | 20,000         | 16,400 | 13,600 | 11,600 | 10,200 | 9,200  | 8,200  | 7,300  |
| 850                | 21,500         | 17,750 | 14,850 | 12,700 | 11,300 | 10,200 | 9,100  | 8,100  |
| 900                | 23,000         | 19,100 | 16,100 | 13,800 | 12,350 | 11,200 | 10,050 | 9,000  |
| 950                | 24,600         | 20,500 | 17,350 | 14,900 | 13,400 | 12,200 | 11,000 | 9,800  |
| 1,000              | 26,100         | 21,900 | 18,600 | 16,000 | 14,500 | 13,200 | 11,900 | 10,700 |
| 1,050              | 27,600         | 23,300 | 19,900 | 17,100 | 15,600 | 14,200 | 12,850 | 11,500 |
| 1,100              | 29,100         | 24,600 | 21,050 | 18,200 | 16,600 | 15,200 | 13,750 | 12,400 |
| 1,150              | 30,600         | 26,000 | 22,300 | 19,300 | 17,700 | 16,200 | 14,700 | 13,200 |
| 1,200              | 32,200         | 27,300 | 23,550 | 20,400 | 18,800 | 17,200 | 15,600 | 14,100 |
| 1,250              | 33,700         | 28,700 | 24,800 | 21,500 | 19,850 | 18,200 | 16,500 | 14,900 |
| 1,300              | 35,300         | 30,100 | 26,050 | 22,650 | 20,900 | 19,200 | 17,450 | 15,800 |
| 1,350              | 36,800         | 31,400 | 27,300 | 23,750 | 22,000 | 20,200 | 18,400 | 16,650 |
| 1,400              | 38,400         | 32,800 | 28,550 | 24,900 | 23,100 | 21,200 | 19,350 | 17,500 |
| 1,450              | 39,900         | 34,200 | 29,800 | 26,000 | 24,200 | 22,200 | 20,300 | 18,350 |
| 1,500              | 41,400         | 35,600 | 31,050 | 27,100 | 25,250 | 23,200 | 21,200 | 19,200 |

Table A.5.5.3(b) Extended Discharge for Enclosed Recirculating Rotating Electrical Equipment (Cubic Meters Protected for Deceleration Time) (SI Units)

| kg CO <sub>2</sub> | Time (minutes) |       |       |       |       |       |       |       |
|--------------------|----------------|-------|-------|-------|-------|-------|-------|-------|
|                    | 5              | 10    | 15    | 20    | 30    | 40    | 50    | 60    |
| 45.4               | 34.0           | 28.3  | 22.6  | 17.0  | 14.2  | 11.3  | 8.5   | 5.7   |
| 68.1               | 50.9           | 42.5  | 34.0  | 28.3  | 21.2  | 17.0  | 14.0  | 11.3  |
| 90.8               | 67.9           | 55.2  | 45.3  | 36.8  | 28.3  | 24.1  | 18.4  | 14.2  |
| 113.5              | 93.4           | 69.3  | 56.6  | 46.7  | 36.8  | 29.7  | 22.6  | 17.0  |
| 136.2              | 130.2          | 87.7  | 67.9  | 56.6  | 46.7  | 36.8  | 28.3  | 19.8  |
| 158.9              | 172.6          | 116.0 | 84.9  | 70.8  | 56.6  | 46.7  | 34.0  | 25.5  |
| 181.6              | 217.9          | 152.8 | 107.5 | 89.1  | 70.8  | 56.6  | 45.3  | 34.0  |
| 204.3              | 261.8          | 192.4 | 138.7 | 113.2 | 87.7  | 73.6  | 59.4  | 45.3  |
| 227.0              | 305.6          | 229.2 | 172.6 | 141.5 | 110.4 | 93.4  | 79.2  | 62.3  |
| 249.7              | 348.1          | 268.9 | 209.4 | 172.6 | 138.7 | 118.9 | 101.9 | 87.7  |
| 272.4              | 393.4          | 308.5 | 243.4 | 203.8 | 169.8 | 147.2 | 127.4 | 110.4 |
| 295.1              | 435.8          | 348.1 | 278.8 | 234.9 | 199.5 | 175.5 | 155.7 | 135.8 |
| 317.8              | 478.3          | 384.9 | 314.1 | 266.0 | 229.2 | 203.8 | 181.1 | 158.5 |
| 340.5              | 523.6          | 424.5 | 349.5 | 297.2 | 258.9 | 232.1 | 206.6 | 184.0 |
| 363.2              | 586.0          | 464.1 | 384.9 | 328.3 | 288.7 | 260.4 | 232.1 | 206.6 |
| 385.9              | 608.4          | 502.3 | 420.3 | 359.4 | 319.8 | 288.7 | 257.5 | 229.2 |
| 408.6              | 650.9          | 540.5 | 455.6 | 390.5 | 349.5 | 317.0 | 284.4 | 254.7 |

| kg CO <sub>2</sub> | Time (minutes) |        |       |       |       |       |       |       |
|--------------------|----------------|--------|-------|-------|-------|-------|-------|-------|
|                    | 5              | 10     | 15    | 20    | 30    | 40    | 50    | 60    |
| 431.3              | 696.2          | 580.2  | 491.0 | 421.7 | 379.2 | 345.3 | 311.3 | 277.3 |
| 454.0              | 738.6          | 619.8  | 526.4 | 452.8 | 410.4 | 373.6 | 336.8 | 302.8 |
| 476.7              | 781.1          | 659.4  | 563.2 | 483.9 | 441.5 | 401.9 | 363.7 | 325.5 |
| 499.4              | 823.5          | 696.2  | 595.7 | 515.1 | 469.8 | 430.2 | 389.1 | 350.9 |
| 522.1              | 866.0          | 735.8  | 631.1 | 546.2 | 500.9 | 458.5 | 416.0 | 373.6 |
| 544.8              | 911.3          | 772.6  | 666.5 | 577.3 | 532.0 | 486.8 | 441.5 | 399.0 |
| 567.5              | 953.7          | 812.2  | 701.8 | 609.4 | 561.8 | 515.1 | 467.0 | 421.7 |
| 590.2              | 999.0          | 851.8  | 737.2 | 641.0 | 591.5 | 543.4 | 493.8 | 447.1 |
| 612.9              | 1041.4         | 888.6  | 772.6 | 672.1 | 622.6 | 571.7 | 520.7 | 471.2 |
| 635.6              | 1086.7         | 928.2  | 808.0 | 704.7 | 653.7 | 600.0 | 547.6 | 495.3 |
| 658.3              | 1129.2         | 967.9  | 843.3 | 735.8 | 684.9 | 628.3 | 574.5 | 519.3 |
| 681.0              | 1171.6         | 1007.5 | 878.7 | 766.9 | 713.2 | 656.6 | 600.0 | 543.4 |

### Submitter Information Verification

**Committee:** GFE-AAA

**Submittal Date:** Fri Apr 26 09:58:03 EDT 2019

### Committee Statement

**Committee Statement:** This revision makes it clear that this section addresses electrical equipment and is not intended to address stationary combustion engines and gas turbines.

**Response Message:** FR-7-NFPA 12-2019

[Public Input No. 8-NFPA 12-2018 \[Section No. 5.5.3\]](#)

[Public Input No. 9-NFPA 12-2018 \[Section No. A.5.5.3\]](#)

**First Revision No. 12-NFPA 12-2019 [ Section No. A.4.4.3.3.4 ]****A.4.4.3.3.4**

It is anticipated that full discharge tests will be waived by the authority having jurisdiction only under extremely unusual conditions. Factors such as extra cost and interruptions to production or business operations are not considered valid reasons for waiver of full discharge tests.

The full discharge test is intended to verify the full functionality of the system in accordance with 4.4.4. The test should verify the following:

- (1) That all of the carbon dioxide cylinders open as intended. This can be verified by checking the liquid level gauge on a low-pressure supply or by weighing each cylinder of a high-pressure system. Measurements should be taken before and after discharge.
- (2) That carbon dioxide flows through the pipe network and discharges from each nozzle as intended. This can be verified visually or by use of blow-off caps. Where piping is not normally under pressure, it is possibly not bubbletight. However, where a slow discharge is involved, or if under continual pressure, bubbletightness should be achieved.
- (3) That the time delays, notification appliances, and system interlocks, such as damper closures and/or power shutdown, operate as intended.
- (4) That the discharge performance meets or exceeds the minimum design criteria.
  - (a) For total flooding systems, that a sufficient concentration of carbon dioxide is developed within the maximum time and is held for the intended duration. The carbon dioxide concentration can be verified by use of a gas analyzer or by another means acceptable to the authority having jurisdiction. The sample locations should be selected to show that the extinguishing concentration is achieved throughout the enclosure. The time to achieve the design concentration is measured from the time that the concentration measurement rises above zero to the time at which the benchmark concentration is indicated by the measuring device. If the response time of the instrument circuitry is known to cause a delay in the measurement of concentration, that delay can be considered in determining pass/fail criteria. Refer to 5.5.2.1 and 5.5.2.3 for the time requirements for total flooding systems.
  - (b) For local application systems, that the duration of the liquid discharge meets the design requirements and that the discharge provides adequate coverage on or around the hazard. The discharge duration should be measured at the nozzles with a stopwatch. For local application systems, the watch should be started when all nozzles flow liquid and stopped when the discharge changes from liquid to gas at any nozzle. See 6.3.3 and A.6.3.3.2. Coverage on or around the hazard is visually observed. It is useful, but not required, to use video of the discharge to aid in determining if adequate CO<sub>2</sub> coverage is developed during the discharge test.

Prior to the test, personnel should be warned and removed from the area. The local fire department and any remote monitoring stations should also be notified that a test is being conducted. Following the test, the system should be recharged and reset. For more specific instructions, consult the system manufacturer's installation manual, which should outline the system acceptance test procedures.

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Fri Apr 26 13:06:59 EDT 2019

**Committee Statement**

**Committee Statement:** Paragraph (4) is revised to allow for differences in instrumentation.

**Response Message:** FR-12-NFPA 12-2019

[Public Input No. 14-NFPA 12-2018 \[Section No. 5.5.2.1\]](#)

**First Revision No. 5-NFPA 12-2019 [ Section No. A.4.6.1 ]****A.4.6.1**

Not all of the carbon dioxide in the low-pressure container can be rapidly discharged. As the storage container empties, a quantity of cold carbon dioxide vapor remains in the container and pipe . The quantity of this residual vapor varies, depending on the physical configuration of the container and distribution network . ~~This residual vapor~~ In addition, liquid carbon dioxide can be temporarily trapped in the pipeline and might not be available for immediate discharge into other hazards served by the system. This residual carbon dioxide should be considered in determining the storage capacity.

Where the system provides an extended discharge, additional carbon dioxide could be required to maintain pressure in the supply over the discharge period.

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submission Date:** Thu Apr 25 17:41:46 EDT 2019

**Committee Statement**

**Committee Statement:** This revision recognizes that distribution systems with large internal volumes could require additional carbon dioxide.

Additional guidance is provided for extended discharge systems to ensure that the calculated flow rates can be maintained for the design time.

**Response Message:** FR-5-NFPA 12-2019

Public Input No. 12-NFPA 12-2018 [Section No. 4.6.1 [Excluding any Sub-Sections]]



## First Revision No. 8-NFPA 12-2019 [ Section No. A.5.5.2 ]

### A.5.5.2

The minimum design rates of application established are considered adequate for the usual surface or deep-seated fire. However, where the spread of fire can be faster than normal for the type of fire, or where high values or vital machinery or equipment are involved, rates higher than the minimums can, and in many cases should, be used. Where a hazard contains material that will produce both surface and deep-seated fires, the rate of application should be at least the minimum required for surface fires. Having selected a rate suitable to the hazard, the tables and information that follow should be used or such special engineering as is required should be carried out to obtain the proper combination of container releases, supply piping, and orifice sizes that will produce this desired rate.

The leakage rate from an enclosure in the absence of forced ventilation depends mainly on the difference in density between the atmosphere within the enclosure and the air surrounding the enclosure. The following equation can be used to calculate the rate of carbon dioxide loss, assuming that there is sufficient leakage in the upper part of the enclosure to allow free ingress of air:

$$R = 60C\rho A \sqrt{\frac{2g(\rho_1 - \rho_2)h}{\rho_1}} \quad R = 60C\rho A \sqrt{\frac{2g(\rho_1 - \rho_2)h}{\rho_1}} \quad [\text{A.5.5.2}]$$

where:

$R$  = rate of CO<sub>2</sub> [lb/min (kg/min)]

$C$  = CO<sub>2</sub> concentration fraction

$\rho$  = density of CO<sub>2</sub> vapor [lb/ft<sup>3</sup> (kg/m<sup>3</sup>)]

$A$  = area of opening [ft<sup>2</sup> (m<sup>2</sup>) (flow coefficient included)]\*

$g$  = gravitational constant [32.2 ft/sec<sup>2</sup> (9.81 m/sec<sup>2</sup>)]

$\rho_1$  = density of atmosphere [lb/ft<sup>3</sup> (kg/m<sup>3</sup>)]

$\rho_2$  = density of surrounding air [lb/ft<sup>3</sup> (kg/m<sup>3</sup>)]

$h$  = static head between opening and top of enclosure [ft (m)]

\*If there are openings in the walls only, the area of the wall openings can be divided by 2 for calculations because it is presumed that fresh air can enter through one-half of the openings and that protective gas will exit through the other half.

Figure E.1(b) can be used as a guide in estimating discharge rates for extended discharge systems. The curves were calculated using the preceding equation, assuming a temperature of 70°F (21°C) inside and outside the enclosure. In an actual system, the inside temperature will normally be reduced by the discharge, thus increasing the rate of loss. Because of the many variables involved, a test of the installed system could be needed to ensure proper performance.

Where leakage is appreciable, the design concentration should be obtained quickly and maintained for an extended period of time. Carbon dioxide provided for leakage compensation should be applied at a reduced rate. The extended rate of discharge should be sufficient to maintain the minimum design concentration.

### Submitter Information Verification

**Committee:** GFE-AAA

**Submittal Date:** Fri Apr 26 10:25:06 EDT 2019

### Committee Statement

**Committee Statement:** Corrects equation A.5.5.2, which included the gravitational constant,  $g$ , as a subscript.

The last paragraph is revised to clarify that it is the design concentration that should be maintained, not the minimum extinguishing concentration.

**Response Message:** FR-8-NFPA 12-2019

[Public Input No. 6-NFPA 12-2018 \[Section No. A.5.5.2\]](#)



First Revision No. 9-NFPA 12-2019 [ Section No. C.1 ]

C.1



Computing pipe sizes for carbon dioxide systems is complicated by the fact that the pressure drop is nonlinear with respect to the pipeline. Carbon dioxide leaves the storage vessel as a liquid at saturation pressure. As the pressure drops due to pipeline friction, the liquid boils and produces a mixture of liquid and vapor. Consequently, the volume of the flowing mixture increases and the velocity of flow must also increase. Thus, the pressure drop per unit length of pipe is greater near the end of the pipeline than it is at the beginning.

Pressure drop information for designing piping systems can best be obtained from curves of pressure versus equivalent length for various flow rates and pipe sizes. Such curves can be plotted using the theoretical equation given in 4.7.5.1. The Y and Z factors in the equation in that paragraph depend on storage pressure and line pressure. In the following equations, Z is a dimensionless ratio, and the Y factor has units of pressure times density and will therefore change the system of units. The Y and Z factors can be evaluated as follows:

$$Y = -\int_{P_1}^P \rho dP$$

$$Z = -\int_{P_1}^P \frac{dP}{P} = \ln \frac{P_1}{P}$$

[C.1a]

where:

P = pressure at end of pipeline [psi (kPa)]

P<sub>1</sub> = storage pressure [psi (kPa)]

ρ = density at pressure P [lb/ft<sup>3</sup> (kg/m<sup>3</sup>)]

P<sub>1</sub> = density at pressure P<sub>1</sub> [lb/ft<sup>3</sup> (kg/m<sup>3</sup>)]

ln = natural logarithm

The storage pressure is an important factor in carbon dioxide flow. In low-pressure storage, the starting pressure in the storage vessel will recede to a lower level, depending on whether all or only part of the supply is discharged. Because of this, the average pressure during discharge will be about 285 psi (1965 kPa). The flow equation is based on absolute pressure; therefore, 300 psi (2068 kPa) is used for calculations involving low-pressure systems.

In high-pressure systems, the storage pressure depends on the ambient temperature. Normal ambient temperature is assumed to be 70°F (21°C). For this condition, the average pressure in the cylinder during discharge of the liquid portion will be about 750 psi (5171 kPa). This pressure has therefore been selected for calculations involving high-pressure systems.

Using the base pressures of 300 psi (2068 kPa) and 750 psi (5171 kPa), values have been determined for the Y and Z factors in the flow equation. These values are listed in Table C.1(a) and Table C.1(b).

Table C.1(a) Values of Y and Z for 300 psi Initial Storage Pressure

| Pressure<br>(psi) | Z     | Y    |      |      |      |      |      |      |      |      |      |   |
|-------------------|-------|------|------|------|------|------|------|------|------|------|------|---|
|                   |       | 0    | 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    |   |
| 300               | 0.000 | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0 |
| 290               | 0.135 | 596  | 540  | 483  | 426  | 367  | 308  | 248  | 187  | 126  | 63   |   |
| 280               | 0.264 | 1119 | 1070 | 1020 | 969  | 918  | 866  | 814  | 760  | 706  | 652  |   |
| 270               | 0.387 | 1580 | 1536 | 1492 | 1448 | 1402 | 1357 | 1310 | 1263 | 1216 | 1168 |   |
| 260               | 0.505 | 1989 | 1950 | 1911 | 1871 | 1831 | 1790 | 1749 | 1708 | 1666 | 1623 |   |
| 250               | 0.620 | 2352 | 2318 | 2283 | 2248 | 2212 | 2176 | 2139 | 2102 | 2065 | 2027 |   |
| 240               | 0.732 | 2677 | 2646 | 2615 | 2583 | 2552 | 2519 | 2487 | 2454 | 2420 | 2386 |   |
| 230               | 0.841 | 2968 | 2940 | 2912 | 2884 | 2855 | 2826 | 2797 | 2768 | 2738 | 2708 |   |
| 220               | 0.950 | 3228 | 3204 | 3179 | 3153 | 3128 | 3102 | 3075 | 3049 | 3022 | 2995 |   |
| 210               | 1.057 | 3462 | 3440 | 3418 | 3395 | 3372 | 3349 | 3325 | 3301 | 3277 | 3253 |   |
| 200               | 1.165 | 3673 | 3653 | 3632 | 3612 | 3591 | 3570 | 3549 | 3528 | 3506 | 3485 |   |
| 190               | 1.274 | 3861 | 3843 | 3825 | 3807 | 3788 | 3769 | 3750 | 3731 | 3712 | 3692 |   |
| 180               | 1.384 | 4030 | 4014 | 3998 | 3981 | 3965 | 3948 | 3931 | 3914 | 3896 | 3879 |   |
| 170               | 1.497 | 4181 | 4167 | 4152 | 4138 | 4123 | 4108 | 4093 | 4077 | 4062 | 4046 |   |
| 160               | 1.612 | 4316 | 4303 | 4291 | 4277 | 4264 | 4251 | 4237 | 4223 | 4210 | 4196 |   |
| 150               | 1.731 | 4436 | 4425 | 4413 | 4402 | 4390 | 4378 | 4366 | 4354 | 4341 | 4329 |   |

Table C.1(b) Values of Y and Z for 750 psi Initial Storage Pressure

| Pressure<br>(psi) | Z     | Y    |      |      |      |      |      |      |      |      |      |   |
|-------------------|-------|------|------|------|------|------|------|------|------|------|------|---|
|                   |       | 0    | 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    |   |
| 750               | 0.000 | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0    | 0 |
| 740               | 0.038 | 497  | 448  | 399  | 350  | 300  | 251  | 201  | 151  | 101  | 51   |   |
| 730               | 0.075 | 975  | 928  | 881  | 833  | 786  | 738  | 690  | 642  | 594  | 545  |   |
| 720               | 0.110 | 1436 | 1391 | 1345 | 1299 | 1254 | 1208 | 1161 | 1115 | 1068 | 1022 |   |
| 710               | 0.143 | 1882 | 1838 | 1794 | 1750 | 1706 | 1661 | 1616 | 1572 | 1527 | 1481 |   |
| 700               | 0.174 | 2314 | 2271 | 2229 | 2186 | 2143 | 2100 | 2057 | 2013 | 1970 | 1926 |   |
| 690               | 0.205 | 2733 | 2691 | 2650 | 2608 | 2567 | 2525 | 2483 | 2441 | 2399 | 2357 |   |
| 680               | 0.235 | 3139 | 3099 | 3059 | 3018 | 2978 | 2937 | 2897 | 2856 | 2815 | 2774 |   |
| 670               | 0.265 | 3533 | 3494 | 3455 | 3416 | 3377 | 3338 | 3298 | 3259 | 3219 | 3179 |   |
| 660               | 0.296 | 3916 | 3878 | 3840 | 3802 | 3764 | 3726 | 3688 | 3649 | 3611 | 3572 |   |
| 650               | 0.327 | 4286 | 4250 | 4213 | 4176 | 4139 | 4102 | 4065 | 4028 | 3991 | 3953 |   |


| Pressure<br>(psi) | Z     | Y     |       |       |       |       |       |       |       |       |       |
|-------------------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|
|                   |       | 0     | 1     | 2     | 3     | 4     | 5     | 6     | 7     | 8     | 9     |
| 640               | 0.360 | 4645  | 4610  | 4575  | 4539  | 4503  | 4467  | 4431  | 4395  | 4359  | 4323  |
| 630               | 0.393 | 4993  | 4959  | 4924  | 4890  | 4855  | 4821  | 4786  | 4751  | 4716  | 4681  |
| 620               | 0.427 | 5329  | 5296  | 5263  | 5229  | 5196  | 5162  | 5129  | 5095  | 5061  | 5027  |
| 610               | 0.462 | 5653  | 5621  | 5589  | 5557  | 5525  | 5493  | 5460  | 5427  | 5395  | 5362  |
| 600               | 0.498 | 5967  | 5936  | 5905  | 5874  | 5843  | 5811  | 5780  | 5749  | 5717  | 5685  |
| 590               | 0.535 | 6268  | 6239  | 6209  | 6179  | 6149  | 6119  | 6089  | 6058  | 6028  | 5997  |
| 580               | 0.572 | 6560  | 6531  | 6502  | 6473  | 6444  | 6415  | 6386  | 6357  | 6328  | 6298  |
| 570               | 0.609 | 6840  | 6812  | 6785  | 6757  | 6729  | 6701  | 6673  | 6645  | 6616  | 6588  |
| 560               | 0.646 | 7110  | 7084  | 7057  | 7030  | 7003  | 6976  | 6949  | 6922  | 6895  | 6868  |
| 550               | 0.683 | 7371  | 7345  | 7320  | 7294  | 7268  | 7242  | 7216  | 7190  | 7163  | 7137  |
| 540               | 0.719 | 7622  | 7597  | 7572  | 7548  | 7523  | 7498  | 7472  | 7447  | 7422  | 7396  |
| 530               | 0.756 | 7864  | 7840  | 7816  | 7792  | 7768  | 7744  | 7720  | 7696  | 7671  | 7647  |
| 520               | 0.792 | 8098  | 8075  | 8052  | 8028  | 8005  | 7982  | 7958  | 7935  | 7911  | 7888  |
| 510               | 0.827 | 8323  | 8301  | 8278  | 8256  | 8234  | 8211  | 8189  | 8166  | 8143  | 8120  |
| 500               | 0.863 | 8540  | 8519  | 8497  | 8476  | 8454  | 8433  | 8411  | 8389  | 8367  | 8345  |
| 490               | 0.898 | 8750  | 8730  | 8709  | 8688  | 8667  | 8646  | 8625  | 8604  | 8583  | 8562  |
| 480               | 0.933 | 8953  | 8933  | 8913  | 8893  | 8873  | 8852  | 8832  | 8812  | 8791  | 8771  |
| 470               | 0.967 | 9149  | 9129  | 9110  | 9091  | 9071  | 9052  | 9032  | 9012  | 8993  | 8973  |
| 460               | 1.002 | 9338  | 9319  | 9301  | 9282  | 9263  | 9244  | 9225  | 9206  | 9187  | 9168  |
| 450               | 1.038 | 9520  | 9502  | 9484  | 9466  | 9448  | 9430  | 9412  | 9393  | 9375  | 9356  |
| 440               | 1.073 | 9697  | 9680  | 9662  | 9644  | 9627  | 9609  | 9592  | 9574  | 9556  | 9538  |
| 430               | 1.109 | 9866  | 9850  | 9833  | 9816  | 9799  | 9782  | 9765  | 9748  | 9731  | 9714  |
| 420               | 1.146 | 10030 | 10014 | 9998  | 9982  | 9966  | 9949  | 9933  | 9916  | 9900  | 9883  |
| 410               | 1.184 | 10188 | 10173 | 10157 | 10141 | 10126 | 10110 | 10094 | 10078 | 10062 | 10046 |
| 400               | 1.222 | 10340 | 10325 | 10310 | 10295 | 10280 | 10265 | 10250 | 10234 | 10219 | 10204 |
| 390               | 1.262 | 10486 | 10472 | 10458 | 10443 | 10429 | 10414 | 10399 | 10385 | 10370 | 10355 |
| 380               | 1.302 | 10627 | 10613 | 10599 | 10585 | 10571 | 10557 | 10543 | 10529 | 10515 | 10501 |
| 370               | 1.344 | 10762 | 10749 | 10735 | 10722 | 10708 | 10695 | 10681 | 10668 | 10654 | 10641 |
| 360               | 1.386 | 10891 | 10878 | 10866 | 10853 | 10840 | 10827 | 10814 | 10801 | 10788 | 10775 |
| 350               | 1.429 | 11015 | 11003 | 10991 | 10978 | 10966 | 10954 | 10941 | 10929 | 10916 | 10904 |
| 340               | 1.473 | 11134 | 11122 | 11110 | 11099 | 11087 | 11075 | 11063 | 11051 | 11039 | 11027 |
| 330               | 1.518 | 11247 | 11236 | 11225 | 11214 | 11202 | 11191 | 11180 | 11168 | 11157 | 11145 |
| 320               | 1.564 | 11356 | 11345 | 11334 | 11323 | 11313 | 11302 | 11291 | 11280 | 11269 | 11258 |
| 310               | 1.610 | 11459 | 11449 | 11439 | 11428 | 11418 | 11408 | 11398 | 11387 | 11377 | 11366 |
| 300               | 1.657 | 11558 | 11548 | 11539 | 11529 | 11519 | 11509 | 11499 | 11489 | 11479 | 11469 |

For practical application, it is desirable to plot curves for each pipe size that can be used. However, the flow equation can be rearranged as shown in the following equation:

$$\frac{L}{D^{1.25}} = \frac{3647Y}{\left(\frac{Q}{D^2}\right)^2} - 8.08Z \quad \text{[C.1b]}$$

Thus, by plotting values of  $L/D^{1.25}$  and  $Q/D^2$ , it is possible to use one family of curves for any pipe size. Figure C.1(a) gives flow information for 0°F (-18°C) storage temperature on this basis. Figure C.1(b) gives similar information for high-pressure storage at 70°F (21°C). For an inside pipe diameter of exactly 1 in.,  $D^2$  and  $D^{1.25}$  reduce to unity and cancel out. For other pipe sizes, it is necessary to convert the flow rate and equivalent length by dividing or multiplying by these factors. Table C.1(c) gives values for  $D$ .

Figure C.1(a) Pressure Drop in Pipeline for 300 psi (2068 kPa) Storage Pressure.






Figure C.1(b) Pressure Drop in Pipeline for 750 psi (5171 kPa) Storage Pressure.





Table C.1(c) Values of  $D^{1.25}$  and  $D^2$  for Various Pipe Sizes

| Pipe Size and Type | Inside Diameter (in.) | $D^{1.25}$ | $D^2$  |
|--------------------|-----------------------|------------|--------|
| ½ Std.             | 0.622                 | 0.5521     | 0.3869 |
| ¾ Std.             | 0.824                 | 0.785      | 0.679  |
| 1 Std.             | 1.049                 | 1.0615     | 1.100  |
| 1 XH               | 0.957                 | 0.9465     | 0.9158 |
| 1¼ Std.            | 1.380                 | 1.496      | 1.904  |
| 1¼ XH              | 1.278                 | 1.359      | 1.633  |
| 1½ Std.            | 1.610                 | 1.813      | 2.592  |
| 1½ XH              | 1.500                 | 1.660      | 2.250  |
| 2 Std.             | 2.067                 | 2.475      | 4.272  |
| 2 XH               | 1.939                 | 2.288      | 3.760  |
| 2½ Std.            | 2.469                 | 3.09       | 6.096  |
| 2½ XH              | 2.323                 | 2.865      | 5.396  |
| 3 Std.             | 3.068                 | 4.06       | 9.413  |

| Pipe Size and Type | Inside Diameter (in.) | $D^{1.25}$ | $D^2$ |
|--------------------|-----------------------|------------|-------|
| 3 XH               | 2.900                 | 3.79       | 8.410 |
| 4 Std.             | 4.026                 | 5.71       | 16.21 |
| 4 XH               | 3.826                 | 5.34       | 14.64 |
| 5 Std.             | 5.047                 | 7.54       | 25.47 |
| 5 XH               | 4.813                 | 7.14       | 23.16 |
| 6 Std.             | 6.065                 | 9.50       | 36.78 |
| 6 XH               | 5.761                 | 8.92       | 33.19 |

These curves can be used for designing systems or for checking possible flow rates. For example, assume the problem is to determine the terminal pressure for a low-pressure system consisting of a single 2 in. Schedule 40 pipeline with an equivalent length of 500 ft and a flow rate of 1000 lb/min. The flow rate and the equivalent length must be converted to terms of Figure C.1(a) as follows:

$$\frac{Q}{D^2} = \frac{1000}{4.28} = 234 \text{ lb/min} \cdot \text{in.}^2 \quad [\text{C.1c}]$$

$$\frac{L}{D^{1.25}} = \frac{500}{2.48} = 201 \text{ ft/in.}^{1.25}$$

From Figure C.1(a), the terminal pressure is found to be about 228 psi at the point where the interpolated flow rate of 234 lb/min intersects the equivalent length scale at 201 ft.

If this line terminates in a single nozzle, the equivalent orifice area must be matched to the terminal pressure in order to control the flow rate at the desired level of 1000 lb/min. Referring to Table 4.7.5.2.1, it will be noted that the discharge rate will be 1410 lb/min $\cdot$ in. $^2$  of equivalent orifice area when the orifice pressure is 230 psi. The required equivalent orifice area of the nozzle is thus equal to the total flow rate divided by the rate per square inch, as shown in the following equation:

$$\text{Equivalent orifice area} = \frac{1000 \text{ lb/min}}{1410 \text{ lb/min} \cdot \text{in.}^2} = 0.709 \text{ in.}^2 \quad [\text{C.1d}]$$

From a practical viewpoint, the designer would select a standard nozzle having an equivalent area nearest to the computed area. If the orifice area happened to be a little larger, the actual flow rate would be slightly higher and the terminal pressure would be somewhat lower than the estimated 228 psi (1572 kPa).

If, in the previous example, instead of terminating with one large nozzle, the pipeline branched into two smaller pipelines, it would be necessary to determine the pressure at the end of each branch line. To illustrate this procedure, assume that the branch lines are equal and consist of 1½ in. Schedule 40 pipe with equivalent lengths of 200 ft (61 m) and that the flow in each branch line is to be 500 lb/min (227 kg/min). Converting to terms used in Figure C.1(a), the following equations result:

$$\frac{Q}{D^2} = \frac{500}{2.592} = 193 \text{ lb/min} \cdot \text{in.}^2 \quad [\text{C.1e}]$$

$$\frac{L}{D^{1.25}} = \frac{200}{1.813} = 110 \text{ ft/in.}^{1.25}$$

From Figure C.1(a), the starting pressure of 228 psi (1572 kPa) (terminal pressure of main line) intersects the flow rate line [193 lb/min (87.6 kg/min)] at an equivalent length of about 300 ft (91.4 m). In other words, if the branch line started at the storage vessel, the liquid carbon dioxide would have to flow through 300 ft (91.4 m) of pipeline before the pressure dropped to 228 psi (1572 kPa). This length thus becomes the starting point for the equivalent length of the branch line. The terminal pressure of the branch line is then found to be 165 psi (1138 kPa) at the point where the 193 lb/min (87.6 kg/min) flow rate line intersects the total equivalent length line of 410 ft (125 m), or 300 ft + 110 ft (91 m + 34 m). With this new terminal pressure [165 psi (1138 kPa)] and flow rate [500 lb/min (227 kg/min)], the required equivalent nozzle area at the end of each branch line will be approximately 0.567 in. $^2$  (366 mm $^2$ ). This is about the same as the single large nozzle example, except that the discharge rate is cut in half due to the reduced pressure.

The design of the piping distribution system is based on the flow rate desired at each nozzle. This in turn determines the required flow rate in the branch lines and the main pipeline. From practical experience, it is possible to estimate the approximate pipe sizes required. The pressure at each nozzle can be determined from suitable flow curves. The nozzle orifice sizes are then selected on the basis of nozzle pressure from the data given in 4.7.5.2.

In high-pressure systems, the main header is supplied by a number of separate cylinders. The total flow is thus divided by the number of cylinders to obtain the flow rate from each cylinder. The flow capacity of the cylinder valve and the connector to the header vary with each manufacturer, depending on design and size. For any particular valve, dip tube, and connector assembly, the equivalent length can be determined in terms of feet of standard pipe size. With this information, the flow equation can be used to prepare a curve of flow rate versus pressure drop. This curve provides a convenient method of determining header pressure for a specific valve and connector combination.

Table C.1(d) and Table C.1(e) list the equivalent lengths of pipe fittings for determining the equivalent length of piping systems. Table C.1(d) is for threaded joints, and Table C.1(e) is for welded joints. Both tables were computed for Schedule 40 pipe sizes; however, for all practical purposes, the same figures can also be used for Schedule 80 pipe sizes. These tables should be used to determine the equivalent length of pipe for fittings unless manufacturer's test data indicate that other factors are appropriate. For mechanical grooved fittings listed for use in carbon dioxide systems, equivalent length data should be obtained from the manufacturer.

Table C.1(d) Equivalent Lengths in Feet of Threaded Pipe Fitting

| Pipe Size (in.) | Elbow Std. |            | Elbow 90 Degrees Long Radius and Tee Thru Flow | Tee  |                              |
|-----------------|------------|------------|------------------------------------------------|------|------------------------------|
|                 | 45 Degrees | 90 Degrees |                                                | Side | Union Coupling or Gate Valve |
| ¾               | 0.6        | 1.3        | 0.8                                            | 2.7  | 0.3                          |
| ½               | 0.8        | 1.7        | 1.0                                            | 3.4  | 0.4                          |
| ¾               | 1.0        | 2.2        | 1.4                                            | 4.5  | 0.5                          |
| 1               | 1.3        | 2.8        | 1.8                                            | 5.7  | 0.6                          |
| 1¼              | 1.7        | 3.7        | 2.3                                            | 7.5  | 0.8                          |

| Pipe Size<br>(in.) | Elbow                    |                          |                                          | Tee  |                              |
|--------------------|--------------------------|--------------------------|------------------------------------------|------|------------------------------|
|                    | Elbow Std.<br>45 Degrees | Elbow Std.<br>90 Degrees | 90 Degrees Long Radius and Tee Thru Flow | Side | Union Coupling or Gate Valve |
| 1½                 | 2.0                      | 4.3                      | 2.7                                      | 8.7  | 0.9                          |
| 2                  | 2.6                      | 5.5                      | 3.5                                      | 11.2 | 1.2                          |
| 2½                 | 3.1                      | 6.6                      | 4.1                                      | 13.4 | 1.4                          |
| 3                  | 3.8                      | 8.2                      | 5.1                                      | 16.6 | 1.8                          |
| 4                  | 5.0                      | 10.7                     | 6.7                                      | 21.8 | 2.4                          |
| 5                  | 6.3                      | 13.4                     | 8.4                                      | 27.4 | 3.0                          |
| 6                  | 7.6                      | 16.2                     | 10.1                                     | 32.8 | 3.5                          |

For SI units, 1 ft = 0.3048 m.

Table C.1(e) Equivalent Lengths in Feet of Welded Pipe Fitting

| Pipe Size<br>(in.) | Elbow                 |                       |                                          | Tee  |            |
|--------------------|-----------------------|-----------------------|------------------------------------------|------|------------|
|                    | Elbow Std. 45 Degrees | Elbow Std. 90 Degrees | 90 Degrees Long Radius and Tee Thru Flow | Side | Gate Valve |
| ¾                  | 0.2                   | 0.7                   | 0.5                                      | 1.6  | 0.3        |
| ½                  | 0.3                   | 0.8                   | 0.7                                      | 2.1  | 0.4        |
| ¾                  | 0.4                   | 1.1                   | 0.9                                      | 2.8  | 0.5        |
| 1                  | 0.5                   | 1.4                   | 1.1                                      | 3.5  | 0.6        |
| 1¼                 | 0.7                   | 1.8                   | 1.5                                      | 4.6  | 0.8        |
| 1½                 | 0.8                   | 2.1                   | 1.7                                      | 5.4  | 0.9        |
| 2                  | 1.0                   | 2.8                   | 2.2                                      | 6.9  | 1.2        |
| 2½                 | 1.2                   | 3.3                   | 2.7                                      | 8.2  | 1.4        |
| 3                  | 1.8                   | 4.1                   | 3.3                                      | 10.2 | 1.8        |
| 4                  | 2.0                   | 5.4                   | 4.4                                      | 13.4 | 2.4        |
| 5                  | 2.5                   | 6.7                   | 5.5                                      | 16.8 | 3.0        |
| 6                  | 3.0                   | 8.1                   | 6.6                                      | 20.2 | 3.5        |

For SI units, 1 ft = 0.3048 m.

For nominal changes in elevation of piping, the change in head pressure is negligible. However, if there is a substantial change in elevation, this factor should be taken into account. The head pressure correction per foot of elevation depends on the average line pressure where the elevation takes place because the density changes with pressure. Correction factors are given in Table C.1(f) and Table C.1(g) for low-pressure and high-pressure systems, respectively. The correction is subtracted from the terminal pressure when the flow is upward and is added to the terminal pressure when the flow is downward.

Table C.1(f) Elevation Correction Factors for Low-Pressure System

|     | Average Line Pressure |     | Elevation Correction |       |
|-----|-----------------------|-----|----------------------|-------|
|     | psi                   | kPa | psi/ft               | kPa/m |
| 300 | 2068                  |     | 0.443                | 10.00 |
| 280 | 1930                  |     | 0.343                | 7.76  |
| 260 | 1792                  |     | 0.265                | 5.99  |
| 240 | 1655                  |     | 0.207                | 4.68  |
| 220 | 1517                  |     | 0.167                | 3.78  |
| 200 | 1379                  |     | 0.134                | 3.03  |
| 180 | 1241                  |     | 0.107                | 2.42  |
| 160 | 1103                  |     | 0.085                | 1.92  |
| 140 | 965                   |     | 0.067                | 1.52  |

Table C.1(g) Elevation Correction Factors for High-Pressure System

|     | Average Line Pressure |     | Elevation Correction |       |
|-----|-----------------------|-----|----------------------|-------|
|     | psi                   | kPa | psi/ft               | kPa/m |
| 750 | 5171                  |     | 0.352                | 7.96  |
| 700 | 4826                  |     | 0.300                | 6.79  |
| 650 | 4482                  |     | 0.255                | 5.77  |
| 600 | 4137                  |     | 0.215                | 4.86  |
| 550 | 3792                  |     | 0.177                | 4.00  |
| 500 | 3447                  |     | 0.150                | 3.39  |
| 450 | 3103                  |     | 0.125                | 2.83  |
| 400 | 2758                  |     | 0.105                | 2.38  |
| 350 | 2413                  |     | 0.085                | 1.92  |
| 300 | 2068                  |     | 0.070                | 1.58  |

### Supplemental Information

|                  |                             |
|------------------|-----------------------------|
| <b>File Name</b> | <b>Description Approved</b> |
| 12_FR9_C.1.docx  | STAFF USE                   |

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Fri Apr 26 11:49:03 EDT 2019

**Committee Statement**

**Committee Statement:** This revision corrects the units for  $Q/D^2$  in Figures C.1(a) and C.1(b), which should be lb/min-in<sup>2</sup>.

Additional guidance is provided for calculating systems that use fittings not addressed by the existing tables.

**Response Message:** FR-9-NFPA 12-2019

[Public Input No. 15-NFPA 12-2018 \[Section No. C.1\]](#)

**First Revision No. 10-NFPA 12-2019 [ New Section after G.1 ]****G.2**

Additional information on the physical properties of carbon dioxide can be found in the SFPE *Handbook of Fire Protection Engineering* .

**Submitter Information Verification**

**Committee:** GFE-AAA

**Submittal Date:** Fri Apr 26 12:16:10 EDT 2019

**Committee Statement**

**Committee Statement:** The information provided in the SFPE Handbook can be useful for users of the standard.

**Response Message:** FR-10-NFPA 12-2019

Public Input No. 5-NFPA 12-2018 [New Section after G.1]



First Revision No. 11-NFPA 12-2019 [ Section No. G.1 ]



G.1

Carbon dioxide is present in the atmosphere at an average concentration of about 0.03 percent ~~0.04 percent~~ by volume. It is also a normal end product of human and animal metabolism. Carbon dioxide influences certain vital functions in a number of important ways, including control of respiration, dilation and constriction of the vascular system — particularly the cerebrum — and the pH of body fluids. The concentration of carbon dioxide in the air governs the rate at which carbon dioxide is released from the lungs and thus affects the concentration of carbon dioxide in the blood and tissues. An increasing concentration of carbon dioxide in air can, therefore, become dangerous due to a reduction in the rate of release of carbon dioxide from the lungs and decreased oxygen intake. [Further details of carbon dioxide exposure can be obtained from DHHS (NIOSH) Publication No. 76-194.] Personnel safety considerations are covered in Section 4.3.

Table G.1 provides information on acute health effects of high concentrations of carbon dioxide.

Table G.1 Acute Health Effects of High Concentrations of Carbon Dioxide (with Increasing Exposure Levels of Carbon Dioxide)

| Concentration of Carbon Dioxide in Air (%) | Time                 | Effects                                                                                                           |
|--------------------------------------------|----------------------|-------------------------------------------------------------------------------------------------------------------|
| 2                                          | Several hours        | Headache, dyspnea upon mild exertion                                                                              |
| 3                                          | 1 hour               | Dilation of cerebral blood vessels, increased pulmonary ventilation, and increased oxygen delivery to the tissues |
| 4–5                                        | Within a few minutes | Mild headache, sweating, and dyspnea at rest                                                                      |
| 6                                          | 1–2 minutes          | Hearing and visible disturbances                                                                                  |
|                                            | <16 minutes          | Headache and dyspnea                                                                                              |
|                                            | Several hours        | Tremors                                                                                                           |
| 7–10                                       | Few minutes          | Unconsciousness or near unconsciousness                                                                           |
|                                            | 1.5 minutes–1 hour   | Headache, increased heart rate, shortness of breath, dizziness, sweating, rapid breathing                         |
| 10–15                                      | 1+ minute            | Dizziness, drowsiness, severe muscle twitching, and unconsciousness                                               |
| 17–30                                      | <1 minute            | Loss of controlled and purposeful activity, unconsciousness, convulsions, coma, and death                         |

Source: EPA 430-R-00-002, February 2000.


Carbon dioxide is a standard commercial product with many uses. It is perhaps most familiar as the gas that gives the “fizz” in soda pop and other carbonated beverages. In industrial applications, it is used for its chemical properties, its mechanical properties as a pressurizing agent, or its refrigerating properties as dry ice.

For fire-extinguishing applications, carbon dioxide has a number of desirable properties. It is noncorrosive, nondamaging, and leaves no residue to clean up after the fire. It provides its own pressure for discharge through pipes and nozzles. Because it is a gas, it will penetrate and spread to all parts of a hazard. It will not conduct electricity and can therefore be used on live electrical hazards. It can effectively be used on practically all combustible materials except for a few active metals and metal hydrides and materials, such as cellulose nitrate, that contain available oxygen.

Under normal conditions, carbon dioxide is an odorless, colorless gas with a density about 50 percent greater than the density of air. Many people insist they can detect an odor of carbon dioxide, but this could be due to impurities or chemical effects in the nostrils. Carbon dioxide is easily liquefied by compression and cooling. By further cooling and expansion, it can be converted to the solid state.

The relationship between the temperature and the pressure of liquid carbon dioxide is shown on the curve given in Figure G.1. As the temperature of the liquid increases, the pressure also increases. As the pressure increases, the density of the vapor over the liquid increases. On the other hand, the liquid expands as the temperature goes up and its density decreases. At 87.8°F (31°C), the liquid and the vapor have the same density, and of course the liquid phase disappears. This is called the critical temperature for carbon dioxide. Below the critical temperature [87.8°F (31°C)], carbon dioxide in a closed container is part liquid and part gas. Above the critical temperature, it is entirely gas.

Figure G.1 Variation of Pressure of Carbon Dioxide with Change in Temperature (constant volume).



An unusual property of carbon dioxide is the fact that it cannot exist as a liquid at pressures below 60.4 psi [75 psi absolute (517 kPa)]. This is the triple point pressure where carbon dioxide could be present as a solid, a liquid, or a vapor. Below this pressure, it must be either a solid or a

gas, depending on the temperature.

If the pressure in a storage container is reduced by bleeding off vapor, some of the liquid will vaporize and the remaining liquid will become colder. At 60.4 psi [75 psi absolute (517 kPa)], the remaining liquid will be converted to dry ice at a temperature of  $-69.9^{\circ}\text{F}$  ( $-57^{\circ}\text{C}$ ). Further reduction in the pressure to atmospheric will lower the temperature of the dry ice to the normal  $-109.3^{\circ}\text{F}$  ( $-79^{\circ}\text{C}$ ).

The same process takes place when liquid carbon dioxide is discharged to the atmosphere. A large portion of the liquid flashes to vapor with a considerable increase in volume. The rest is converted to finely divided particles of dry ice at  $-109.3^{\circ}\text{F}$  ( $-79^{\circ}\text{C}$ ). It is this dry ice or snow that gives the discharge its typical white cloudy appearance. The low temperature also causes the condensation of water from the entrained air so that ordinary water fog tends to persist for a while after the dry ice has sublimed.

Carbon dioxide is a colorless, odorless, electrically nonconductive inert gas that is a suitable medium for extinguishing fires. Liquid carbon dioxide forms solid dry ice ("snow") when released directly into the atmosphere. Carbon dioxide gas is 1.5 times heavier than air. Carbon dioxide extinguishes fire by reducing the concentrations of oxygen, the vapor phase of the fuel, or both in the air to the point where combustion stops. (See Section 4.3.)

Carbon dioxide fire-extinguishing systems are useful within the limits of this standard in extinguishing fires involving specific hazards or equipment in the following occupancies:

- (1) Where an inert electrically nonconductive medium is essential or desirable
- (2) Where cleanup of other media presents a problem
- (3) Where such systems are more economical to install than systems using other media

Some of the types of hazards and equipment that carbon dioxide systems can satisfactorily protect include the following:

- (1) Flammable liquid materials (See 4.5.4.9.)
- (2) Electrical hazards such as transformers, switches, circuit breakers, rotating equipment, and electronic equipment
- (3) Engines utilizing gasoline and other flammable liquid fuels
- (4) Ordinary combustibles such as paper, wood, and textiles
- (5) Hazardous solids

### Submitter Information Verification

**Committee:** GFE-AAA

**Submittal Date:** Fri Apr 26 12:18:43 EDT 2019

### Committee Statement

**Committee Statement:** The percentage of carbon dioxide in the atmosphere is updated.

**Response Message:** FR-11-NFPA 12-2019