



Tentative Interim Amendment

NFPA[®] 13

Standard for the Installation of Sprinkler Systems

2022 Edition

Reference: A.8.2.6.4.1

TIA 22-5

(SC 22-8-12 / TIA Log #1641)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2019 edition. The TIA was processed by the Technical Committee on Sprinkler System Installation Criteria, and the Correlating Committee on Automatic Sprinkler Systems, and was issued by the Standards Council on August 12, 2022, with an effective date of September 1, 2022.

I. Revise Annex A.8.2.6.4.1 to read as follows:

A.8.2.6.4.1 The connection from an air compressor to the dry pipe valve should be of a type recommended by the manufacturer and approved by the authority having jurisdiction, taking into consideration the pressures, temperatures, and vibrations that the connection and adjacent equipment will endure. ~~Flexible hose should be considered suitable when capable of withstanding expected vibration, a maximum pressure of 175 psi (12 bar) or greater, and a maximum temperature of 150°F (66°C) or greater.~~

Issue Date: August 12, 2022

Effective Date: September 1, 2022

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2022 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION