



NATIONAL FIRE PROTECTION ASSOCIATION

The leading information and knowledge resource on fire, electrical and related hazards

NFPA Technical Committee on Fixed Guideway Transit and Passenger Rail Systems (FKT-AAA)

NFPA 130 FIRST DRAFT MEETING AGENDA

October 26-29, 2020

12:00 pm – 4:00 pm (EST)

Web/Teleconference

Monday, October 26, 2020

1. Call to Order -12:00 pm
2. Attendance and Voting Members (Page 3)
3. Review Agenda
4. NFPA Staff Liaison Presentation and Review of Key Dates (Page 8)
5. Chairman's Remarks
6. Approval of Previous Meeting Minutes (October 2-4, 2018) (Page 24)
7. Act on hundred and fifty nine (159) Public Inputs for NFPA 130 (Page 29)
 - a. Chapter 5 Task Group Reports and Recommended Actions (38 PI's)
 - b. Chapter 12 Task Group Reports and Recommended Actions (16 PI's)
8. Recess 2:00 pm
9. Call to Order – 2:15 pm
10. Recess 4:00 pm

Tuesday, October 27, 2020

1. Call to Order -12:00 pm
2. Act on Public Comments for NFPA 130 (159)
 - a. Chapter 6 Task Group Reports and Recommended Actions (24 PI's)
 - b. Chapter 7 Task Group Reports and Recommended Actions (6 PI's)
3. Recess 2:00 pm
4. Call to Order – 2:15 pm
5. Recess – 4:00 pm

Wednesday, October 28, 2020

1. Call to Order -12:00 pm
2. Act on Public Comments for NFPA 130 (159)
 - a. Chapter 8 Task Group Reports and Recommended Actions (17 PI's)
 - b. Other PI's (Chapters 1, 2, 3, 9, 10, 11, A, B, C, E, G: 58 PI's)
3. Recess 2:00 pm
4. Call to Order – 2:15 pm
5. Recess – 4:00 pm

Thursday, October 29, 2020

1. Call to Order -12:00 pm
2. Actions on Public Inputs for NFPA 130 (159)
 - Other PI's (Chapters 1, 2, 3, 9, 10, 11, A, B, C, E, G: 58 PI's)
3. Recess 2:00 pm
4. Call to Order – 2:15 pm
5. New Business
 - Assignment of new task groups
6. Next Meeting
7. Adjourn 4:00pm

Address List No Phone

10/13/2020
Baran Ozden
FKT-AAA

Fixed Guideway Transit and Passenger Rail Systems

Jarrold Alston	SE 8/9/2011	Richard M. Arvin	U 04/04/2017
Chair Arup 955 Massachusetts Avenue Cambridge, MA 02139-3180 Alternate: Matthew W. Davy	FKT-AAA	Principal Annapolis Fire & Life Safety Engineering 508 Kansala Drive Annapolis, MD 21401-8100 Washington Metropolitan Area Transit Authority (WMATA) Alternate: Neil E. Nott	FKT-AAA
Kenneth E. Bush	E 08/08/2019	David M. Casselman	SE 1/1/1990
Principal Maryland State Fire Marshals Office 301 Bay Street, Lower Level Easton, MD 21601-2721 International Fire Marshals Association	FKT-AAA	Principal Lea & Elliott, Inc. 2505 North State Highway 360 Suite 750 Grand Prairie, TX 75050 Alternate: Robert W. Falvey	FKT-AAA
James J. Convery	U 04/05/2016	Thomas Eng	U 08/03/2016
Principal Amtrak 33 Clearview Drive Tinton Falls, NJ 07724	FKT-AAA	Principal Los Angeles County Metro Transportation Authority One Gateway Plaza Los Angeles, CA 90012 Alternate: Thomas Alan Langer	FKT-AAA
Katherine Fagerlund	SE 10/23/2003	Michel Fournier	U 08/17/2018
Principal JENSEN HUGHES Consulting Canada Ltd. 13900 Maycrest Way, Suite 135 Richmond, BC V6V 3E2 Canada Alternate: John F. Devlin	FKT-AAA	Principal Societe de Transport de Montreal (STM) 2000 Berri, 4th Floor Montréal, QC H2L 4V7 Canada Alternate: Riccardo Di Marco	FKT-AAA
Marcelo M. Hirschler	M 08/08/2019	Bernard J. Kennedy, IV	RT 04/08/2015
Principal GBH International 2 Friar's Lane Mill Valley, CA 94941 ACC-North American Flame Retardant Alliance	FKT-AAA	Principal US Department of Transportation Volpe National Transportation Systems Center 55 Broadway, Kendall Square Cambridge, MA 02142-1093 US Department of Transportation Research	FKT-AAA
William E. Koffel	M 08/09/2012	Max Lakkonen	RT 08/17/2017
Principal Koffel Associates, Inc. 8815 Centre Park Drive Suite 200 Columbia, MD 21045-2107 Automatic Fire Alarm Association, Inc. Alternate: Daniel P. Finnegan	FKT-AAA	Principal Institute for Applied Fire Safety Research Pankstrasse 8-10, Haus A Berlin DE, 13127 Germany	FKT-AAA

Address List No Phone

10/13/2020
Baran Ozden
FKT-AAA

Fixed Guideway Transit and Passenger Rail Systems

William H. Lampkin	M 12/06/2019	Kevin M. Lewis	M 3/2/2010
Principal Greenheck Fan Corporation PO Box 410 Schofield, WI 5447643528	FKT-AAA	Principal Bombardier Transportation 1501 Lebanon Church Road Pittsburgh, PA 15236-1491 Alternate: Muriel Villalta	FKT-AAA
Silas K. Li	SE 7/14/2004	Harold A. Locke	SE 11/1/1984
Principal WSP/Parsons Brinckerhoff, Inc. One Penn Plaza New York, NY 10119 Alternate: Andrew Louie	FKT-AAA	Principal Locke & Locke Inc. 3552 West 2nd Avenue Vancouver, BC V6R 1J4 Canada Alternate: Gary L. English	FKT-AAA
David Mao	E 1/15/2004	Scott W. McAleese	U 08/17/2015
Principal US Department of Transportation Federal Railroad Administration 1200 New Jersey Avenue, SE RRS-14, MS-25, Room W35-311 Washington, DC 20590 US Department of Transportation Enforcement	FKT-AAA	Principal Chicago Transit Authority 567 West Lake Street Chicago, IL 60661	FKT-AAA
Zoran Radojevic	U 11/30/2016	Dilip S. Shah	SE 7/23/2008
Principal Toronto Transit Commission 5140 Yonge Street Toronto, ON M2N 6L6 Canada Alternate: Predrag Petrovic	FKT-AAA	Principal AECOM Technical Services, Inc. Tunnel Ventilation Group 300 Lakeside Drive, Suite 400 Oakland, CA 94612 Alternate: Thomas P. O'Dwyer	FKT-AAA
Blake M. Shugarman	RT 08/08/2019	Joshua H. Teo	U 08/11/2014
Principal UL LLC 333 Pfingsten Road Northbrook, IL 60062-2096	FKT-AAA	Principal Bay Area Rapid Transit District (BART) 300 Lakeside Drive, 18th Floor San Francisco, CA 94612 Alternate: Jason Eng	FKT-AAA
Robert C. Till	SE 7/16/2003	William Ventura	E 08/17/2017
Principal John Jay College of Criminal Justice 220 E. 57th Street Apartment 14G New York, NY 10022 Alternate: Bruce Dandie	FKT-AAA	Principal FDNY 12 Nicola Lane Nesconset, NY 11767	FKT-AAA

Address List No Phone

10/13/2020
Baran Ozden
FKT-AAA

Fixed Guideway Transit and Passenger Rail Systems

David J. Volk	U 11/30/2016	John Powell White	SE 03/05/2012
Principal Port Authority Trans Hudson One Path Plaza Jersey City, NJ 07306	FKT-AAA	Principal Fire Cause Analysis 935 Pardee Street Berkeley, CA 94710-2623 Alternate: Steve Virostek	FKT-AAA
Steven C. White	E 7/28/2006	Ritch D. Hollingsworth	SE 7/28/2006
Principal MTA-Long Island Rail Road 93-59 183rd Street Hollis, NY 11423-2323 Metropolitan Transportation Authority Long Island Rail Road Alternate: Daniel E. Nichols	FKT-AAA	Voting Alternate LTK Engineering Services 100 West Butler Avenue Amber, PA 19002	FKT-AAA
Nequan Isaac	U 08/08/2019	Bruce Dandie	SE 04/08/2015
Voting Alternate New York City Transit Authority 2 Broadway D5.93 New York, NY 10004 NYC Transit	FKT-AAA	Alternate RRT PTY LTD PO Box 3835 Victoria Point West, QLD 4165 Australia Principal: Robert C. Till	FKT-AAA
Matthew W. Davy	SE 12/08/2015	John F. Devlin	SE 1/1/1996
Alternate Arup 60 State Street Boston, MA 02109 Principal: Jarrod Alston	FKT-AAA	Alternate JENSEN HUGHES 3610 Commerce Drive, Suite 817 Baltimore, MD 21227 JENSEN HUGHES Principal: Katherine Fagerlund	FKT-AAA
Riccardo Di Marco	U 08/08/2019	Jason Eng	U 08/03/2016
Alternate STM Societe De Transport De Montreal 8845 St-Laurent Boulevard 4th Floor Montreal, QC H2N 1M3 Canada Principal: Michel Fournier	FKT-AAA	Alternate Bay Area Rapid Transit District (BART) 300 Lakeside Drive 18th Floor Oakland, CA 94612 Principal: Joshua H. Teo	FKT-AAA
Gary L. English	SE 12/06/2017	Robert W. Falvey	SE 1/10/2002
Alternate Underground Command And Safety 23415 67 Lane Southwest Vashon, WA 98070 Principal: Harold A. Locke	FKT-AAA	Alternate Lea & Elliott, Inc. 7345 West Sand Lake Road Suite 214 Orlando, FL 32819 Principal: David M. Casselman	FKT-AAA

Address List No Phone

10/13/2020
Baran Ozden
FKT-AAA

Fixed Guideway Transit and Passenger Rail Systems

Daniel P. Finnegan	M 03/07/2013	Thomas Alan Langer	U 08/17/2018
Alternate Siemens Smart Infrastructure 2953 Exeter Court West Dundee, IL 60118-1724 Automatic Fire Alarm Association, Inc. Principal: William E. Koffel	FKT-AAA	Alternate Los Angeles County Metro Transportation Authority (LACMTA) One Gateway Plaza 99-11-03 Los Angeles, CA 90012 Principal: Thomas Eng	FKT-AAA
Andrew Louie	SE 08/03/2016	Daniel E. Nichols	E 12/06/2017
Alternate WSP USA 1 Penn Plaza, Floor 2 New York, NY 10119 Principal: Silas K. Li	FKT-AAA	Alternate State of New York Metropolitan Transportation Authority Metro North Railroad 3 Valerie Court Hyde Park, NY 12538 Metropolitan Transportation Authority Enforcer Principal: Steven C. White	FKT-AAA
Neil E. Nott	U 10/4/2007	Thomas P. O'Dwyer	SE 08/17/2017
Alternate Washington Metropolitan Area Transit Authority (WMATA) 198 Van Buren Street Suite 300 Herndon, VA 20170 Principal: Richard M. Arvin	FKT-AAA	Alternate Aecom 125 Broad Street, 16th Floor New York, NY 10004 Principal: Dilip S. Shah	FKT-AAA
Predrag Petrovic	U 08/11/2020	Muriel Villalta	M 04/11/2018
Alternate Toronto Transit Commission 5140 Yonge Street, 6th Floor Toronto, ON M2N6L7 Canada Principal: Zoran Radojevic	FKT-AAA	Alternate Bombardier Transportation P.O. Box 220 Station Kingston, ON K7M 6R2 Canada Principal: Kevin M. Lewis	FKT-AAA
Steve Virostek	SE 11/30/2016	Arnold Dix	SE 7/29/2005
Alternate Fire Cause Analysis 935 Pardee Street Berkeley, CA 94710 Principal: John Powell White	FKT-AAA	Nonvoting Member School Medicine, UWS Lawyer/Scientist 16 Sherman Court Berwick, VIC 3806 Australia	FKT-AAA
Frank J. Cihak	SE 1/1/1982	Norman H. Danziger	1/1/1975
Member Emeritus FJC Transit Consultants 9010 Nomini Lane Alexandria, VA 22309-2811	FKT-AAA	Member Emeritus 11231 Golfridge Lane Boynton Beach, FL 33437	FKT-AAA

Address List No Phone

10/13/2020
Baran Ozden
FKT-AAA

Fixed Guideway Transit and Passenger Rail Systems

Edward K. Farrelly	1/1/1975	Harold L. Levitt	01/18/2001
Member Emeritus	FKT-AAA	Member Emeritus	FKT-AAA
E. Farrelly & Associates		Self Employed	
60 Blanch Avenue		35 Nottingham Drive	
Harrington Park, NJ 07640		Old Bridge, NJ 08857	
Baran Ozden	04/25/2019		
Staff Liaison	FKT-AAA		
National Fire Protection Association			
One Batterymarch Park			
Quincy, MA 02169-7471			



National Fire Protection Association

1 Batterymarch Park, Quincy, MA 02169-7471
Phone: 617-770-3000 • Fax: 617-770-0700 • www.nfpa.org

Technical Committee on Fixed Guideway Transit and Passenger Rail Systems
MINUTES
NFPA 130 Second Draft Meeting
October 2-4, 2018
Holiday Inn Orlando – Disney Springs Area
Orlando, Florida

Part I, Attendance:

Committee Members and Staff:

Name	Office	Organization
Jarrold Alston	Chair	Arup
Richard Arvin	Principal	Washington Metropolitan Area Transit
David Casselman	Principal	Lea & Elliott, Inc.
James Convery	Principal	Amtrak
Thomas Eng	Principal	Los Angeles County Metropolitan
Katherine Fagerlund	Principal	Jensen Hughes
Michael Fournier	Principal	Societe de Transport de Montreal (STM)
Charles Giblin III	Principal	International Fire Marshals Association
Bernard Kennedy	Principal	US Department of Transportation
William Koffel	Principal	Automatic Fire Alarm Association, Inc.
Max Lakkonen	Principal	Institute for Applied Fire Safety Research
Pierre Laurin	Principal	Toronto Transit Commission
Kevin Lewis (Teleconference)	Principal	Bombardier Transportation
Silas Li	Principal	WSP
Harold Locke	Principal	Locke & Locke Inc.
Henry Schober	Principal	Metropolitan Transportation Authority
Dilip Shah	Principal	AECOM Technical Services, Inc.
Joshua Teo	Principal	Bay Area Rapid Transit District (BART)
Robert Till	Principal	John Jay College of Criminal Justice
William Ventura	Principal	Fire Department City of New York
David Volk	Principal	Port Authority Trans Hudson
John White	Principal	Fire Cause Analysis
Steven White	Principal	Metropolitan Transportation Authority
Matthew Davy	Alternate	Arup
Jason Eng	Alternate	Bay Area Rapid Transit District (BART)
Gary English	Alternate	Underground Command And Safety
Ritch Hollingsworth	Alternate	LTK Engineering Services
Thomas Kenny	Alternate	Metropolitan Transportation Authority
Thomas Langer	Alternate	Los Angeles County Metro Transportation
Andrew Louie	Alternate	WSP

Scott McAleese	Alternate	Chicago Transit Authority
Thomas O'Dwyer	Alternate	AECOM
Zoran Radojevic	Alternate	Toronto Transit Commission
Arnold Dix	Nonvoting Member	School Medicine, UWS
Janna Shapiro	Staff Liaison	NFPA

Guests:

Robert Schmidt	RSCC Wire and Cable LLC
James Conrad	Marmon Innovation & Technology
Marcelo Hirschler	GBH International
David Plotkin	AECOM
Gil Shoshani	RSCC Wire and Cable LLC
Jim Notarfrancesco	RSCC Wire and Cable LLC
Brian Lattimer	Jensen Hughes
Adrian Milford	Jensen Hughes
Andrew Coles	Jensen Hughes
Justin Edenbaum	Never Gray
Baljinder Bassi	Parsons Inc.
Ian Ong	Mott Macdonald
Nicholas Harris	LTK Engineering Services

Part II, Minutes:

1. Chairman Jarrod Alston called the meeting to order at 8:00 AM on Tuesday, Oct. 2, 2018.
2. All attendees delivered their self-introductions. An attendance roster was produced; there were 34 Committee Members (Principals and Alternates) present. There were also 13 guests and NFPA Staff Liaison Janna Shapiro. Of this total, 1 member was in attendance via teleconference.
3. Chairman Alston called for a motion to accept minutes of the October 2017 meeting (1st Draft) of the Technical Committee in Mesa, AZ. Motion passed unanimously.
4. Staff Liaison Shapiro provided standard meeting instructions and legal policies.
5. Staff Liaison Shapiro instructed Technical Committee on Roster update and attendance log.
6. The Technical Committee completed the review and action process on 20 Public Comments.
7. Task Group Reports were presented to the Technical Committee:
 - a. Harold Locke presented the work of the Passenger Rail Task Group. No actions were taken at this time. The Technical Committee will review this further in the next revision cycle.

- b. Bill Koffel presented the work of the “Exit” Definitions Task Group, resulting in a Second Revision.
 - c. Katherine Fagerlund presented the work of the Stations Task Group, Tunnels Task Group, and “Fire Hazard Analysis” vs. “Engineering Analysis” Task Group, resulting in several Second Revisions.
 - d. Silas Li presented the work of the Ventilation Task Group, resulting in several Second Revisions.
8. Additional items were brought forward for discussion:
- a. Brian Lattimer presented an update of railcar fire safety research by the Federal Railroad Administration/Volpe National Transportation System Center.
 - b. A TIA for A.6.3.2.1 of the 2017 edition of NFPA 130 was discussed to ensure consistency with the proposed 2020 edition before processing.
 - c. Katherine Fagerlund proposed revisions to the guideway crosswalk language in 6.3.1 and 6.3.3. No action was taken at this time. The Technical Committee will review this further in the next revision cycle.
 - d. David Plotkin proposed revisions to ensure consistency in the use of “fire-life safety” terminology throughout the document, resulting in a Second Revision.
 - e. Remaining Committee Inputs that were not addressed by task groups were reviewed, resulting in Second Revisions.
 - f. Katherine Fagerlund brought forward several first draft ballot comments for discussion, resulting in several Second Revisions.
 - g. Katherine Fagerlund discussed a conflict with ASME A17.1/CSA B44 with respect to stopped elevators as a means of egress. No actions were taken at this time. The Technical Committee will review this further in the next revision cycle.
9. Chairman Alston appointed the following Task Groups for future business:
- a. Intentional Acts: This Task Group will determine if it is appropriate to address the possibility of intentional acts within NFPA 130 and develop proposals as necessary. Task Group members to be determined.

- b. Toxicity: This Task Group will discuss the possible inclusion of toxicity requirements within NFPA 130 and develop proposals as necessary. Task Group members to be determined.
- c. Tenability Criteria: This Task Group will review the tenability criteria in NFPA 130 to determine if it is current, and suggest updates as appropriate. Task Group Members to be determined.
- d. Ventilation: This task group will continue to develop proposals to clarify the intent of “critical velocity”. Task Group members include Silas Li (chair), Robert Falvey, Pierre Laurin, Zoran Radojevic, Thomas Eng, Andrew Coles, James Convery, David Plotkin, Thomas Kenny, Tom O'Dwyer, and Dilip Shah.
- e. Accessible Means of Egress: This Task Group will determine if it is appropriate to address accessible means of egress within NFPA 130 and develop proposals as necessary. Task Group members to be determined.
- f. Passenger Rail: This task group will liaison with TRB and review NFPA 130 requirements to determine where exemptions and exceptions should apply to passenger rail. Task Group members include Harold Locke (chair), Kevin Lewis, Jarrod Alston, David Mao, Bernie Kennedy, Harold Levitt, Steven White, James Convery, Robert Till, and Arnold Dix.
- g. Density-Based Alternative: This Task Group will further review CI 62 and develop proposals for the implementation of density-based occupant load calculations. Task Group members to be determined.
- h. Elevators: This Task Group will review the use of elevators for evacuation and develop proposals as necessary. Task Group members to be determined.
- i. Escalators: This Task Group will review ASME A17.1/CSA B44 with respect to stopped elevators as a means of egress. Task Group members to be determined.
- j. Risk Categories: This Task Group will review the risk categorization of design fires in AS 4825 and develop proposals as necessary. Task Group members to be determined.
- k. Vehicles: This Task Group will review the vehicle requirements in NFPA 130 based on Lattimer’s presentation and the first draft ballot comments. Task Group members to be determined.

- l. Chapter 12: This task group will review the language in Chapter 12 and propose revisions as necessary to ensure that the requirements state the performance goals that are intended. Task group members to be determined (initiated by Katherine Fagerlund and Andrew Coles).
 - m. Annex C: This task group will review the calculations in Annex C and propose revisions as necessary. Task group members to be determined.
 - n. Application of 7.2.5: This Task Group will review the application of 7.2.5 to more than one train in a single ventilation zone. Recommendations will be provided in the next revision cycle. Task Group members include Gary English (Chair), David Plotkin, Silas Li, Zoran Radojevic, Harold Locke, Scott McAleese, David Volk, and Joshua Teo.
 - o. New Annex on AHJ Guidance: This Task Group will review existing NFPA documents and develop a new annex providing guidance for AHJs, including the roles of the AHJ, how to handle conflicts between various regulations, prescriptive vs. performance based design, etc. Recommendations will be provided in the next revision cycle. Task Group members include Gary English (Chair), Arnold Dix, and Thomas Eng.
 - p. Harmonization with European Standards: This Task Group will review European standards in relation to NFPA 130 and propose revisions as necessary. Task Group members include Arnold Dix (chair). Others to be determined.
10. The First Draft meeting of the next revision cycle will be scheduled at a later date.
- Suggestions for location included Seattle, Chicago, Denver, New Orleans, and San Antonio. It is requested that the meeting be coordinated with the NFPA 502 First Draft Meeting, as was done for this meeting.
11. Chairman Alston called for a motion to adjourn the meeting at 5:35 PM on Wednesday, Oct. 3, 2018. Motion passed unanimously.



Public Input No. 4-NFPA 130-2019 [Global Input]

1. Revise 6.3.3.6 to read as follows:

6.3.3.6 Guards shall not be required along the trainway side of walkways where the bottom of the trainway is closed by a deck or grating.

2. Revise 6.3.3.7 to read as follows:

6.3.3.7 Guards shall not be required on walkways that are located between two trainways.

3. Revise 6.3.3.9 to read as follows:

6.3.3.9 Walkways that are greater than 1120 mm (44 in.) wide and located between two trainways shall not be required to have a handrail.

4. Revise A.6.3.3.5 to read as follows:

A.6.3.3.5 It is important that guards be configured so that they do not interfere with either the vehicle dynamic envelope or with egress from the train onto the walkway. For that reason, guards are not required on the trainway side of walkways, provided that the bottom of the trainway is closed by deck or grating so that persons could not fall through the bottom of the guideway.

5. Revise A.6.3.3.8 to read as follows:

A.6.3.3.8 It is important that handrails be configured so that they do not interfere with either the vehicle dynamic envelope or with egress from the train onto the walkway. For that reason, handrails are not required on the trainway side of raised walkways. Likewise, walkways located between trainways are not required to have handrails, provided they are a minimum width of 1120 mm (44 in.).

Additional Proposed Changes

<u>File Name</u>	<u>Description</u>	<u>Approved</u>
TIA_130_20_1.pdf	NFPA 130_TIA_20-1	

Statement of Problem and Substantiation for Public Input

NOTE: This public input originates from Tentative Interim Amendment No. 20-1 (Log 1354) issued by the Standards Council on August 6, 2019 and per the NFPA Regs., needs to be reconsidered by the Technical Committee for the next edition of the Document.

Substantiation: In the A2013 ROP, a revision to remove the term “raised” was accepted (130-120 Log #214). However, this revision was never incorporated into the 2014 edition of the Standard. This TIA is intended to correct this error by removing the term “raised” from the 2017 and proposed 2020 editions of NFPA 130.

Submitter Information Verification

Submitter Full Name: TC on FKT-AAA

Organization: NFPA

Street Address:

City:

State:

Zip:

Submittal Date: Mon Oct 28 10:13:14 EDT 2019

Committee:



Public Input No. 88-NFPA 130-2020 [Global Input]

For facilities that utilize a supervisory control and data acquisition (SCADA) system to monitor and control facility sub-systems as part of an integrated emergency response system (i.e., ventilation, fire protection, traffic control, emergency communications systems, etc.), the fire alarm control panel (FACP) should interface with the SCADA system for the purpose of reporting alarm signals from the automatic fire detection system directly to the SCADA system. The number of data points exported from the FACP to the SCADA system should be sufficient to provide notifications, alarms, and status conditions to the SCADA system necessary to allow the initiation of an appropriate sub-system response by the SCADA system to the alarms and conditions received from the automatic fire detection system.

Statement of Problem and Substantiation for Public Input

The revisions are necessary to direct users of the standard that the FACP is to be used to receive alarms from the fire detection system and that the FACP sends those alarms to the facility monitoring and control sub-systems such that these sub-systems are empowered to implement an integrated emergency response to the alarms.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 87-NFPA 130-2020 [Section No. 5.4.2.1]	Annex Material for change in main body.

Submitter Information Verification

Submitter Full Name: Justin Edenbaum
Organization: Never Gray
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 15:41:02 EDT 2020
Committee:



Public Input No. 90-NFPA 130-2020 [Global Input]

The monitoring and control of sub-systems can vary, depending on the level of supervision provided. For example, for tunnels without 24-hour supervision, the activation of sub-systems in response to a fire emergency can be directly initiated from the FACP, whereas for facilities where sub-systems are monitored and controlled through an approved SCADA system, the SCADA system is utilized to initiate sub-system activation.

Statement of Problem and Substantiation for Public Input

NFPA 72 issues

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 89-NFPA 130-2020 [New Section after 5.4.2.2]	Annex Language

Submitter Information Verification

Submitter Full Name: Justin Edenbaum
Organization: Never Gray
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 15:48:03 EDT 2020
Committee:



Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]

1.1.3

This standard shall not cover requirements for the following:

- (1) Conventional freight systems
- (2) Buses and trolley coaches
- (3) Circus trains
- (4) Tourist, scenic, historic, or excursion operations
- (5) Any other system of transportation not included in the definition of *fixed guideway transit system*(see 3.3.64.1) or *passenger rail system*(see 3.3.64.2)
- (6)* ~~Shelter stops~~

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to address application of NFPA 130 to Passenger Rail and Light Rail Transit Systems. Existing requirements do not adequately address differences in those systems from typical rapid transit systems relative to fire-life safety hazards. Refer to related proposed revisions to A.1.1.3, new definition for "stop" and associated annex language, new annex language associated with the definition for "station", proposed new sections 5.6 and 5.7, and proposed new sections 6.6 and 6.7.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]	
Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]	
Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 18:02:00 EDT 2020
Committee: FKT-AAA

**Public Input No. 5-NFPA 130-2019 [Section No. 1.1.3]****1.1.3**

This standard shall not cover requirements for the following:

- (1) Conventional freight systems
- (2) Buses and trolley coaches
- (3) Circus trains
- (4) Tourist, scenic, historic, or excursion operations
- (5) Any other system of transportation not included in the definition of *fixed guideway transit system*(see 3.3.64.1) or *passenger rail system*(see 3.3.64.2)
- (6) * Shelter stops
- (7) Vehicle maintenance facilities

Statement of Problem and Substantiation for Public Input

While I agree the code does not apply to vehicle maintenance facilities, this addition will serve to clarify 100% that his standard does not cover these facilities.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Affiliation: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 10:27:14 EST 2019

Committee: FKT-AAA



Public Input No. 6-NFPA 130-2019 [Section No. 1.1.4]

1.1.4

To the extent that a system, including those listed in 1.1.3(1) through 1.1.3(6 7), introduces hazards of a nature similar to those addressed herein, this standard shall be permitted to be used as a guide.

Statement of Problem and Substantiation for Public Input

Subject to committee agreement of my previous PI, this figure should be changed to address points 1 through to 7.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Affiliation: NA

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 10:33:03 EST 2019

Committee: FKT-AAA



Public Input No. 7-NFPA 130-2019 [Section No. 2.2]

2.2 NFPA Publications.

National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

[NFPA 2, Hydrogen Technologies Code](#)

NFPA 4, *Standard for Integrated Fire Protection and Life Safety System Testing*, 2018 [edition](#).

NFPA 10, *Standard for Portable Fire Extinguishers*, 2018 [edition](#).

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2019 [edition](#).

NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 2019 [edition](#).

NFPA 22, *Standard for Water Tanks for Private Fire Protection*, 2018 [edition](#).

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2020 [edition](#).

NFPA 70[®], *National Electrical Code*[®], 2020 [edition](#).

NFPA 72[®], *National Fire Alarm and Signaling Code*[®], 2019 [edition](#).

NFPA 91, *Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Particulate Solids*, 2015 [edition](#).

NFPA 101[®], *Life Safety Code*[®], 2018 [edition](#).

NFPA 110, *Standard for Emergency and Standby Power Systems*, 2019 [edition](#).

NFPA 220, *Standard on Types of Building Construction*, 2018 [edition](#).

NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*, 2019 [edition](#).

NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*, 2019 [edition](#).

NFPA 262, *Standard Method of Test for Flame Travel and Smoke of Wires and Cables for Use in Air-Handling Spaces*, 2019 [edition](#).

NFPA 275, *Standard Method of Fire Tests for the Evaluation of Thermal Barriers*, 2017 [edition](#).

NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, 2019 [edition](#).

NFPA 703, *Standard for Fire Retardant-Treated Wood and Fire-Retardant Coatings for Building Materials*, 2018 [edition](#).

NFPA 1221, *Standard for the Installation, Maintenance, and Use of Emergency Services Communications Systems*, 2019 [edition](#).

Statement of Problem and Substantiation for Public Input

The committee should give due regard to reference NFPA 2 for hydrogen systems, or establish a working group to address this. New technology and sustainability requirements across the world are looking at hydrogen technology for rail vehicles.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Affiliation: N/A

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 10:36:56 EST 2019

Committee: FKT-AAA



Public Input No. 48-NFPA 130-2020 [Section No. 2.3.4]

2.3.4 ASTM Publications.

ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM C1166, *Standard Test Method for Flame Propagation of Dense and Cellular Elastometric Gaskets and Accessories*, 2006 (2016).

ASTM D2724, *Standard Test Methods for Bonded, Fused, and Laminated Apparel Fabrics*, 2007 (2015) 2019 .

ASTM D3574, *Standard Test Methods for Flexible Cellular Materials — Slab, Bonded, and Molded Urethane Foams*, 2017.

ASTM D3675, *Standard Test Method for Surface Flammability of Flexible Cellular Materials Using a Radiant Heat Energy Source*, 2017 2019 .

ASTM D7568, *Standard Specification for Polyethylene-Based Structural-Grade Plastic Lumber for Outdoor Applications*, 2017.

ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, 2018a 2020 .

ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, 2018a 2020 .

ASTM E136, *Standard Test Method for ~~Behavior- Assessing Combustibility~~ of Materials in-a- Using a Vertical Tube Furnace at 750°C*, 2016a 2019a .

ASTM E162, *Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source*, 2016.

ASTM E648, *Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source*, 2017a 2019a e1 .

ASTM E662, *Standard Test Method for Specific Optical Density of Smoke Generated by Solid Materials*, 2017a 2019 .

ASTM E814, *Standard Test Method for Fire Tests of Penetration Firestop Systems*, 2013a (2017).

ASTM E1354, *Standard Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter*, 2017.

ASTM E1537, *Standard Test Method for Fire Testing of Upholstered Furniture*, 2016.

ASTM E1590, *Standard Test Method for Fire Testing of Mattresses*, 2017.

ASTM E2061, *Standard Guide for Fire Hazard Assessment of Rail Transportation Vehicles*, 2018 2020 .

ASTM E2652, *Standard Test Method for ~~Behavior of Materials in-a- Assessing Combustibility of Materials Using a~~ Tube Furnace with a Cone-shaped Airflow Stabilizer, at 750°C*, 2016 2018 .

Statement of Problem and Substantiation for Public Input

updates

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 16 18:08:30 EDT 2020

Committee: FKT-AAA



Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]

2.3.9 UL Publications.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

ANSI/ UL 44, *Standard for Safety Thermoset Thermoset -Insulated Wires and Cables*, 2014 2018 .ANSI/

UL 83, *Standard for Safety Thermoplastic Thermoplastic -Insulated Wires and Cables*, 2014 2017 .

ANSI/ UL 263, *Standard for Fire Fire Tests of Building Construction and Materials*, 2015.ANSI/UL 1685, *Standard for* 2019.

UL 723, *Test for Surface Burning Characteristics of Building Materials*, 2018

UL 1479, *Fire Tests of Penetration Firestops*, 2015

UL 1685, *Vertical-Tray Fire-Propagation and Smoke-Release Test for Electrical and Optical-Fiber Cables*, 2015.

UL 1724, *Outline of Investigation for Fire Tests for Electrical Circuit Protective Systems*, 2006.

ANSI/ UL 2196, *Standard Tests for Safety for Tests for Fire Resistive Cables*, 2001, revised 2012 2017 .

Statement of Problem and Substantiation for Public Input

Reason: Many years ago, UL preferred the ANSI/UL reference because there was a transition of traditional UL standards towards an ANSI standards development process.

Now, years later, a large majority of UL Standards are ANSI approved and follow the ANSI development and maintenance process. However, sometimes readers are confused because they don't understand the standards are actually UL standards, not developed by ANSI. There are many other references to standards promulgated by other standards development organizations where they are considered ANSI approved but do not include ANSI in the reference.

UL 1479 is equivalent to ASTM E814 for fire testing penetration fire stops. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire stop ratings are required.

UL 723 is an equivalent standard to ASTM E 84. Both standards are used to determine flame spread and smoke development ratings of different materials. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever these ratings are required.

Update of existing references.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 119-NFPA 130-2020 [Section No. 5.2.5.1]	
Public Input No. 120-NFPA 130-2020 [Section No. 6.2.7.2]	
Public Input No. 121-NFPA 130-2020 [Section No. 6.2.8.2]	
Public Input No. 122-NFPA 130-2020 [Section No. 8.4.1.15]	
Public Input No. 123-NFPA 130-2020 [Section No. 8.5.1.3]	
Public Input No. 125-NFPA 130-2020 [Section No. 12.4.4]	
Public Input No. 126-NFPA 130-2020 [Section No. 12.5]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto

Organization: UL LLC

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 16 12:16:57 EDT 2020

Committee: FKT-AAA



Public Input No. 9-NFPA 130-2019 [Section No. 2.3.11]

2.3.11 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

[EN 45545 Railway Applications - Fire protection on Railway Vehicles](#)

Statement of Problem and Substantiation for Public Input

The committee should consider the inclusion of EN standards for rail vehicles to ensure the standard can be applied worldwide. On a recent project this standard was determined by a third party to be equivalent or superior to NFPA 130 Chapter 8.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Affiliation: NA

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 10:44:46 EST 2019

Committee: FKT-AAA



Public Input No. 8-NFPA 130-2019 [Section No. 2.4]

2.4 References for Extracts in Mandatory Sections.

NFPA 72[®], *National Fire Alarm and Signaling Code*[®], 2019 [edition](#).

NFPA 92, *Standard for Smoke Control Systems*, 2018 [edition](#).

NFPA 101[®], *Life Safety Code*[®], 2018 [edition](#).

NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*, 2019 [edition](#).

NFPA 270, *Standard Test Method for Measurement of Smoke Obscuration Using a Conical Radiant Source in a Single Closed Chamber*, 2018 [edition](#).

NFPA 402, *Guide for Aircraft Rescue and Fire-Fighting Operations*, 2019 [edition](#).

NFPA 472, *Standard for Competence of Responders to Hazardous Materials/Weapons of Mass Destruction Incidents*, 2018 [edition](#).

NFPA 502, *Standard for Road Tunnels, Bridges, and Other Limited Access Highways*, 2020 [edition](#).

NFPA 921, *Guide for Fire and Explosion Investigations*, 2017 [edition](#).

NFPA 1994, *Standard on Protective Ensembles for First Responders to CBRN Terrorism Incidents*, 2018 [edition](#).

Statement of Problem and Substantiation for Public Input

I propose reference to NFPA 502 is removed. My experience dealing with projects in the Middle East region is clients are looking for the design to meet with both NFPA 130 & 502, due to the inclusion of this reference [NFPA 502] within section 2.4. Clearly the codes are different.

The only reference to NFPA 502 is 3.3.20. This cross reference can be removed and NFPA 130 committee adopt their own definition.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Affiliation: NA

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 10:40:04 EST 2019

Committee: FKT-AAA

**Public Input No. 165-NFPA 130-2020 [New Section after 3.3]****TITLE OF NEW CONTENT**

Type your content here ...

3.3.XX Stop

A place located within a public way designated for the purpose of loading and unloading passengers.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to address application of NFPA 130 to Passenger Rail and Light Rail Transit Systems. Existing requirements do not adequately address differences in those systems from typical rapid transit systems relative to fire-life safety hazards. Refer to related proposed revisions to A.1.1.3, new annex language associated with the definition for "station", proposed new sections 5.6 and 5.7, and proposed new sections 6.6 and 6.7.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]</u>	
<u>Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]</u>	
<u>Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]</u>	
<u>Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]</u>	
<u>Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]</u>	
<u>Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]</u>	
<u>Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]</u>	
<u>Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]</u>	
<u>Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]</u>	
<u>Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]</u>	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 18:06:51 EDT 2020
Committee: FKT-AAA

**Public Input No. 63-NFPA 130-2020 [New Section after 3.3.3]****Automatic Fire Detection System**

A fire detection system that senses the presence of fire, smoke, or heat and provides automatic alarm signals

Statement of Problem and Substantiation for Public Input

This term is used in NFPA 130 and does not necessarily have an ordinarily accepted meaning

Submitter Information Verification

Submitter Full Name: Jonathan Redding

Organization: FOGTEC Fire Protection

Street Address:

City:

State:

Zip:

Submittal Date: Fri Jun 26 07:47:28 EDT 2020

Committee: FKT-AAA



Public Input No. 50-NFPA 130-2020 [Section No. 3.3.32.2]

3.3.32.2* Fire Heat Release Rate.

Rate of energy release for a given fire scenario or fire test, ~~expressed as a function of time~~.

Statement of Problem and Substantiation for Public Input

Rate is always a property per unit of time. The present definition talks about rate as a function of time but that would not be a rate but an acceleration. The annex note already describes the typical units.

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 16 18:24:10 EDT 2020

Committee: FKT-AAA



Public Input No. 161-NFPA 130-2020 [Section No. 3.3.37]

3.3.37 Occupancy.

3.3.37.1 Incidental Occupancies Within Stations Occupancy .

~~The use of a portion of~~ An occupancy within the station operated by others who are neither transit not system employees nor passengers and where such the space remains under the control of the system ~~-operating-~~ authority.

A. 3.3. 61.1

Incidental occupancies include leased areas used for mercantile and other business purposes such as concessions and information booths. Incidental occupancies refer to premises that are accessed from within the station only.

3.3. 37.2 Nonsystem Occupancy.

An occupancy not under the control of the system ~~-operating-~~ authority.

A.3.3.62.2

Nonsystem occupancies include areas within or adjacent to stations and have access and egress that is independent of the station. Nonsystem occupancies may have pedestrian connections to the station but such connections would be subject to requirements of the applicable building code for connections between buildings.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to clarify which occupancies these definitions are intended to include. The revisions support better application of requirements in Section 5.2.4 as well as proposed revisions to Section 5.4.4.1.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 156-NFPA 130-2020 [Sections 5.4.4.1, 5.4.4.2]</u>	
<u>Public Input No. 160-NFPA 130-2020 [Section No. A.5.4.4.1]</u>	
<u>Public Input No. 156-NFPA 130-2020 [Sections 5.4.4.1, 5.4.4.2]</u>	
<u>Public Input No. 160-NFPA 130-2020 [Section No. A.5.4.4.1]</u>	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 17:09:45 EDT 2020
Committee: FKT-AAA



Public Input No. 64-NFPA 130-2020 [New Section after 3.3.37.2]

On-board fire suppression system

A firefighting system that is installed on a rail vehicle to control and suppress fire. Typically activated from an automatic fire detection system

Statement of Problem and Substantiation for Public Input

This term is used in a proposed annex section on fire detection and fire suppression systems and does not necessarily have an ordinarily accepted meaning.

Submitter Information Verification

Submitter Full Name: Jonathan Redding

Organization: FOGTEC Fire Protection

Street Address:

City:

State:

Zip:

Submittal Date: Fri Jun 26 07:55:38 EDT 2020

Committee: FKT-AAA



Public Input No. 106-NFPA 130-2020 [Section No. 3.3.42]

3.3.42* Point of Safety.

An

3.3.40 Point of Safety . . . A point of safety is one of the following: (1) an enclosed exit that leads to a public way or safe location outside the

structure,

station, trainway, or vehicle; (2) an at-grade point beyond

any

the vehicle, enclosing

structure

station, or, trainway; (3) any other approved location . . . A location that

(a) is exterior to and away from a building; or

(b) is within a building of any construction type protected throughout by an approved automatic sprinkler system and that is either (1) within an exit enclosure meeting the requirements of this Code, or (2) within another portion of the building that is separated by smoke barriers in accordance with Section 8.5 having a minimum 1/2-hour fire resistance rating, and that portion of the building has access to a means of escape or exit that conforms to the requirements of this Code and does not necessitate return to the area

that affords adequate protection for evacuating passengers.
of fire involvement; or

(c) is within a building of Type I, Type II(222), Type II(111), Type III(211), Type IV, or Type V(111) construction (see 8.2.1.2) and is either (1) within an exit enclosure meeting the requirements of this Code, or (2) within another portion of the building that is separated by smoke barriers in accordance with Section 8.5 having a minimum 1/2-hour fire resistance rating, and that portion of the building has access to a means of escape or exit that conforms to the requirements of this Code and does not necessitate return to the area of fire involvement. (SAF-BCF) . . .

Statement of Problem and Substantiation for Public Input

This language is out of the building code and is provided to allow the 130 technical committee an opportunity to study the differences between definitions of a point of safety. 130 relies on ventilation in some areas to protect passengers from smoke (heat, toxic gases, loss of visibility) and allows the point of safety to be on the platform if approved. This approach is fundamentally different than building/fire codes which require a physical barrier between the occupants and fire and does not rely on ventilation. Two challenges occur without a physical barrier, 1) although ventilation can control heating air in many conditions, ventilation has no effect on radiant heat, 2) reliance on ventilation assumes the ventilation system will always be fully functional, yet 130 now requires acknowledgment of one fan failures. If a fan failure occurs during emergencies, portions of the station areas may not be fully protected from smoke and convective heat, whereas physical barriers provide a 'less prone to failure' protection. Physical barriers are required in 101 and International building codes.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:12:34 EDT 2020

Committee: FKT-AAA

**Public Input No. 84-NFPA 130-2020 [Section No. 3.3.56]****3.3.56* Speech Interference Level- (SIL) .**

A calculated quantity providing a guide to the interfering effect of noise on speech intelligibility; measured in decibels.

Statement of Problem and Substantiation for Public Input

SIL acronym is used much more for Safety Integrity Level in railway industry. Therefore SIL is in this context confusing for professionals in railway industry. E.g. following standards are used for in railway applications for SIL (Safety Integrity Level).

- EN 50128 (railway applications – software for railway control and protection)
- EN 50129 (railway applications – safety related electronic systems for signalling)
- IEC 61508 (Functional safety of electrical/electronic/programmable electronic safety related systems)

Submitter Information Verification

Submitter Full Name: Max Lakkonen

Organization: IFAB - Institute for Applied Fire Safety Research

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 05:05:39 EDT 2020

Committee: FKT-AAA



Public Input No. 40-NFPA 130-2020 [New Section after 3.3.57]

3.3.5.7.3 Elevated Station

A station that is constructed such that the guideway and platforms are wholly or in part elevated above the local at-grade elevation, and where emergency egress routes require vertical circulation, other than for crossing the guideways to traverse between platforms, to reach a point of safety.

Statement of Problem and Substantiation for Public Input

NFPA 130 contains specific requirements applicable to elevated stations. However the standard lacks a definition of an elevated station and the NFPA Glossary does not contain any definition. The proposed addition would clarify the applicability of "Elevated Station" requirements.

Submitter Information Verification

Submitter Full Name: Iain Bowman

Organization: Mott MacDonald Canada Ltd.

Street Address:

City:

State:

Zip:

Submittal Date: Fri Jan 17 13:59:51 EST 2020

Committee: FKT-AAA



Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]

3.3.57* Station.

A place designated for the purpose of loading and unloading passengers, including patron service areas and ancillary spaces associated with the same structure.

3.3.57.1* Enclosed Station.

A station or portion thereof that does not meet the definition of an open station.

3.3.57.2* Open Station.

A station that is constructed such that it is directly open to the atmosphere and smoke and heat are allowed to disperse directly into the atmosphere.

A.3.3.57

The term station refers to a structure having walls or other barriers that separate the area within the station from the surrounding area and that restrict passenger movement in and out of the station.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to address application of NFPA 130 to Passenger Rail and Light Rail Transit Systems. Existing requirements do not adequately address differences in those systems from typical rapid transit systems relative to fire-life safety hazards. Refer to related proposed revisions to 1.1.3, A.1.1.3, new definition for "stop" and associated annex language, proposed new sections 5.6 and 5.7, and proposed new sections 6.6 and 6.7.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]	
Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]	
Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 18:15:55 EDT 2020
Committee: FKT-AAA



Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]

5.1.1 Applicability.

5.1.1.1

This chapter shall apply to all portions of stations, except as provided in Sections 5.6 and 5.7.

5.6 Passenger Rail Stations.

5.6.1 Applicability.

Passenger rail stations shall comply with Sections 5.1 through 5.5 except as provided in this Section.

5.6.2 Relationship to Local Codes

Where platforms and track areas are located outside of the passenger rail station building, the station building shall be designed in accordance with the requirements of the locally applicable building code.

5.6.3* Means of Egress

Passenger rail station platforms shall be permitted to egress through the station building.

A.5.6.3 Provisions for egress from the platform should consider both egress from a fire on the platform and in the event of a fire in the station building. For egress from the platform during a station building fire, platform occupant loads may not need to account for train evacuation and it may be reasonable to consider temporary areas of refuge on the platform.

5.7 Stops.

5.7.1 Applicability.

This section shall apply to loading and unloading locations that are designed as stops.

5.7.2* Means of Egress

The means of egress serving a stop shall comply with this section.

5.7.2.1 The design of ramps and stairs serving the loading area shall be in accordance with the requirements of the locally applicable code.

5.7.2.1 For loading areas that are raised above surrounding grade, guards shall be provided in accordance with the requirements of the locally applicable code, except guards shall not be required adjacent to the track.

A.5.7.2 The determination of occupant load is not required for a stop in consideration that stops do not significantly restrict passenger movement and are open to the atmosphere.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to address application of NFPA 130 to Passenger Rail and Light Rail Transit Systems. Existing requirements do not adequately address differences in those systems from typical rapid transit systems relative to fire-life safety hazards. Refer to related proposed revisions to A.1.1.3, new definition for "stop" and associated annex language, new annex language associated with the definition for "station", and proposed new sections 6.6 and 6.7.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]</u>	
<u>Public Input No. 165-NFPA 130-2020 [New Section after 3.3]</u>	
<u>Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]</u>	
<u>Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]</u>	
<u>Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]</u>	
<u>Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]</u>	

[Public Input No. 165-NFPA 130-2020 \[New Section after 3.3\]](#)

[Public Input No. 166-NFPA 130-2020 \[Section No. A.1.1.3\(6\)\]](#)

[Public Input No. 167-NFPA 130-2020 \[Section No. 3.3.57\]](#)

[Public Input No. 169-NFPA 130-2020 \[Section No. 6.1.1\]](#)

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund

Organization: JENSEN HUGHES Consulting Canad

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 18:21:22 EDT 2020

Committee: FKT-AAA



Public Input No. 10-NFPA 130-2019 [Section No. 5.1.2]

5.1.2* Relationship to Local Codes.

5.1.2.1

The requirements in this chapter shall supplement the requirements of the locally applicable codes for the design and construction of stations.

5.1.2.2

Where the requirements in this chapter do not address a specific feature of fire protection or life safety, the requirements of the local codes shall be considered applicable.

5.1.2.4

Where areas of a station are not normally accessible to passenger, the design of such areas shall meet with the locally applicable codes.

Statement of Problem and Substantiation for Public Input

The addition of this clause clarifies that the non public areas of the station shall meet with local building code requirements. Appendix material can be added to refer the reader to NFPA 101 as a suitable standard for such a design.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Affiliation: NA

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 11:32:55 EST 2019

Committee: FKT-AAA



Public Input No. 133-NFPA 130-2020 [New Section after 5.1.2.1]

TITLE OF NEW CON

*5.1.2.1 Appendix note (separate from previous comment).

Great savings in time money and energy can be realized by drafting a Building Code Analyses. A Buiding Code Analyses is not a subordinate standards compliance matrix. If Employer wants to minimize bid spread and maximize likelihood of intended delivery, then example BCAs should be included in the specifications / tender for prototypical buildings. Update the BCA as design progresses. One of the goals of the BCA is to find early in the design process, gaps, inconsistencies and questions, when it costs 1/100th the energy to resolve issues than waiting until 60% design. Particular attention should be paid towards interface items (elevators, fuel tanks, parking structures, carriage emergency, exit discharges onto public ways, shopping mall openings, airport, harbor facilities, even building insulations systems.

Statement of Problem and Substantiation for Public Input

This helps resolve problem that the referenced section in the main body of the standard addresses: confusion over which design guide to use, and confusion created by interfaces existant with and without the added complexity of not working with the agreed upon alpha design guide-which usually is the adopted local building code.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 12:36:50 EDT 2020

Committee: FKT-AAA



Public Input No. 129-NFPA 130-2020 [Section No. 5.1.2.1]

5.1.2.1

The requirements in this chapter shall supplement the requirements of the locally adopted (or if not, then applicable) codes for the design and construction of stations.

Statement of Problem and Substantiation for Public Input

This is a seminal, ground-zero problem with huge repercussions that are not overstated. Use of the word "applicable" allows NFPA 500 to slide in under the radar, when many 'organized' jurisdictions enact (i.e. legally adopt) their own local building code. We want to sell NFPA 5000, but we first should respect a sovereign jurisdiction's decision when it adopts its own local building code. The local building code hopefully has guidance tuned to local climate, construction practices and risk tolerance which is not possible or even envisioned by NFPA 5000, or any other building code imported 100% from a foreign nation. Witness the confusion overseas where NFPA is trying to sell NFPA 5000, tyro designers try to use NFPA 5000 as the locally "applicable" code, only to get told by officials years into a Metro project, "should we not be following our own government ordained, decreed, funded and authorized Building Code? Should we not be following our own Building Code that we have so much confidence in, we patronized an updated revision for?" It is one thing to sell Building Codes, but it is going a bridge too far to leave even the faintest doubt in a designer or AHJs mind, that they can use an 'applicable code' other than their locally adopted building code. There are no unique features in the NFPA 5000 or NFPA 101 that make it particularly suited for station design. In fact, NFPA 101 is particularly ill suited, due to its focus on life and not property safety. And sending user to NFPA 220, is a punishment not befitting an organization so respected as the NFPA. To its discredit, the USA does not set the example with this NFPA 130 and local building code interface; but we should. The local building code is the IBC, but it has not stepped up and owned its responsibility. Chris.Reeves@iccsafe.org has rejected my question three times--as to the purpose of Section 405.1.E3. Why does IBC clearly reject liability for design of stations deeper than 9.1 m, but IBC is not standing up and admitting that it retains responsibility for design of stations shallower than 9.1 m? This line in the sand at 9.1 meters deep, is an irresponsibly unresolved interface; NFPA and ICCsafe need work it out-- together. It is costing taxpayers millions in inefficiency and confusion (one simple example, 'how to interface tunnel safety systems between a DUS [ICC won't touch DUS design due to Section 405.1.E3] and an At-Grade station where IBC without a doubt--is legally bound and retains responsibility in black-and-white of Section 405.1 since it is shallower than 9.1 m]? Resolving this interface will save person-months of design time in many disciplines, not just fire. I have asked old-timers with the BOCA to help me understand why BOCA retained design responsibility for stations shallower than 9.1 m; it is obvious why BOCA does not want the increased liability for deep stations---in light of the purposefully framed obsfucation in NFPA 130 sprinkler guidance. Slowly, the old timers are dying. I asked <wayne.jewell@greenoaktwp.com> an old-time building code official to help with this problem, and he said he would get around to it. Our contact in that 'tuit, has since died. Time slips by and this interface gap sucks up time and money like a black hole. I know why code consultants don't want to fix this gap... 'chaos creates cash.' Enough cash has been created. It is time to organize, not pilfer from the taxpayers more. If NFPA 130 and ICC would get together and harmonize their respective guidance on this issue of locally "adopted" building code, you will be doing the sustainable thing, which is not to waste precious resources. And, a more organized design guide will help NFPA sell more subordinate standards, planet-wide. IBC is a great Building Code, there is nothing in it (as Chris.Reeves@iccsafe.org claims) that makes IBC or any other Building Code for that matter, inherently unsuited to the unique environment of Metro stations. If a Building Code were ill-suited for station design, why would NFPA 130 finally agree that the major responsibility for station design IS the local code, after trying to do the bulk of the station design guidance by itself for 20 years? And legally, though it was not admitted, but legally IBC retains design responsibility unquestionably for design of all Metro property higher than 9.1 m underground (except where NFPA 130 guidance is more specific, and even then, in the instance of conflict with the IBC, IBC retains the option of deciding in case of conflict). NFPA 130 and ICC need to harmonize this interface gap because inefficiencies on projects costing tens of billions of dollars, are not what responsible organizations like NFPA or ICCsafe should be noted for.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 11:25:36 EDT 2020

Committee: FKT-AAA

**Public Input No. 110-NFPA 130-2020 [New Section after 5.1.3]****TITLE OF NEW CONTENT**

Type your content here ... 5.1.2.3 . Where provisions of this standard and the local codes conflict, the language which provides the greatest safety will be used.

Statement of Problem and Substantiation for Public Input

Conflicts between this standard and local codes occur without clear guidance on which should be used. Although the local codes often take precedence as they are adopted under the state authority, for safety reasons there needs to be clear language on which takes precedence when they conflict.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:37:41 EDT 2020

Committee: FKT-AAA



Public Input No. 115-NFPA 130-2020 [Section No. 5.2.3]

~~5.2.3 Flammable and Combustible Liquids Intrusion.~~

~~5.2.3.1 – General.~~

~~Protection of belowgrade system structures against the accidental intrusion of flammable and combustible liquids shall be provided in accordance with 5.2.3 .~~

~~5.2.3.2 – Vehicle Roadway Terminations.~~

~~Vent or fan shafts utilized for ventilation of belowgrade system structures shall not terminate at grade on any vehicle roadway.~~

~~5.2.3.3 – Median and Sidewalk Terminations.~~

~~Vent and fan shafts shall be permitted to terminate in the median strips of divided highways, on sidewalks designed to accept such shafts, or in open space areas, provided that the grade level of the median strips, sidewalk, or open space meets the following conditions:~~

- ~~(1) It is at a higher elevation than the surrounding grade level.~~
- ~~(2) It is separated from the roadway by a concrete curb at least 150 mm (6 in.) in height.~~

Statement of Problem and Substantiation for Public Input

The requirements in Subsection 5.2.3 are specific to ventilation openings and the scope of the standard addresses emergency ventilation these requirements would be applicable to the considerations in Subsection 7.6 for ventilation openings. Ventilation structures can be integrated into a station or a standalone structure and the considerations in Subsection 5.2.3 will apply to the ventilation shaft opening irrespective of on how it is integrated. As such, specifics separated into Chapter 5 or Chapter 6 are not required. Move Subsection 5.2.3 to a new section 7.6.3.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 116-NFPA 130-2020 [Section No. 7.6]	
Public Input No. 117-NFPA 130-2020 [Section No. 6.2.3]	

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 02:08:57 EDT 2020
Committee: FKT-AAA



Public Input No. 162-NFPA 130-2020 [Section No. 5.2.3]

5.2.3 Flammable and Combustible Liquids Intrusion.

5.2.3.1* General.

~~Protection of belowgrade system structures against the accidental~~ Ventilation openings and fan shafts shall be positioned or designed to prevent accidental intrusion of flammable and combustible liquids shall be provided in accordance with 5.2.3 or combustible liquids into belowgrade system structures.

A.5.3.2.1

Protection as required by 5.2.3.

~~2- Vehicle Roadway Terminations.~~

~~Vent or fan shafts utilized for ventilation of belowgrade system structures shall~~ 1 can be achieved as follows:

~~(1) Ventilation openings or fan shafts should not terminate at grade on any vehicle roadway.~~

~~5.2.3.3 – Median and Sidewalk Terminations.~~

~~Vent and fan shafts shall be permitted to~~ (2) Where ventilation openings or fan shafts terminate in the median strips of divided highways, on sidewalks designed to accept such shafts, or in open space areas, provided that the grade level of the median strips, sidewalk, or open space meets the following conditions: It is surface level of that area should be at a higher elevation than the surrounding grade level. It is separated or should be separated from the roadway by a concrete curb at least 150 mm (6 in.) in height .

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to indicate the performance intent of the requirements, with potential design solutions more appropriately relocated to Annex language. Refer also to related changes to 7.6.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 163-NFPA 130-2020 [Section No. 7.6]</u>	
<u>Public Input No. 163-NFPA 130-2020 [Section No. 7.6]</u>	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 17:47:23 EDT 2020
Committee: FKT-AAA

**Public Input No. 14-NFPA 130-2019 [Section No. 5.2.4.1]****5.2.4.1 Interconnected Floor Levels.**

Interconnection between floor levels in stations shall be permitted as follows:

- (1) * Stairs and escalators used by passengers shall not be required to be fire-separated.
- (2) Public areas on different levels in open stations shall be permitted to be interconnected.
- (3) Public areas on different levels in enclosed stations shall be permitted to be interconnected, provided fire separation is not required for smoke control or other fire protection purposes.
- (4) Linear joints in enclosed stations, which only connect non fire seperated interconnecting public spaces, shall not require fire seperation when subjected to a fire hazard analysis.

Statement of Problem and Substantiation for Public Input

Typically in enclosed stations the concourse and platform are located directly above/ below each other. This clause serves to clarify that the linear expansion joint does not require a fire resistance rating as they are interconnected.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 11:57:52 EST 2019

Committee: FKT-AAA



Public Input No. 12-NFPA 130-2019 [Section No. 5.2.4.5]

5.2.4.5 Rooms solely used for the dispensing of system tickets shall not require separation from public areas.

5.2.4.6 * Separation Between System and Nonsystem Occupancies.

All station public areas shall be fire separated from adjacent nonsystem occupancies.

Statement of Problem and Substantiation for Public Input

This addition clarifies that ticking rooms do not require fire separation from public spaces. These spaces typically have glazing to protect the operator which cannot be provided with fire rating due to openings in the glazing to allow for transactions. The counter is typically at different heights to allow for mobility impaired occupant use.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 11:49:20 EST 2019

Committee: FKT-AAA



Public Input No. 119-NFPA 130-2020 [Section No. 5.2.5.1]

5.2.5.1

Materials used as interior wall and ceiling finish in enclosed stations shall comply with one of the following requirements:

- (1) The materials shall be noncombustible in accordance with Section 4.6.
- (2) The materials shall be limited-combustible in accordance with 4.6.2.
- (3) The materials shall comply with the following requirements when tested in accordance with NFPA 286:
 - (4) Flames shall not spread to the ceiling during the 40 kW (135 kBtu/hr) exposure.
 - (5) Flames shall not spread to the outer extremities of the sample on any wall or ceiling.
 - (6) Flashover, as described in NFPA 286, shall not occur.
 - (7) The peak heat release rate shall not exceed 800 kW (2730 kBtu/hr).
 - (8) The total smoke released throughout the test shall not exceed 1000 m² (10,764 ft²).
- (9) The materials shall comply with a flame spread index not exceeding 25 and a smoke development index not exceeding 450 when tested in accordance with ASTM E84 or UL 723 , except that the materials in 5.2.5.2 shall be required to be tested in accordance with NFPA 286.

Statement of Problem and Substantiation for Public Input

UL 723 is an equivalent standard to ASTM E 84. Both standards are used to determine flame spread and smoke development ratings of different materials. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever these ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 120-NFPA 130-2020 [Section No. 6.2.7.2]	
Public Input No. 121-NFPA 130-2020 [Section No. 6.2.8.2]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 10:04:14 EDT 2020
Committee: FKT-AAA

**Public Input No. 45-NFPA 130-2020 [Section No. 5.2.5.1]****5.2.5.1**

Materials used as interior wall and ceiling finish in enclosed stations shall comply with one of the following requirements:

- (1) The materials shall be noncombustible in accordance with Section 4.6.
- (2) The materials shall be limited-combustible in accordance with 4.6.2.
- (3) The materials shall comply with the following requirements when tested in accordance with NFPA 286:
 - (4) Flames shall not spread to the ceiling during the 40 kW (135 kBtu/hr) exposure.
 - (5) Flames shall not spread to the outer extremities of the sample on any wall or ceiling.
 - (6) Flashover, as described in NFPA 286, shall not occur.
 - (7) The peak heat release rate shall not exceed 800 kW (2730 kBtu/hr).
 - (8) The total smoke released throughout the test shall not exceed 1000 m² (10,764 ft²).
- (9) The materials shall comply with a flame spread index not exceeding 25 and a smoke development index not exceeding 450 when tested in accordance with ASTM E84, except that the materials in 5.2.5.2 shall be required to be tested in accordance with NFPA 286.
- (10) Materials used on interior walls and ceiling finish in enclosed stations, which are fully sprinkler protected throughout in accordance with NFPA 13 shall comply with a flame spread index not exceeding 75 and a smoke development index not exceeding 450 when tested in accordance with ASTM E84, except that the materials in 5.2.5.2 shall be required to be tested in accordance with NFPA 286.

Statement of Problem and Substantiation for Public Input

The code requires Class A finish; however does not state whether the structure needs to be fully sprinkler protected. NFPA 101 permits the interior finish for fully sprinkler protected buildings to have a Class B finish. This edit it proposed to align with NFPA 101 for fully sprinkler protected structures. Note that new materials are being proposed for stations, such as LED screens, which are not able to be Class A but are used in stations fully sprinkler protected.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Wed Jun 10 03:43:17 EDT 2020

Committee: FKT-AAA

**Public Input No. 55-NFPA 130-2020 [Section No. 5.2.6]****5.2.6** ~~Exposed Insulation~~ Insulation .**5.2.6.1**

In public circulation areas, ~~exposed~~ insulation shall ~~be protected~~ be protected by a thermal barrier complying with NFPA 275 or by ½ in. (12.7 mm) gypsum board or ½ in. (12.7 mm) concrete.

5.2.6.2

Where thermal barriers are required by 5.2.6.1, penetrations shall be firestopped in accordance with ASTM E814.

Statement of Problem and Substantiation for Public Input

If the insulation is protected by a thermal barrier (as it should be) it is not exposed.

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submittal Date: Thu Jun 18 18:07:14 EDT 2020

Committee: FKT-AAA

**Public Input No. 127-NFPA 130-2020 [Section No. 5.2.6.1]****5.2.6.1**

In public circulation areas, ~~exposed~~ foam plastic insulation shall be

~~protected by a thermal barrier complying with NFPA 275 or by 1/2 in. (12.7 mm) gypsum board or 1/2 in. (12.7 mm)~~

separated from the interior of a building by an approved thermal barrier of 1/2-

inch (12.7 mm) gypsum wallboard, heavy timber (Type IV) or a material that is tested in accordance

with and meets the acceptance criteria of both the Temperature Transmission Fire Test and the Integrity Fire Test of NFPA 275. Combustible concealed spaces shall comply include fireblocking and draftstopping as required by the locally enforced building code.

5.2.6.2 A thermal barrier is not required for foam plastic insulation installed in a masonry or concrete wall, floor or roof system where the foam plastic insulation is covered on each face by not less than 1-inch (25 mm) thickness of masonry or concrete.

Statement of Problem and Substantiation for Public Input

This proposal provides better explains the NFPA 275 performance test criteria and is consistent with International Building Code requirements

Submitter Information Verification

Submitter Full Name: Kelly Nicoello

Organization: UL LLC

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 10:34:22 EDT 2020

Committee: FKT-AAA

**Public Input No. 13-NFPA 130-2019 [Section No. 5.2.6.1]****5.2.6.1**

~~In public circulation areas, exposed~~ Exposed insulation shall be protected by a thermal barrier complying with NFPA 275 or by ½ in. (12.7 mm) gypsum board or ½ in. (12.7 mm) concrete.

Statement of Problem and Substantiation for Public Input

This requirement should be applied throughout the station.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 11:55:30 EST 2019

Committee: FKT-AAA

**Public Input No. 53-NFPA 130-2020 [Section No. 5.2.7.2]****5.2.7.2 * – Rubbish containers**

5.2.7.2.1 Permanent rubbish containers in the station shall be manufactured of noncombustible materials.

5.2.7.2.2 Rubbish containers that are used in the station on a temporary basis (e.g., during cleaning operations) shall be manufactured of noncombustible materials or of materials that comply with a peak heat release rate not exceeding 300 kW/m^2 ($26.4 \text{ Btu/ft}^2 \cdot \text{sec}$) when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m^2 ($4.4 \text{ Btu/ft}^2 \cdot \text{sec}$), in the horizontal orientation.

Statement of Problem and Substantiation for Public Input

The standard recommends that temporary use rubbish containers be constructed of noncombustible materials or of materials meeting low heat release but does not mandate it. This PI mandates that they be low heat release (or noncombustible) and an associated PI deletes the annex material. This does not affect permanent rubbish containers which will still have to be noncombustible but improves fire safety for temporary rubbish containers.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 54-NFPA 130-2020 [Section No. A.5.2.7.2]	

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler
Organization: GBH International
Street Address:
City:
State:
Zip:
Submittal Date: Thu Jun 18 17:56:28 EDT 2020
Committee: FKT-AAA



Public Input No. 15-NFPA 130-2019 [Section No. 5.3.1.1]

5.3.1.1

The provisions for means of egress for public spaces in a station shall comply with NFPA 101 Chapters 7 and 12 ~~of NFPA 101.2~~, except as herein modified.

5.3.1.2

The provisions for means of egress for non-public spaces in a station structure shall comply with the provisions of the relevant occupancy chapter of NFPA 101.

Statement of Problem and Substantiation for Public Input

This edit services to clarify that NFPA 101 Chapter 7 applies in full and only NFPA 101 12.2 shall be applied. This is required due to the inconsistencies of not applying NFPA 5000 for construction types (for example a 3 level elevated station with more than 1,000 occupants would require Type II (111) whereas NFPA 5000 would require Type II (222).

The second clause clarifies that other occupancy chapters of NFPA 101 should be applied. This clarifies that the stations can be mixed occupancy.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:04:04 EST 2019

Committee: FKT-AAA



Public Input No. 17-NFPA 130-2019 [Section No. 5.3.2.2]

5.3.2.2*

For station(s) servicing areas such as civic centers, sports complexes, malls, and convention centers, the peak ridership figures shall consider events that establish occupant loads not included in normal passenger loads.

Statement of Problem and Substantiation for Public Input

The addition of malls requires the user to consider additional ridership due to the mall. It is the experience in the Middle East that malls are used as places to socialise, especially during religious holidays. This mean public transport links become very congested and potentially dangerous. With the increased push towards sustainable transportation, the use of public transport to such venue need to be considered.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:14:23 EST 2019

Committee: FKT-AAA

**Public Input No. 159-NFPA 130-2020 [New Section after 5.3.2.4]****TITLE OF NEW CONTENT**

For the purposes of determining the number of levels for triggering elevators for evacuation of mobility challenged, a level will be counted as 3.6 m in height, regardless if a level is present or not.

Statement of Problem and Substantiation for Public Input

to avoid installing ADA elevators, GC are not counting technical levels as levels. This subverts the intent of preventing firefighter fatigue. This prescription would over-rule the IBC building code guidance.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 16:57:19 EDT 2020

Committee: FKT-AAA



Public Input No. 152-NFPA 130-2020 [Section No. 5.3.2.5]

5.3.2.5* Calculation of Platform Occupant Load.

The platform occupant load for each platform in a station shall be the maximum peak period occupant load calculated according to the following:

- (1) The peak period occupant load for each platform shall be based on the simultaneous evacuation of the entraining load and the train load for that platform in the peak period.
- (2) The entraining load for each platform shall be the sum of the entraining loads for each track serving that platform.
- (3) * The entraining load for each track shall be based on the entraining load per train headway factored to account for service disruptions and system reaction time.
- (4) * Where a platform serves more than one line on one track, the calculation of entraining load shall consider the combined effect of accumulation for each of the lines served.
- (5) The train load for each platform shall be the sum of the train loads for each track serving that platform.
- (6) * The train load for each track shall be based on the train load per train headway factored to account for service disruptions and system reaction time.
- (7) The maximum train load at each track shall be the maximum passenger capacity for the largest capacity train operating on that track during the peak period.
- (8) The major design details (e.g. occupant load, principals design engineers and stakeholders, design fire, fan operation, exit time, etc) shall be memorialized onto a metal plaque mortared into the wall at eye level for all to clearly read from a widely noticeable and accessible location on the platform.

Statement of Problem and Substantiation for Public Input

Often: the simple overall concept of a platform exit design is lost what for all the details (HVACs fans off, underplatform make up air on, trainway exhaust fans on, opposite platform fans reverse dampers, fan reverse direction, escalators stop-then-reverse-under-load, elevators recall, makeup-air doors open, evacuees obstruct makeup air while filling exit passageways, roll-down vertical doors descend onto platform with makeshift personnel doors operable for 'emergencies', etc. Any intelligent fool can make a system bigger and more complicated, but it takes a touch of genius and a lot of courage to go in the opposite direction[1]. There needs to be some simple summary of the exit assumptions, for life safety professionals to assess as they scan the facility for safe operating conditions. And these operating conditions will hopefully extend through a 100-year service life.

There are three variables in exit design of Metro stations platforms: design fire, occupant load and exit capacity. We get to pick two. We should convey all three to future fire safety inspectors. Often, plan reviewers have barely have the ability to remember what these three variables are, for all the other details. A simple summary of the design should be provided. Obsfucation with egress in high-occupancy assembly areas should be avoided [1]. Einstein

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 30 16:12:57 EDT 2020

Committee: FKT-AAA

**Public Input No. 107-NFPA 130-2020 [New Section after 5.3.3]****TITLE OF NEW CONTENT**

Type your content here ... 5.3.2.5 -- Enclosed fixed guideway transit and passenger rail stations shall be posted with the occupancy load

Statement of Problem and Substantiation for Public Input

Posting occupant load will allow the rail agency and authorities having jurisdiction the necessary information to address overcrowding. For example of the design occupant load for a station is 2000 (e.g. a skipped train load and the detraining load of an arriving train), and the actual load is 2500, this could exceed the available exits capacity resulting in exit time longer than the specified times in 130. In buildings where occupant load has been exceeded, the building operator prevents additional additional people to enter the building, until the load has been reduced.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:18:29 EDT 2020

Committee: FKT-AAA

**Public Input No. 155-NFPA 130-2020 [Section No. 5.3.3.6]****5.3.3.6 Alternate Egress.**

At least two means of egress remote from each other shall be provided from each station platform as follows:

- (1) * A means of egress used as a public circulation route shall be permitted to provide more than 50 percent of the required egress capacity from a station platform or other location.
- (2) Means of egress from separate platforms shall be permitted to converge.
- (3) Where means of egress routes from separate platforms converge, the subsequent capacity of the egress route shall be sufficient to maintain the required evacuation time from the incident platform.
- (4) Back of house shall not be used as means-of-egress from the platform.

Statement of Problem and Substantiation for Public Input

The back of house are being used as egress, because they are not explicitly verboten.

The intention is to avoid counting as an exit, a door that management will be highly motivated to lock at some point in the future service life of the station. It is undesirable for three reasons to use back-of-house as an exit. 1). access from the platform will probably ($P_b > 0.7$) be locked by management eventually, as the utility of this exit capacity will fade from memory, 2). evacuees should not be exposed to a non-sterile exit (unless local risk tolerances explicitly permit). 3). Rail system power and control rooms should not be exposed to potential access from person able to simply enter the area from the platform.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 16:31:32 EDT 2020

Committee: FKT-AAA



Public Input No. 18-NFPA 130-2019 [Section No. 5.3.3.6]

5.3.3.6 Dead End Distance

The maximum permitted dead-end distance on a platform shall be limited to 6.1 m.

5.3.3.6 Alternate Egress.

At least two means of egress remote from each other shall be provided from each station platform as follows:

- (1) * A means of egress used as a public circulation route shall be permitted to provide more than 50 percent of the required egress capacity from a station platform or other location.
- (2) Means of egress from separate platforms shall be permitted to converge.
- (3) Where means of egress routes from separate platforms converge, the subsequent capacity of the egress route shall be sufficient to maintain the required evacuation time from the incident platform.

Statement of Problem and Substantiation for Public Input

This addition clarifies that the dead-end distance limitation on platform is limited to 6.1 m. This is consistent with NFPA 101.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:23:39 EST 2019

Committee: FKT-AAA



Public Input No. 85-NFPA 130-2020 [Section No. 5.3.3.7]

5.3.3.7* Engineering Analysis.

Modification of the evacuation times and travel distances shall be permitted based on an engineering analysis by evaluating material heat release rates, station geometry, and automatic fire detection systems, fire suppression systems and emergency ventilation systems.

Statement of Problem and Substantiation for Public Input

The use of fire detection or fire suppression systems can have an impact on the engineering analysis concerning evacuation times and design heat release rates. The detection system is potentially needed for starting emergency actions like ventilation system.

Submitter Information Verification

Submitter Full Name: Max Lakkonen

Organization: IFAB - Institute for Applied Fire Safety Research

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 05:30:36 EDT 2020

Committee: FKT-AAA

**Public Input No. 19-NFPA 130-2019 [Section No. 5.3.5.5]****5.3.5.5**

Escalators shall be permitted to account for more than one-half of the required egress capacity at any one level where the following criteria are met:

- (1) The escalators are capable of being remotely brought to a stop in accordance with the requirements of 5.3.5.7(3)(b), 5.3.5.7(4), and 5.3.5.7(5).
- (2) A portion of the egress capacity from each station level is stairs.
- (3) For enclosed stations, at least one enclosed exit per non-interconnected platform provides continuous access from the platforms to the public way.

Statement of Problem and Substantiation for Public Input

This edit clarifies that an enclosed exit is required per platform, which are not interconnected. It is often unsafe for occupants to cross the track to reach an emergency exit.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:28:37 EST 2019

Committee: FKT-AAA

**Public Input No. 20-NFPA 130-2019 [Section No. 5.3.5.9]****5.3.5.9**

Escalators exposed to the outdoor environment shall be provided with slip-resistant landing and floor plates, ~~and if they are~~ .

- Escalators exposed to freezing temperatures, the landing and floor plates and the steps shall be heated to prevent the accumulation of ice and snow.

- Escalators exposed to elevated temperatures, handrails shall remain touchable without discomfort due to excess heat.

Statement of Problem and Substantiation for Public Input

This edit clarifies that where escalators are used in hot environment shall remain usable in an emergency.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:32:55 EST 2019

Committee: FKT-AAA



Public Input No. 21-NFPA 130-2019 [Section No. 5.3.7.1]

5.3.7.1

The egress capacity for doors and gates in a means of egress serving public areas shall be computed as follows:

- (1) 60 people per minute (p/min) for single leaf doors and gates
- (2) 0.0819 p/mm-min (2.09 p/in.-min) for double leaf doors without mullion
- (3) * 0.0819 p/mm-min (2.08 p/in.-min) for bi-parting multileaf doors and gates measured for the clear width dimension.

Statement of Problem and Substantiation for Public Input

This change clarifies that double doors without mullion can use the same value as bi-folding doors. This aligns with the sample calculation in Appendix C.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:42:13 EST 2019

Committee: FKT-AAA

**Public Input No. 22-NFPA 130-2019 [Section No. 5.3.10.2]****5.3.10.2**

Horizontal sliding platform screen or platform edge doors shall be permitted to separate the platform from the trainway in stations, provided that the following criteria are met:

- (1) The doors permit emergency egress from the train to the platform regardless of the stopping position of the train.
- (2) The doors provide egress when a force not exceeding 220 N (50 lb) is applied from the train side of the doors.
- (3) The doors are designed to withstand positive and negative pressures caused by passing trains.

5.3.12.3

In stations where platform is longer than the stationary train, openable platform screen or platform edge doors shall not be required to extend the whole length of the platform where all the following are met:

- (1) Evacuation remains possible through the stationary train in all possible scenarios via an open gangway.
- (2) The maximum permitted distance without openable platform screen or platform edge doors shall not exceed one-half carriage.
- (3) The configuration is supported by fire hazard analysis.

Statement of Problem and Substantiation for Public Input

It is experienced with the increased use of public transport platforms are being congested, hence the platforms are made larger. The size of the rolling stock is not possible to change. Therefore this clause serves to clarify that operable platform edge doors do not need to extend the whole length of the platform when evacuation can be demonstrated from the rolling stock.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 12:50:09 EST 2019

Committee: FKT-AAA



Public Input No. 23-NFPA 130-2019 [Section No. 5.3.11]

5.3.11 Means of Egress Lighting.

5.3.11.1

Illumination of the means of egress in stations, including escalators that are considered a means of egress, shall be in accordance with Section 7.8 of NFPA 101.

5.3.11.2

Means of egress, including escalators considered as means of egress, shall be provided with a system of emergency lighting in accordance with Section 7.9 of NFPA 101.

5.3.11.3

In addition to the requirements of 5.3.11.1 and 5.3.11.2:

- (1) Lighting for stairs and escalators shall be designed to emphasize illumination on the top and bottom steps and landings.
- (2) Where newel- and comb-lighting is provided for escalator steps, such lighting shall be on emergency power circuits.

5.3.12 Accessible Means of Egress

5.3.12.1 Stations shall be designed to meet accessible means of egress requirements in accordance with NFPA 101 7.5.4.

Statement of Problem and Substantiation for Public Input

This change serves to clarify the remind the user to provide accessible means of egress within stations. This is especially important for rail systems as they are designed for full inclusion of the population. With fully automatic rolling stock this is the only place occupants can evacuate safely in case of a fire. The trainway is not currently required to meet with accessible means of egress requirements.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 13:00:03 EST 2019

Committee: FKT-AAA



Public Input No. 87-NFPA 130-2020 [Section No. 5.4.2.1]

5.4.2.1

Enclosed stations shall be protected by an addressable fire alarm system that is ~~designed and installed~~ installed, inspected, and maintained in accordance with Chapters 12, 14, and 23 of NFPA 72, or other equivalent international standards .

Statement of Problem and Substantiation for Public Input

There are unintended consequences from linking a standard for the surface built, occupied environment to underground transit infrastructure. Many systems us 24-hour supervision with computer controlled SCADA systems.

The revisions are necessary to direct users of the standard that the FACP is to be used to receive alarms from the fire detection system and that the FACP sends those alarms to the facility monitoring and control sub-systems such that these sub-systems are empowered to implement an integrated emergency response to the alarms.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 88-NFPA 130-2020 [Global Input]	
Public Input No. 89-NFPA 130-2020 [New Section after 5.4.2.2]	

Submitter Information Verification

Submitter Full Name: Justin Edenbaum
Organization: Never Gray
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 15:31:18 EDT 2020
Committee: FKT-AAA



Public Input No. 89-NFPA 130-2020 [New Section after 5.4.2.2]

FACP Monitoring

The FACP shall be used to receive signals from the facilities' automatic fire detection system and to initiate alarms.

Statement of Problem and Substantiation for Public Input

The revisions are necessary to direct users of the standard that the FACP is to be used to receive alarms from the fire detection system and that the FACP sends those alarms to the facility monitoring and control sub-systems such that these sub-systems are empowered to implement an integrated emergency response to the alarms.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 87-NFPA 130-2020 [Section No. 5.4.2.1]	Follow-on requirement
Public Input No. 90-NFPA 130-2020 [Global Input]	

Submitter Information Verification

Submitter Full Name: Justin Edenbaum
Organization: Never Gray
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 15:45:31 EDT 2020
Committee: FKT-AAA

**Public Input No. 108-NFPA 130-2020 [New Section after 5.4.3]****TITLE OF NEW CONTENT**

Type your content here ...5.4.2.7 . The location of the fire alarm annunciating panel . or fire alarm panel shall not be in a means of egress, or in a ventilation path, and must be approved. .

Statement of Problem and Substantiation for Public Input

Stations which have local fire alarm panels and/or fire alarm annunciator panels which are located in the mean of egress create a necessary can create an exit impediment as the responding agency and fire personnel must access the panel and stand in the way of passenger egress. Also, when located in a ventilation path, this places agency personnel and responders in either the exhausting smoke/heat exhaust which is dangerous or in the supply make up air which can be very cold when exterior temperature are low. This is exacerbated by the wind chill factor.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:25:50 EDT 2020

Committee: FKT-AAA



Public Input No. 24-NFPA 130-2019 [Section No. 5.4.4]

5.4.4 Automatic Fire Suppression Systems.

5.4.4.1*

An automatic sprinkler protection system shall be provided in areas of non-enclosed stations used for concessions, in storage areas, in trash rooms, and other similar areas with combustible loadings, ~~except~~ trainways.

5.4.4.2

Sprinkler protection shall be permitted to be omitted in areas of open stations remotely located from public spaces.

5.4.4.3

~~Where required, sprinkler systems~~ Enclosed stations shall be provided with a sprinkler system designed and installed in accordance with NFPA 13.

5.4.4.4

Automatic sprinkler protection within stations shall be exempt for the trainway section of the station.

5.4.4.5

A sprinkler system waterflow alarm and supervisory signal service shall be installed.

5.4.4.5 6

Other fire suppression systems, if approved, shall be permitted to be substituted for automatic sprinkler systems in the areas listed in 5.4.4.1.

5.4.4.6 7

Automatic fire sprinkler systems shall be tested and maintained in accordance with NFPA 25.

Statement of Problem and Substantiation for Public Input

This change serves to clarify an inconsistency with the application of NFPA 130 and NFPA 101. This clarifies that enclosed stations are required to be fully protected with a sprinkler system per NFPA 13 requirements except the trainway.

In lieu of this, the committee is required to clarify of the existing text would classify an enclosed station as fully sprinkler protected.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 13:06:44 EST 2019

Committee: FKT-AAA



Public Input No. 109-NFPA 130-2020 [Section No. 5.4.4.1]

5.4.4.1*

An automatic sprinkler protection system shall be provided in all areas of stations ~~used for concessions, in storage areas, in trash rooms, and other similar areas with combustible loadings, except trainways.~~ per NFPA 13 including the trainways.

Statement of Problem and Substantiation for Public Input

NFPA prescribes sprinklers in all areas except in nonpublic areas with no combustible loads. Fire sprinklers are already required in all areas of the station where there is a combustible load, except the public areas. Therefore the fire sprinkler supply water, most valves and controls are already required.

Lack of fire sprinklers in public areas discounts the probability of a fire occurring in materials brought into the station. The public areas combustible load can be significant with baggage, baby carriages, backpacks, etc. many of which are hydrocarbon based and therefore burn readily. NFPA 13 does not require under carriage sprinklers which would need to be addressed elsewhere in 130.

Also, rail agencies generally specify that, where possible, a burning train shall be moved from a tunnel into a station or open air to allow safest evacuation. Without sprinklers in underground stations, the arriving train could present a significant fire and ignite carried on combustibles. Fire sprinklers above trainways would usually prevent extension of fire between exterior of cars and platform combustibles from catching fire. Note a burning train could arrive at the station without warning to the waiting passengers (crush load?) on the platform and their luggage. A deluge type system located above the trainway in stations could be remotely activated before arrival of the burning train which would need coordination with evacuation messages. NFPA 13 does not specify under train sprinklers. This language would not trigger retroactive requirements.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: 130 Technical Committee alternative

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:30:39 EDT 2020

Committee: FKT-AAA



Public Input No. 156-NFPA 130-2020 [Sections 5.4.4.1, 5.4.4.2]

Sections 5.4.4.1, 5.4.4.2

5.4.4.1*

~~An automatic~~ Automatic sprinkler protection system shall be provided in areas of enclosed stations used for concessions, ~~in storage~~ as ancillary areas, in trash rooms, and other similar areas with combustible loadings, ~~except trainways~~.

5.4.4.2 –

~~Sprinkler protection shall be permitted to be omitted in areas of open stations remotely located from public spaces.~~

incidental occupancies and nonsystem occupancies.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to clarify the intended provision of sprinkler protection in stations relative to the fire hazard. Refer also to proposed revisions to the definitions for occupancy types in Chapter 3 and to proposed revisions to associated annex language.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 161-NFPA 130-2020 [Section No. 3.3.37]</u>	
<u>Public Input No. 160-NFPA 130-2020 [Section No. A.5.4.4.1]</u>	
<u>Public Input No. 160-NFPA 130-2020 [Section No. A.5.4.4.1]</u>	
<u>Public Input No. 161-NFPA 130-2020 [Section No. 3.3.37]</u>	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 16:35:58 EDT 2020
Committee: FKT-AAA

**Public Input No. 150-NFPA 130-2020 [New Section after 5.4.4.6]****TITLE OF NEW CONTENT**

Appendix note: In many building codes, lucrative construction reduction features are offered for sprinklered-throughout status. That status is not often common knowledge; one definition is found in NFPA 13 at Appendix Note A.81.1. The intent of NFPA 13 is to install sprinklers to mitigate many unforeseen occupancy and operational fire risks. Sprinkler effectiveness is proven, especially in high density assembly occupancies...unless those occupancies are kept almost free of combustibles. Over the 100-year service life of a rail system, there can be drift in the focus on fire prevention. Rooms with electrical gear can safely be protected with wet pipe sprinkler. This not only has proven effective in terms of property protection for large employers, it saves 5%+ on construction costs because in rooms protected with "alternate agents" in place of sprinklers, the lucrative construction reductions awarded for sprinkler throughout status, may be forfeited.

Statement of Problem and Substantiation for Public Input

self-stated

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 30 15:53:47 EDT 2020

Committee: FKT-AAA

**Public Input No. 37-NFPA 130-2019 [Section No. 5.4.5.1]****5.4.5.1***

Class I standpipes shall be installed in enclosed stations in accordance with NFPA 14 except as modified herein for a minimum water supply for 1 hour .

Statement of Problem and Substantiation for Public Input

This change clarifies that a minimum 1 hour water supply should be provided for the standpipe system. Note that NFPA 130 clauses 6.4.5.5 and 6.4.5.6 contain extensive requirements; however this not stated within this section.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Mon Dec 09 04:49:27 EST 2019

Committee: FKT-AAA

**Public Input No. 140-NFPA 130-2020 [Section No. 5.4.5.2]****5.4.5.2**

Standpipe systems shall not be required to be enclosed in fire-rated construction provided the following conditions are met:

- (1) The system is cross-connected at fire pump room, riser room, or other location of grouped mains with the intention to facilitate ITM and RAM. The intent is for all FDCs to be fed from two locations all station standpipes systems, realizing limitations may exist where freezing standpipes is possible.
- (2) Upon approval of the local fire department, only one independent FDC may be provided. The intention is to prevent the fire department from having to lay hose where it obstructs evacuation or firefighter ingress or road traffic .
- (3) Isolation valves are installed not more than 245 m (800 ft) apart and be readily identifiable as to their location .
- (4) Isolation valves will be at the ends of platforms rather than inside trainways, to increase safety for operators.

Statement of Problem and Substantiation for Public Input

The intention is not to tell the Owner or designer how to design in detail, but to offer details that support RAM intentions. In the pressure of an emergency, there is more reliability when every FDC feeds every internal standpipe; there is less chance for mistakenly charging the unintended standpipe. There is more reliability of the hose lays are short and avoiding heavy traffic areas. If there are outside standpipes, these can be joined to inside standpipes when freezing is not a concern.

Submitter Information Verification

Submitter Full Name: Scot Deal
Organization: Excelsior Fire Engineering
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 13:54:35 EDT 2020
Committee: FKT-AAA



Public Input No. 157-NFPA 130-2020 [New Section after 5.4.5.7]

TITLE OF NEW CONTENT

With approval from the fire department, standpipes may be designed with static pressure of 175 psig at the hose valve connection, so long as under full-open valve conditions, the hydraulic pressure-flow rate prescriptions from the local building code or standpipe standard are met.

Statement of Problem and Substantiation for Public Input

With the insertion of static, orifice plates or a run of reduced diameter pipe, there is potential to save time, money, space and improve RAM.

In DUS with office buildings above, it is possible for fire pump to see a wide range of hydraulic demand points. Pressure reducing valves are often used to meet these multiple demand points, but they compromise RAM. As the static 175 will drop to a residual pressure required once the initial transient pressure wave is released, the fire department need exercise some physical prowess for the benefit of all of us. This design in some instances, allows a second set of pumps from being specified, and thus instead of four pumps, 2 for low rise, 2 pumps for high-rise, one can use three pumps with two backups realizing a theoretical 100% increase in reliability. If all pumps are the same duty point, it is easier to maintain and repair parts: increase in RAM. Pressure reducing valves at the hose outlet can be eliminated, much to some manufacturer's chagrin: increase in RAM.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 16:40:57 EDT 2020

Committee: FKT-AAA



Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]

6.1.1* Applicability.

This chapter applies to all portions of the trainway, including pocket storage and tail tracks not intended for occupancy by passengers, except as provided in Sections 6.6 and 6.7 for trainways serving passenger rail and light rail systems.

6.6 Passenger Rail Trainways.

6.6.1 Applicability.

Passenger rail trainways shall comply with Sections 6.1 through 6.5 except as provided in this Section.

6.6.1.1 The requirements of Sections 6.2.2, 6.2.5, 6.2.6, 6.2.7 and 6.2.8 for construction types and combustibility of materials shall not apply to at grade, open trainways.

6.6.1.2* Provisions for egress from at grade, open trainways shall comply with Section 6.3.1.1.

A.6.6.1.2 The intent is that other requirements for provision of egress within trainways as described throughout Section 6.3 do not apply for at grade, open trainways.

6.6.1.3 Emergency access to at grade, open trainways shall be provided as deemed necessary by the authority having jurisdiction.

A.6.6.1.3 The intent is that other requirements for provision of emergency access to trainways as described in Section 6.4.1 do not apply for at grade, open trainways except where required by the local fire department.

6.7 Light Rail Vehicle System Trainways.

6.7.1 Applicability.

Light rail vehicle system trainways shall comply with Sections 6.1 through 6.5 except as provided in this Section.

6.7.1.1 The requirements of Sections 6.2.2, 6.2.5, 6.2.6, 6.2.7 and 6.2.8 for construction types and combustibility of materials shall not apply to at grade light rail system trainways that are located within a street right of way.

6.7.1.2* Provisions for egress from at grade light rail trainways shall comply with Section 6.3.1.1.

A.6.7.1.2 The intent is that other requirements for provision of egress within trainways as described throughout Section 6.3 do not apply for at grade light rail trainways.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to address application of NFPA 130 to Passenger Rail and Light Rail Transit Systems. Existing requirements do not adequately address differences in those systems from typical rapid transit systems relative to fire-life safety hazards. Refer to related proposed revisions to A.1.1.3, new definition for "stop" and associated annex language, new annex language associated with the definition for "station", and proposed new sections 5.6 and 5.7.

Related Public Inputs for This Document

Related Input	Relationship
Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]	
Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	

[Public Input No. 166-NFPA 130-2020 \[Section No. A.1.1.3\(6\)\]](#)

[Public Input No. 167-NFPA 130-2020 \[Section No. 3.3.57\]](#)

[Public Input No. 168-NFPA 130-2020 \[Section No. 5.1.1\]](#)

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund

Organization: JENSEN HUGHES Consulting Canad

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 18:27:03 EDT 2020

Committee: FKT-AAA

**Public Input No. 25-NFPA 130-2019 [Section No. 6.2.1]****6.2.1 Safeguards During Construction.**

A standpipe system shall be installed in enclosed trainways 30 m in length or more under construction in accordance with NFPA 241.

Statement of Problem and Substantiation for Public Input

This edit seeks to clarify that tunnels over a certain length require a standpipe during construction. A small tunnel say 10 m in length would not require a standpipe.

30 m is selected back upon a hose reels with 30 m coverage.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 14 09:31:59 EST 2019

Committee: FKT-AAA

**Public Input No. 26-NFPA 130-2019 [Section No. 6.2.2.6]****6.2.2.6 Surface.**

Construction materials shall be materials or assemblies permitted for use in Type I or Type II construction, in accordance with NFPA 220, unless otherwise permitted by a fire hazard analysis of potential fire exposure hazards to the structure.

Statement of Problem and Substantiation for Public Input

This edit seek to confirm that Type II material can also be used. Type II is permitted for elevated sections, so the same should apply for at grade systems.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 14 09:35:45 EST 2019

Committee: FKT-AAA

**Public Input No. 117-NFPA 130-2020 [Section No. 6.2.3]**

6.2.3 – Flammable and Combustible Liquids Intrusion.

6.2.3.1 – General.

Protection of belowgrade system structures against the accidental intrusion of flammable and combustible liquids shall meet the requirements of 5.2.3 .

Statement of Problem and Substantiation for Public Input

Refer to PI 115 for problem input

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 115-NFPA 130-2020 [Section No. 5.2.3]	Delete text
Public Input No. 116-NFPA 130-2020 [Section No. 7.6]	Move 5.2.3 to new Subsection 7.6.3

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 02:19:04 EDT 2020
Committee: FKT-AAA



Public Input No. 105-NFPA 130-2020 [Sections 6.2.5.1, 6.2.5.2, 6.2.5.3]

Sections 6.2.5.1, 6.2.5.2, 6.2.5.3

6.2.5.1

~~Where combustible components not specifically addressed in this standard are installed in a trainway, a fire hazard analysis shall be conducted to determine that~~ Non-structural combustible and composite materials can be used in or along a trainway, where otherwise required by this standard to be noncombustible, when supported by a fire hazard analysis that determines the level of occupant fire safety is not adversely affected by the contents.

6.2.5.2 3

The fire hazard analysis required by 6.2.5.1- shall meet the following criteria:

- ~~It shall include, as a minimum, an examination of peak heat release rate for combustible elements, total heat released, ignition temperatures, radiant heating view factors, and behavior of the component during internal or external fire scenarios.~~

~~It shall determine~~ shall verify that, if a fire propagates beyond involving the component ~~component of fire origin, a level of fire safety is provided~~ within an enclosed along the trainway commensurate with this standard.

6.2.5.3 –

Computer

2 –

The fire hazard analysis required by 6.2.5.1 shall use appropriate engineering methods, such as computer modeling, material fire testing, or full-scale fire testing ~~shall be conducted~~ to assess the performance in potential fire scenarios commensurate with the proposed location and trainway environment . It shall include an examination of peak heat release rate for combustible elements, total heat released, ignition temperatures, radiant heating view factors, and behavior of the component during internal or external fire scenarios.

Statement of Problem and Substantiation for Public Input

The proposed change provides more specific wording to the application of the requirement to nonstructural elements, connects the two paragraphs that were about analytical methods, adds composite materials, and separates the paragraph that defines acceptance criteria. Renumbering is also provided to combine the analytical section as sentence 2 and the acceptance criteria as sentence 3.

The first instance of the requirement was in the 2003 Edition of NFPA 130 and was specific to underground subways. The substantiation for the change indicated was intended for any non-structural tunnel components such as signalling devices, communication equipment and lighting systems, all of which would otherwise be required to be noncombustible by the standard. This addressed a gap in the standard where flexibility was needed to allow for variations in the use of materials while maintaining a level of protection in consideration of the tunnel as a "means of egress" from a train fire in the tunnel. The substantiation also included a performance criteria for combustible materials based on the performance requirements permitted for combustibles on trains. The Committee accepted the change, in part, keeping the general requirements, but not keeping the performance criteria. This is explained in the Committee Statement as follows, "The fire safety performance submitted in the original proposal was eliminated due to lack of justification in applying vehicle component test criteria to tunnel construction and components. The proposed change provides criteria to evaluate impact of the components on the fire safety of combustible components not currently addressed ... "

It can be inferred from the documentation that the concern with the combustible components was primarily intended to address enclosed trainways (i.e., tunnels) addressing the risks of egress associated with the tunnel. However, in the 2006/2007 version of the standard, a further change was made that altered its application to all trainways and not just tunnels. The Committee initiative appears to have been intended for renumbering, but the editorial changes altered its application to apply to any trainway component, thereby extending its application to at-grade and elevated trainways. This aspect of the change is not addressed in the Committee documentation,

A final change occurred in the 2014 edition of NFPA 130, where the appendix note for the combustible components paragraph was adopted into the text of the standard and the appendix note was eliminated. The 2017 version of

the standard is identical to the 2014 version, as is the 2020 version of NFPA 130 even though it is not being applied to this Project. Therefore, in reviewing the documentation supporting the change to the standard, it can be concluded that:

1. The requirement is intended to allow for the use of non-structural combustible components on elements otherwise required by the standard to be noncombustible.
2. The requirement was originally intended for subway tunnels that are used as a means of egress and therefore pose a risk of exposure to combustible components. Its subsequent application to all trainways, including elevated and at-grade components, appears to be editorial.

Reworking of the requirements is intended to update the context to reflect its application to all trainways, clarify that it is for nonstructural elements, include composite materials, and align performance analysis while separating the criteria.

Submitter Information Verification

Submitter Full Name: Peter Senez

Organization: Senez Consulting Ltd.

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:03:36 EDT 2020

Committee: FKT-AAA

**Public Input No. 120-NFPA 130-2020 [Section No. 6.2.7.2]****6.2.7.2**

Coverboard or protective material tested in accordance with ASTM E84 or [UL 723](#) shall have a flame spread index of not more than 25 and a smoke developed index not exceeding 450.

Statement of Problem and Substantiation for Public Input

UL 723 is an equivalent standard to ASTM E 84. Both standards are used to determine flame spread and smoke development ratings of different materials. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever these ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 119-NFPA 130-2020 [Section No. 5.2.5.1]	
Public Input No. 121-NFPA 130-2020 [Section No. 6.2.8.2]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 10:07:02 EDT 2020
Committee: FKT-AAA

**Public Input No. 51-NFPA 130-2020 [Section No. 6.2.8]****6.2.8 Rail Ties.****6.2.8.1**

Rail ties used in enclosed locations shall be noncombustible materials in accordance with Section 4.6.

6.2.8.2

Rail ties used outdoors at switch or crossover locations shall be made of materials that comply with one of the following:

- (1) ~~Materials that comply with 6.2.8.1~~ Noncombustible materials in accordance with Section 4.6.
- (2) Fire retardant-treated wood in accordance with NFPA 703
- (3) Pressure-treated wood materials that exhibit a flame spread index of not more than 75 when tested in accordance with ASTM E84
- (4) Plastic composite materials that comply with the requirements of ASTM D7568 and exhibit a flame spread index of not more than 75 in accordance with ASTM E84
- (5) Limited-combustible materials in accordance with 4.6.2
- (6) Wood encased in concrete such that only the top surface is exposed

6.2.8.3

Rail ties used outdoors at locations other than switch or crossover locations shall comply with one of the following:

- (1) Materials that comply with with 6.2.8.1 ~~or 6.2.8.2~~
- (2) Pressure treated wood materials
- (3) Plastic composite materials that comply with the requirements of ASTM D7568

Statement of Problem and Substantiation for Public Input

This makes the section easier to follow because it sends directly to the relevant sections. At present 6.2.8.2 sends you to 6.2.8.1 which then sends you to 4.6, while the PI recommends going directly to 4.6. At present 6.2.8.3 sends you to 6.2.8.2 which sends you to 6.2.8.1 or gives other options; sending to 6.2.8.1 from 6.2.8.3 is unnecessary as it is already covered in 6.2.8.2.

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submittal Date: Thu Jun 18 17:48:17 EDT 2020

Committee: FKT-AAA

**Public Input No. 121-NFPA 130-2020 [Section No. 6.2.8.2]****6.2.8.2**

Rail ties used outdoors at switch or crossover locations shall be made of materials that comply with one of the following:

- (1) Materials that comply with 6.2.8.1
- (2) Fire retardant-treated wood in accordance with NFPA 703
- (3) Pressure-treated wood materials that exhibit a flame spread index of not more than 75 when tested in accordance with ASTM E84
- (4) Plastic composite materials that comply with the requirements of ASTM D7568 and exhibit a flame spread index of not more than 75 in accordance with ASTM E84 or UL 723
- (5) Limited-combustible materials in accordance with 4.6.2
- (6) Wood encased in concrete such that only the top surface is exposed

Statement of Problem and Substantiation for Public Input

UL 723 is an equivalent standard to ASTM E 84. Both standards are used to determine flame spread and smoke development ratings of different materials. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever these ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 119-NFPA 130-2020 [Section No. 5.2.5.1]	
Public Input No. 120-NFPA 130-2020 [Section No. 6.2.7.2]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 10:08:33 EDT 2020
Committee: FKT-AAA



Public Input No. 101-NFPA 130-2020 [Section No. 6.3.1.4]

6.3.1.4*

Within enclosed trainways, the maximum distance between exits shall not exceed ~~762 m~~ 244m
(~~2500 ft~~ 800 ft). _ _ .

Statement of Problem and Substantiation for Public Input

Recommended change to provide equivalent level of safety between tunnels with and without cross passages. From a safety perspective, requiring a path to safety at 800 feet in tunnels with a cross passage while allowing a distance three times greater in a tunnel without cross passages places passengers at considerably higher risk in the tunnel for the same fire scenario.

For example a realistic example of a tunnel just under 2500 feet, with longitudinal ventilation and a train stopped and unable to move just before exiting the portal. Adding a fire in the rear portion of the train presents the following scenario. Operator would request ventilation towards rear of train (to protect most passengers). Passengers would be directed to evacuate in clean air towards safety of nearby portal, i.e. front of train. However, passengers downstream of the fire may not be able to move past the fire and would be exposed to heat, smoke, toxic gases. They would either wait for rescue or self-evacuate downwind toward the closest exit, in this case the portal, roughly 2000? feet away (distance from rear portion of train to the opposite portal)

At 2000? ft the travel time for the first person evacuating from rear of train and walking in clear air would be just over 16 minutes. (2020 130 5.3.4.4 maximum egress travel speed along...corridors... shall be computed at 37.7m/min (124 ft/min). However, evacuees will tend to walk in single file along the narrow walkway, meaning they will be moving at speed of the slowest person, so the corridor calculation may be too fast.

Walking in smoke with reduced visibility, exposed to gas and heat, will result in even slower walking speed. Following example provide results from several studies yielding a very slow walking speed in smoke of 40ft/min vs the 124 ft/min., resulting in an expected walking time to portal safety increased time from 16 minutes to roughly 48 minutes. This walking speed is based on following (which is used as an one example of walking in tunnels in smoke.)

"Method 3: The representation is done individually

Each individual's walking speed in smoke-free conditions is randomised, and is then assumed to reduce linearly as for method 1 and 2 in smoke. Practically, method 3 means that:

- Visibility levels > 3 meter: Peoples' walking speed is represented by a randomised value from a normal distribution with mean 1,35 m/s and standard deviation 0,25 m/s (based on Fruin [15]) with minimum and maximum thresholds of 0,85 and 1,85 m/s.
- Visibility levels ≤ 3 meter: Peoples' walking speed is represented by a relative reduction of 0,34 m/s per meter visibility down to the minimum speed of 0,2 m/s." (40ft / min) (1)

Some individuals will possibly just stop given the distance, possibly difficulty breathing, reduced visibility, or physical limits. This effectively stops the orderly evacuation of everyone following them in single file. Slow or stopped evacuation could result in some individuals moving to the invert (taking the risk of third rail exposure) to evacuate.

For comparison tunnels with cross passages, and assuming a distance of 250 ft evacuation distance to reach a cross passage, the time would be 2 minutes without smoke. Same challenge with slow walkers, reduced visibility exist albeit exposure time would be less.

If the expectation the local fire responders will be able to assist evacuees at those distances, this is incorrect. Firefighters lack the necessary air supply in the air bottles they wear to walk to the train, and safely return. The air supply will last approximately 15-20 minutes while walking. This would allow them to walk from the either portal to reach evacuees who need assistance, but their air supply would be inadequate to perform search and perform rescues.

For firefighters, the lack of air supply could be addressed by installing Firefighter Air Replenishment System (FARS) now required in some high rise buildings. However this is NOT available for evacuees.

(1) "WALKING SPEED IN SMOKE: REPRESENTATION IN LIFE SAFETY" Karl Fridolf, WSP Sverige AB

Submitter Information Verification**Submitter Full Name:** Gary English**Organization:** Underground Command And Safety**Affiliation:** NFPA 130 technical committee alternate**Street Address:****City:****State:****Zip:****Submittal Date:** Mon Jun 29 23:31:41 EDT 2020**Committee:** FKT-AAA

**Public Input No. 111-NFPA 130-2020 [Section No. 6.3.2.1]****6.3.2.1***

The means of egress within the trainway shall be provided with an unobstructed clear width graduating from ~~610 mm (24 in.)~~ from ~~610 mm (24 inches)~~ 914 mm (36") at the walking surface to ~~760 mm~~ 760mm (~~30 in.)~~ at ~~1575 mm (62 in.~~ 30 inches) ~~1067 mm (42 inches)~~ at 1575 mm (62") above the ~~walking surface to~~ 430 mm (17 in.) at ~~2025 mm (80 in.~~ walkway surface to ~~430 mm (17 inches)~~ 737mm (29 inches) at ~~2025mm~~ 2032 mm (80") above the walking surface.

Statement of Problem and Substantiation for Public Input

Current language at 24" is a very narrow pathway and is not allowed for public egress in any adopted standards (NFPA 101, IBC, etc., other than staff access to utility equipment) The proposed increase partially addresses the larger physical size of today's population than earlier Fruin analysis. The 36" walkway width would allow some people to squeeze past each other which might occur when someone is walking slowly, thus improving egress times. In addition the emergency gurneys used to evacuate passengers who cannot walk, has a wheel width of 23". The 24" width allows the gurney wheels to readily fall off the walkway. For very large patients who cannot fit on a gurney, a low friction 'solid membrane' flexible skid with handles is used. The wider width would make it possible to move most people at the walkway width on this skid. 36" is allowed in some new construction under NFPA 101. IF this is adopted, corresponding changes in Annex 6.3.2.1 would be necessary.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 30 00:49:47 EDT 2020

Committee: FKT-AAA



Public Input No. 153-NFPA 130-2020 [Sections 6.3.3.5, 6.3.3.6, 6.3.3.7, 6.3.3.8, 6.3.3.9]

Sections 6.3.3.5, 6.3.3.6, 6.3.3.7, 6.3.3.8, 6.3.3.9

6.3.3.5*

Walkways that are more than 760 mm (30 in.) above the floor or grade below shall be provided with a continuous guard to prevent falls over the open side .

6.3.3.6 –

except at the following locations.

(1) Guards shall not be required along the trainway side of walkways where the bottom of the trainway is closed by a deck or grating.

6.3.3.7 –

(2) Guards shall not be required on walkways that are located between two trainways where the bottom of the trainway is closed by a deck or grating .

6.3.3.

8

6 * –

Handrails for walkways shall be provided as follows:

(1) Walkways that are more than 760 mm (30 in.) above the floor or grade below shall be provided with a continuous handrail along the side opposite the trainway.

6.3.3.9 –

(2) Walkways that are greater than 1120 mm (44 in.) wide and located between two trainways shall not be required to have a handrail.

Statement of Problem and Substantiation for Public Input

Proposed re-organization of this section is intended to provide better grouping of related requirements. Proposed revision to 6.3.3.7 (now 6.3.3.5(2)) is to address similar conditions to those applicable for 6.3.3.6 (now 6.3.3.5(1)). Proposed revisions to related annex language are to more adequately address intended application for conditions that are commonly found in transit system trainways.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 154-NFPA 130-2020 [Sections A.6.3.3.5, A.6.3.3.8]</u>	
<u>Public Input No. 154-NFPA 130-2020 [Sections A.6.3.3.5, A.6.3.3.8]</u>	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 16:14:33 EDT 2020
Committee: FKT-AAA

**Public Input No. 28-NFPA 130-2019 [Sections 6.3.3.5, 6.3.3.6, 6.3.3.7, 6.3.3.8, 6.3.3.9]****Sections 6.3.3.5, 6.3.3.6, 6.3.3.7, 6.3.3.8, 6.3.3.9****6.3.3.5***

Walkways that are more than 760 mm (30 in.) above the floor or grade below shall be provided with a continuous guard, in accordance with NFPA 101 Chapter 7 except as modified herein, to prevent falls over the open side. The guard shall provide consist of a continious handrail along the side opposite of the trainway.

6.3.3.6

Guards shall not be required along the trainway side of walkways where the bottom of the trainway is closed by a deck or grating.

6.3.3.7

Guards shall not be required on walkways that are located between two trainways.

6.3.3.8*

~~Walkways that are more than 760 mm (30 in.) above the floor or grade below shall be provided with a continuous handrail along the side opposite the trainway.~~

6.3.3.9 –

~~Walkways that are greater than 1120 mm (44 in.) wide and located between two trainways shall not be required to have a handrail.~~

Statement of Problem and Substantiation for Public Input

This change serves to send the designer to NFPA 101 for guard requirements. As it stands, the code requires a guard however does not state how the guard should be designed and the height. requirement of the guard. In addition, the handrail clause of 6.3.3.8 is merged within the edit, as this information is duplication and could lead to confusion within an environment where NFPA 101 is not applied.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submission Date: Thu Nov 21 09:38:16 EST 2019

Committee: FKT-AAA



Public Input No. 148-NFPA 130-2020 [Sections 6.3.3.10, 6.3.3.11, 6.3.3.12, 6.3.3.13]

Sections 6.3.3.10, 6.3.3.11, 6.3.3.12, 6.3.3.13

6.3.3.10*

Exit stairs and doors shall comply with Chapter 7 of NFPA 101, except as herein modified.

A. 6.3.3.

11

Doors in the means of egress, ~~except cross-passageway doors,~~ shall open in the direction of exit travel. **10**

Section 6.3.3.10 is not intended to apply to stairs within the trainway that facilitate transition from trainway walkways where space constraints limit strict compliance--e.g., at track crossings or at ends of station platforms. Where such transition are required, steps should be as uniform as possible and additional markings may be required where design varies considerably from NFPA 101 criteria.

6.3.3.12 11

Doors in the means of egress, ~~except cross-passageway doors,~~ shall comply with the following:

~~Open~~ (1) They shall open in the direction of exit travel.

(2) They shall open fully when a force not exceeding 220 N (50 lb) is applied to the latch side of the door

~~Be adequate to~~

.

(3) They shall withstand positive and negative pressures caused by passing trains and the emergency ventilation system .

6.3.3.13 12

Cross-passageway doors shall comply with the following:

(1) Horizontal sliding doors shall be permitted in cross-passageways. .

(2)* The force required to slide the doors to an open position shall not exceed 220 N (50 lb).

(3) They shall return to a closed position when the opening force is removed.

(4) They shall withstand positive and negative pressures caused by passing trains and the emergency ventilation system.

A.6.3.3.12(2)

The intent is that the required force may be applied as an action to horizontally slide the door to an open position.

Statement of Problem and Substantiation for Public Input

Proposed revisions are to clarify intended application of NFPA 101 and NFPA 130 requirements for egress components in trainways.

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund

Organization: JENSEN HUGHES Consulting Canad

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 15:50:29 EDT 2020

Committee: FKT-AAA

**Public Input No. 112-NFPA 130-2020 [Section No. 6.3.3.11]****6.3.3.11**

Doors in the means of egress, except cross-passageway doors immediately adjacent to the trainway , shall- shall open in the direction of exit travel.

Statement of Problem and Substantiation for Public Input

Only door swing adjacent to the trainway which could impede the emergency walkway needs to swing in the opposite direction of travel. For cross passages where the doors are recessed far enough away from the walkway, the doors can swing in the direction of travel.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 00:57:18 EDT 2020

Committee: FKT-AAA

**Public Input No. 113-NFPA 130-2020 [Section No. 6.3.3.12]****6.3.3.12**

Doors in the means of egress shall comply with the following:

- (1) Open fully when a force not exceeding ~~220 N~~ 133 N (~~50-lb~~ 30 lb) is applied to the latch side of the door
- (2) Be adequate to withstand positive and negative pressures caused by passing trains and the emergency ventilation system

Statement of Problem and Substantiation for Public Input

For individuals with limited strength, or physical disabilities, the allowance of a 50lb swing force is difficult or impossible. This also conflicts with standard building code language where 30lbs is the maximum allowed. Pressure relief vents and power assisted doors have been used successfully to overcome ventilation pressures

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 01:05:50 EDT 2020

Committee: FKT-AAA



Public Input No. 170-NFPA 130-2020 [Sections

6.4.1.2, 6.4.1.3, 6.4.1.4, 6.4.1.5, 6.4.1.6, 6.4.1...]

Sections 6.4.1.2, 6.4.1.3, 6.4.1.4, 6.4.1.5, 6.4.1.6, 6.4.1.7, 6.4.1.8

6.4.1.2

If Where security fences are used along the trainway, access gates shall be provided ~~in security fences~~, as deemed necessary by the authority having jurisdiction.

6.4.1.3 –

–

(2) Access gates shall be a minimum 1120 mm (44 in.) wide and shall be of the hinged or sliding type.

6.4.1.4

(1) Access gates shall be placed as close as practicable to the portals to permit easy access to enclosed trainways.

6.4.1.5

(3) Information that clearly identifies the route and location of each gate shall be provided on the gates or adjacent thereto.

6 6.4.1.6 3

Access to ~~the elevated trainway~~ trainways shall be from stations or by mobile ladder equipment from roadways adjacent to the ~~trackway~~ trainway .

A. 6.4.1.7 – 3

If no adjacent or crossing roadways exist for ~~the elevated trainway~~, ~~access roads at a maximum of 762 m (2500 ft) intervals shall be required.~~ additional crossings may be required where access from adjacent stations is deemed insufficient by the authority having jurisdiction.

6.4.1.4

Access to open-cut trainways shall be from stations or by mobile ladder equipment from roadways adjacent to the trainway.

A. 6.4.1.8 4

Where the configuration of an open-cut trainway prevents or impedes access for firefighting, additional provisions shall ~~may be made~~ required to permit ~~facilitate~~ fire fighter access to that section of trainway at intervals not exceeding 762 m (2500 ft) where access from adjacent stations is deemed insufficient by the authority having jurisdiction .

Statement of Problem and Substantiation for Public Input

Proposed re-organization of this section is intended to provide better grouping of related requirements. Proposed revisions to requirements in 6.4.1.6 through 6.4.1.8 (now 6.4.1.3, 6.4.1.4 and associated annex language) are to differentiate between performance requirements versus potential design solutions, and to delete references to specific distances that are not substantiated by technical rationale.

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund

Organization: JENSEN HUGHES Consulting Canad

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 30 19:23:27 EDT 2020

Committee: FKT-AAA

**Public Input No. 29-NFPA 130-2019 [Section No. 6.4.1.3]****6.4.1.3**

Access gates shall be a minimum ~~1120 mm~~ 810mm (44 in 31.9 in.) wide and shall be of the hinged swing out of the trainway, or sliding type.

Statement of Problem and Substantiation for Public Input

The code provides no guidance as to this requirements.

The proposed change clarifies the route can be used for evacuation purposes, as well as fire department access.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 21 10:04:56 EST 2019

Committee: FKT-AAA

**Public Input No. 30-NFPA 130-2019 [Section No. 6.4.2.1]****6.4.2.1***

Blue light stations shall be provided at the following locations:

- (1) At the ends of station platforms
- (2) At cross-passageways
- (3) At emergency access points
- (4) At emergency entry points
- (5) At traction power substations
- (6) In enclosed trainways as approved

Statement of Problem and Substantiation for Public Input

BLS is designed for cut power to the traction power, hence this change clarifies the BLS is required at emergency entry points to ensure this functionally.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 21 10:10:11 EST 2019

Committee: FKT-AAA

**Public Input No. 86-NFPA 130-2020 [Section No. 6.4.2.1]****6.4.2.1***

Blue light stations shall be provided at the following locations:

- (1) At the ends of station platforms
- (2) At cross-passageways
- (3) At emergency access points gates
- (4) At traction power substations
- (5) In enclosed trainways as approved

Additional Proposed Changes

<u>File Name</u>	<u>Description Approved</u>
Proposed_coce_change_to_6.4.2.1.docx	

Statement of Problem and Substantiation for Public Input

This use of the term emergency access point (EAP) is undefined and occurs only the reference to blue light stations; and is not otherwise referred to, defined or elaborated up. This leaves it open for interpretation as to whether or where it is intended to apply. Elsewhere in the standard, there are many other terms that are used in reference to access. Clause 6.4.1 requires "Emergency Access," but does not further clarify which should be considered as EAPs. Instead, it uses "emergency access routes," "access gates," and "access to the elevated trainway," "access roads," and "access for firefighting." It is not forthright that all or any of these are intended to be EAP's.

Therefore, it is reasonable to interpret that none of these are EAP's. Blue light stations are only therefore required on elevated and at-grade trainways at the stations, which are also designated "emergency access routes," which is the closest equivalent to the use of the EAP term within NFPA 130.

The need for blue light stations on elevated and at-grade sections is becoming a dated concept. Workers and fire fighters depend on the OCC for control of power and frequently don't have the expertise needed to disable power and confidently proceed with emergency operations. NFPA 130 doesn't required two-way communication on at-grade or elevated. Coordinating the language and terminology of Chapter 6 access requirements and blue lights is therefore needed to establish where blue light stations are required on at-grade and elevated sections.

Submitter Information Verification

Submitter Full Name: Peter Senez
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submission Date: Mon Jun 29 11:08:37 EDT 2020
Committee: FKT-AAA

**Public Input No. 103-NFPA 130-2020 [Section No. 6.4.3]****~~6.4.3 – Emergency Communications System.~~**

~~Enclosed trainways shall be provided with an emergency communications system in accordance with Chapter 10.~~

Statement of Problem and Substantiation for Public Input

Section 6.4.3 applying only to "Enclosed Trainways" is in conflict with 10.1 which applies "throughout fixed guideway transit and passenger rail systems," and 10.4.1 which applies to "Enclosed stations and ALL trainways." It is therefore proposed that 6.4.3 be deleted in its entirety to eliminate confusion..

Submitter Information Verification

Submitter Full Name: Peter Senez

Organization: Senez Consulting Ltd.

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 23:44:40 EDT 2020

Committee: FKT-AAA

**Public Input No. 36-NFPA 130-2019 [Section No. 6.4.5]****6.4.5 Standpipe and Hose Systems.****6.4.5.1**

An approved fire standpipe system shall be provided in enclosed trainways where physical factors prevent or impede access to the water supply or fire apparatus, where required by the authority having jurisdiction.

6.4.5.2

A fire standpipe system is not required in open trainways.

6.4.5.3 *

Class I standpipe systems shall be installed in enclosed trainways in accordance with NFPA 14 except as modified herein.

6.4.5.3 4

Standpipe systems shall not be required to be enclosed in fire-rated construction, provided the following conditions are met:

- (1) The system is cross-connected or fed from two locations.
- (2) Isolation valves are installed not more than 244 m (800 ft) apart.

6.4.5.4 5

Standpipes shall be permitted to be of the dry type with the approval of the authority having jurisdiction provided the following conditions are met:

- (1) * Standpipes shall be installed so that the water is delivered to all hose connections on that standpipe in 10 minutes or less.
- (2) Combination air relief–vacuum valves shall be installed at each high point on the standpipe.

6.4.5.5 6

Standpipe systems shall be provided with an approved water supply capable of supplying the system demand for a minimum of 1 hour.

6.4.5.6 7

Acceptable water supplies shall include the following:

- (1) Municipal or privately owned waterworks systems that have adequate pressure, flow rate, and level of integrity
- (2) Automatic or manually controlled fire pumps that are connected to water source
- (3) Pressure-type or gravity-type storage tanks that are installed in accordance with NFPA 22

6.4.5.7 8

Identification numbers and letters conforming to the system sectional identification numbers and letters shall be provided at each surface fire department connection and at each hose valve on the standpipe lines.

6.4.5.8 9

Identifying signs shall be affixed to enclosed trainway walls at each hose outlet valve or shall be painted directly on the standpipe in white letters next to each hose outlet valve.

6.4.5.9 10

Exposed standpipe lines and identification signs shall be painted as required by the authority having jurisdiction.

6.4.5.10 11

A fire department access road shall extend to within 30.5 m (100 ft) of the fire department connection.

This proposed change highlights that a fire standpipe is not required for non enclosed trainways.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Mon Dec 09 04:41:54 EST 2019

Committee: FKT-AAA



Public Input No. 142-NFPA 130-2020 [New Section after 6.4.5.10]

Standpipe Capacity

Requirement for standpipes on both sides of a fixed guideway is not intended; the AHJ shall justify need for more than one standpipe.

*Appendix Note: Reliability of one standpipe is better than simultaneous degradation of two standpipes. Galvanized piping is good on paper, but not as productive in practice, some large organizations ban Zn-coated pipe due to lower RAM.

Statement of Problem and Substantiation for Public Input

Safety is a balance between tolerated risk and expense of time, money and energy. Rarely do standpipes on both sides of a single fixed guideway provide beneficial risk reduction equal to the expense in time, money or energy.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 14:42:19 EDT 2020

Committee: FKT-AAA

**Public Input No. 31-NFPA 130-2019 [Section No. 6.4.8.2]****6.4.8.2**

The following systems shall be connected to the emergency power system:

- (1) Emergency lighting
- (2) Emergency tunnel ventilation system
- (3) Protective signaling systems
- (4) Emergency communication system
- (5) Fire command center

Statement of Problem and Substantiation for Public Input

This change clarifies that emergency power is required for the tunnel ventilation system in emergency mode.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 21 10:15:10 EST 2019

Committee: FKT-AAA

**Public Input No. 61-NFPA 130-2020 [Section No. 6.4.8.3]****6.4.8.3**

The emergency lighting and communications circuits shall be kept entirely independent from all other none emergency circuits and protected from physical damage by system vehicles or other normal system operations and from fire as described in 12.4.4.

Statement of Problem and Substantiation for Public Input

The only way to prevent failure in both circuits during a fault condition will be to isolated the normal circuits from the emergency circuits.

Additionally, In a fire event, the non-emergency circuits are not designed to survive a fire and will likely fail during a fire. This type of event can cause the emergency circuits to fail. Therefore, the normal and emergency circuits shall not share the same raceway.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 22 15:21:28 EDT 2020

Committee: FKT-AAA

**Public Input No. 137-NFPA 130-2020 [Section No. 7.3.2.1]****7.3.2.1**

The fan inlet airflow ~~hot~~ design temperature shall be determined by an engineering analysis, however, this temperature shall not be less than 150°C (302°F).

Statement of Problem and Substantiation for Public Input

Incorrect grammar - temperature is a measure of heat. A body or fluid can be 'hot', have a 'high temperature' or a 'design temperature'. A temperature can be 'high' or 'low' relative to some datum.

Submitter Information Verification

Submitter Full Name: Conor Fleming

Organization: Coanda Research and Development Corporation

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 13:23:42 EDT 2020

Committee: FKT-AAA

**Public Input No. 138-NFPA 130-2020 [Section No. 7.3.2.2]****7.3.2.2***

The fan inlet airflow ~~hot~~ design temperature shall be determined using the design fire at a location in the immediate vicinity of the emergency ventilation system track/station inlet(s), as applicable. Airflow rates shall be based upon the rates needed to achieve the critical velocity in enclosed trainways or station tenability requirements, as applicable.

Statement of Problem and Substantiation for Public Input

Incorrect grammar - temperature is a measure of heat. A body or fluid can be 'hot', have a 'high temperature' or a 'design temperature'. A temperature can be 'high' or 'low' relative to some datum.

Submitter Information Verification

Submitter Full Name: Conor Fleming

Organization: Coanda Research and Development Corp

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 13:27:52 EDT 2020

Committee: FKT-AAA

**Public Input No. 43-NFPA 130-2020 [Section No. 7.5]****7.5** Testing.**7.5.1** *

Equipment used for emergency ventilation (including fans, dampers, and airflow control devices) shall ~~be listed for~~ be designed for the application or shall be approved by the authority having jurisdiction in accordance with the requirements of a recognized standard for the type of equipment to be installed.

7.5.2 *

The no-fire (or cold) airflows provided by the installed mechanical ventilation system shall be measured during commissioning to confirm that the airflows meet the requirements determined by the engineering analysis.

Statement of Problem and Substantiation for Public Input

there have been some job specifications issued, where the designer saw that dampers had to be "listed"; and went out to look for a listing agent to put into the specifications. In one case, the specification called for tunnel vent dampers to be UL Listed. These dampers have many different configurations, many different types of actuators and are generally much larger than UL tests can accommodate. Therefore, tunnel vent dampers are not "listed" by any 3rd party body like UL or others.

Submitter Information Verification

Submitter Full Name: William Lampkin

Organization: Greenheck Fan Corporation

Street Address:

City:

State:

Zip:

Submittal Date: Mon Mar 02 11:24:51 EST 2020

Committee: FKT-AAA



Public Input No. 116-NFPA 130-2020 [Section No. 7.6]

7.6 Emergency Ventilation Openings.

7.6.1

Emergency ventilation openings shall be positioned or designed to minimize recirculation of smoke into the station or enclosed trainway through any openings, such that a tenable environment is maintained along the path of egress for the time of tenability and as required for designated points of safety.

7.6.2

Adjacent structures and property uses also shall be considered.

7.6.3 Flammable and Combustible Liquids Intrusion.

7.6.3.1 General.

Protection of belowgrade system structures against the accidental intrusion of flammable and combustible liquids shall be provided in accordance with 7.6.3.

7.6.3.2 Vehicle Roadway Terminations.

Vent or fan shafts utilized for ventilation of belowgrade system structures shall not terminate at grade on any vehicle roadway.

7.6.3.3 Median and Sidewalk Terminations.

Vent and fan shafts shall be permitted to terminate in the median strips of divided highways, on sidewalks designed to accept such shafts, or in open space areas, provided that the grade level of the median strips, sidewalk, or open-space meets the following conditions:

- (1) It is at a higher elevation than the surrounding grade level.
- (2) It is separated from the roadway by a concrete curb at least 150 mm (6 in.) in height.

Statement of Problem and Substantiation for Public Input

Refer to PI#115. This moves the text from Subsection 5.2.3 to Section 7.6

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 115-NFPA 130-2020 [Section No. 5.2.3]	
Public Input No. 117-NFPA 130-2020 [Section No. 6.2.3]	

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 02:14:46 EDT 2020
Committee: FKT-AAA



Public Input No. 163-NFPA 130-2020 [Section No. 7.6]

7.6 Emergency Ventilation Openings.

7.6.1

Emergency ventilation openings shall be positioned or designed to minimize recirculation of smoke into the station or enclosed trainway through any openings, such that a tenable environment is maintained along the path of egress for the time of tenability and as required for designated points of safety.

7.6.2

Emergency ventilation openings shall be positioned or designed to prevent the accidental intrusion of flammable or combustible liquids into belowgrade system structures.

A.7.6.2

Refer also to A.5.2.3.1.

7.6.3

Adjacent structures and property uses also shall be considered.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to indicate the performance intent of the requirements, with potential design solutions more appropriately relocated to Annex language. Refer also to proposed revisions to Section 5.2.3.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 162-NFPA 130-2020 [Section No. 5.2.3]	
Public Input No. 162-NFPA 130-2020 [Section No. 5.2.3]	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 17:56:07 EDT 2020
Committee: FKT-AAA



Public Input No. 62-NFPA 130-2020 [Section No. 7.8.1]

7.8.1

The design of the power for the emergency ventilation system shall comply with the requirements of Article 700 of *NFPA 70*. The emergency ventilation circuits shall be kept entirely independent from all other non-emergency circuits.

7.8.1.1

Alternatively, the design of the power for the emergency ventilation system shall be permitted to be based upon the results of the electrical reliability engineering analysis according to 7.2.3(6), as approved.

7.8.1.2

The emergency ventilation circuits routed through the station public areas and trainway shall be protected from physical damage by fixed guideway transit or passenger rail vehicles or other normal operations and from fire as described in 12.4.4.

Statement of Problem and Substantiation for Public Input

The only way to prevent failure in both circuits during a fault condition will be to isolated the normal circuits from the emergency circuits.

Additionally, In a fire event, the non-emergency circuits are not designed to survive a fire and will likely fail during a fire. This type of event can cause the emergency circuits to fail. Therefore, the normal and emergency circuits shall not share the same raceway.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 22 15:32:31 EDT 2020

Committee: FKT-AAA



Public Input No. 96-NFPA 130-2020 [Section No. 8.4.1]

8.4.1*

The test procedures and minimum performance for materials and assemblies shall be as detailed in Table 8.4.1.

Table 8.4.1 Fire Test Procedures and Performance Criteria for Materials and Assemblies

Category	Function of Material	Test Method	Performance	
			Criteria	
Cushioning	All individual flexible cushioning materials used in seat cushions, mattresses, mattress pads, armrests, crash pads, and grab rail padding ^{a-e}	ASTM D3675	$I_s = 25$	
			ASTM E662, IMO FTP Annex 1:Part 2	$D_s (1.5) = 100$, Pass
				$D_s (4.0) = 175$
Fabrics	Seat upholstery, mattress ticking and covers, curtains, draperies, window shades, and woven seat cushion suspensions ^{a-c,f-h}	14 CFR 25, Appendix F, Part I (vertical test)	Flame time = 10 sec	Burn length = 6 in.
			ASTM E662, IMO FTP Annex 1:Part 2	$D_s (4.0) = 200$, Pass
Other vehicle components	Seat and mattress frames, wall and ceiling lining and panels, seat and toilet shrouds, toilet seats, trays and other tables, partitions, shelves, opaque windscreens, combustible signage, end caps, roof housings, articulation bellows, exterior shells, nonmetallic skirts, battery case material, and component boxes and covers ^{a,b,i-k}	ASTM E162	$I_s = 35$	
			ASTM E662, IMO FTP Annex 1:Part 2	$D_s (1.5) = 100$, Pass
				$D_s (4.0) = 200$
		Thermal and acoustical insulation ^{a,b}	ASTM E162	$I_s = 25$
			ASTM E662, IMO FTP Annex 1:Part 2	$D_s (4.0) = 100$, Pass
		HVAC ducting ^{a,b}	ASTM E162	$I_s = 25$
			ASTM E662, IMO FTP Annex 1:Part 2	$D_s (4.0) = 100$, Pass
		Floor covering ^{b,k,l}	ASTM E648	CRF = 5 kW/m ²
			ASTM E662, IMO FTP Annex	$D_s (1.5) = 100$
				Pass

^aSee 8.4.1.1.
^bSee 8.4.1.2.
^cSee 8.4.1.3.
^dSee 8.4.1.4.
^eSee 8.4.1.5.
^fSee 8.4.1.6.
^gSee 8.4.1.7.
^hSee 8.4.1.8.
ⁱSee 8.4.1.9.

^jSee 8.4.1.10.

^kSee 8.4.1.11.

^lSee 8.4.1.12.

^mSee 8.4.1.13.

ⁿSee 8.4.1.14.

^oSee 8.4.1.15.

^pSee 8.4.1.16.

^q See 8.4.1. 17

8.4.1.1 *

Materials tested for surface flammability shall not exhibit any flaming running or flaming dripping.

8.4.1.2

The ASTM E662 maximum test limits for smoke emission (specific optical density) shall be based on both the flaming and the nonflaming modes.

8.4.1.3*

Testing of a complete seat assembly (including cushions, fabric layers, and upholstery) according to ASTM E1537 using the pass/fail criteria of California Technical Bulletin 133 and testing of a complete mattress assembly (including foam and ticking) according to ASTM E1590 using the pass/fail criteria of California Technical Bulletin 129 shall be permitted in lieu of the test methods prescribed herein, provided the assembly component units remain unchanged or new (replacement) assembly components possess fire performance properties equivalent to those of the original components tested.

8.4.1.3.1

A fire hazard analysis shall also be conducted that considers the operating environment within which the seat or mattress assembly will be used in relation to the risk of vandalism, puncture, cutting, introduction of additional combustibles, or other acts that potentially expose the individual components of the assemblies to an ignition source.

8.4.1.3.2

The requirements of 8.4.1.5 through 8.4.1.8 shall be met.

8.4.1.4

Testing shall be performed without upholstery.

8.4.1.5

The surface flammability and smoke emission characteristics shall be demonstrated to be permanent after dynamic testing according to ASTM D3574, Test I₂ or Test I₃, both using Procedure B, except that the test samples shall be a minimum of 150 mm (6 in.) × 450 mm (18 in.) × the thickness used in end-use configuration, or multiples thereof. If Test I₃ is used, the size of the indentor described in Section 96.2 of ASTM D3574 shall be modified to accommodate the specified test specimen.

8.4.1.6

The surface flammability and smoke emission characteristics shall be demonstrated to be permanent by washing, if appropriate, in accordance with the manufacturer's recommended procedure. If a washing procedure is not provided by the manufacturer, the fabric shall be washed in accordance with ASTM E2061, Annex A1.

8.4.1.7

The surface flammability and smoke emission characteristics shall be demonstrated to be permanent by dry cleaning, if appropriate, according to ASTM D2724.

8.4.1.8

Materials that cannot be washed or drycleaned shall be so labeled and shall meet the applicable performance criteria after being cleaned as recommended by the manufacturer.

8.4.1.9

Combustible operational and safety signage shall not be required to meet flame spread or smoke emission requirements if the combustible mass of a single sign does not exceed 500 g (1.1 lb) and the aggregate area of combustible signage does not exceed 1 ft² per foot of car length.

8.4.1.10

Materials used to fabricate miscellaneous, discontinuous small parts (such as knobs, rollers, fasteners, clips, grommets, and small electrical parts) where the surface area of any individual small part is less than 100 cm² (16 in.²) in end use configuration and that will not contribute materially to fire growth in end use configuration shall comply with either 8.4.1.10.1 or 8.4.1.10.2.

8.4.1.10.1

The materials shall be exempt from flammability and smoke emission performance requirements, provided that an appropriate fire hazard analysis is conducted that addresses the location and quantity of the materials used and the vulnerability of the materials to ignition and contribution to flame spread.

8.4.1.10.2

The materials shall be tested in accordance with ASTM E1354, at an initial test heat flux of 50 kW/m² (4.4 Btu/sec-ft²) in the horizontal orientation with a retainer frame, and shall meet the performance criteria of a 180-second average heat release rate not exceeding 100 kW/m² (8.8 Btu/sec-ft²) and a test average smoke extinction area not exceeding 500 m²/kg (2441.2 ft²/lb).

8.4.1.11

Carpeting used as a wall or ceiling covering shall be tested according to ASTM E162 and ASTM E662 and shall meet the respective criteria of $I_s \leq 35$, $D_s (1.5) \leq 100$, and $D_s (4.0) \leq 200$. (See 8.4.1.1 and 8.4.1.2.)

8.4.1.12

If padding is used in the actual installation, floor covering shall be tested with padding in accordance with NFPA 253 or ASTM E648.

8.4.1.13

Penetrations (ducts, etc.) shall be designed against acting as passageways for fire and smoke, and representative penetrations of each type shall be included as part of test assemblies.

8.4.1.14*

See 8.5.1.

8.4.1.15*

Portions of the vehicle body that separate the major ignition source, energy sources, or sources of fuel load from vehicle interiors shall have fire resistance as determined by a fire hazard analysis acceptable to the authority having jurisdiction that addresses the location and quantity of the materials used, as well as vulnerability of the materials to ignition, flame spread, and smoke generation. These portions shall include equipment-carrying portions of a vehicle's roof and the interior structure separating the levels of a bi-level car but do not include a flooring assembly subject to Section 8.5. In those cases, the use of the ASTM E119 test procedure shall not be required.

8.4.1.16 Testing of Adhesives and Sealants.**8.4.1.16.1**

Adhesives and sealants shall be tested in accordance with both ASTM E162 and ASTM E662 as a composite system, including a substrate, as shown in 8.4.1.16.2 through 8.4.1.16.3, as appropriate.

8.4.1.16.2

In the absence of a specified assembly or system, or if the adhesive or sealant is used on several different assemblies or systems, adhesives and sealants intended for application to combustible base materials shall comply with 8.4.1.16.2.1 and 8.4.1.16.2.2.

8.4.1.16.2.1

The adhesive shall be applied to the smooth face of 6.4 mm (¼ in.) thick tempered hardboard, nominal density 800 kg/m³ to 960 kg/m³ (50 lb/ft³ to 60 lb/ft³), using recommended (or practical) application techniques and coverage rates.

8.4.1.16.2.2

Tests shall also be conducted on the hardboard alone, and these values shall be recorded as supplemental to the measured values for the composite specimen.

8.4.1.16.3

Adhesives and sealants intended for application to noncombustible substrate materials shall be applied to the smooth face of 6.4 mm (¼ in.) thick inorganic reinforced cement board, nominal density $1762 \text{ kg/m}^3 \pm 160 \text{ kg/m}^3$ ($110 \text{ lb/ft}^3 \pm 10 \text{ lb/ft}^3$), using recommended (or practical) application techniques and coverage rates.

Statement of Problem and Substantiation for Public Input

Table 8.4.1

For all materials in table that require ASTM E662 smoke emission testing, add toxicity testing requirement

Test Method: IMO FTP Annex 1:Part 2

Performance Requirement: Pass

Add note q : qSee 8.4.1.17

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 97-NFPA 130-2020 [New Section after 8.4.1.16.3]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi

Organization: Jensen Hughes

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 17:17:10 EDT 2020

Committee: FKT-AAA



Public Input No. 95-NFPA 130-2020 [Section No. 8.4.1 [Excluding any Sub-Sections]]

The test procedures and minimum performance for materials and assemblies shall be as detailed in Table 8.4.1.

Table 8.4.1 Fire Test Procedures and Performance Criteria for Materials and Assemblies

<u>Category</u>	<u>Function of Material</u>	<u>Test Method</u>	<u>Performance</u>		
			<u>Criteria</u>		
Cushioning	All individual flexible cushioning materials used in seat cushions, mattresses, mattress pads, armrests, crash pads, and grab rail padding ^{a-e}	ASTM D3675	$I_s = 25$		
			ASTM E662	D_s (1.5) = 100	
					D_s (4.0) = 175
Fabrics	Seat upholstery, mattress ticking and covers, curtains, draperies, window shades, and woven seat cushion suspensions ^{a-c,f-h}	14 CFR 25, Appendix F, Part I (vertical test)	Flame time = 10 sec		
				Burn length = 6 in.	
			ASTM E662	D_s (4.0) = 200	
Other vehicle components	Seat and mattress frames, wall and ceiling lining and panels, seat and toilet shrouds, toilet seats, trays and other tables, partitions, shelves, opaque windscreens, combustible signage, end caps, roof housings, articulation bellows, exterior shells, nonmetallic skirts, battery case material, and component boxes and covers ^{a,b,i-k}	ASTM E162	$I_s = 35$		
			ASTM E662	D_s (1.5) = 100	
					D_s (4.0) = 200
		ASTM E1354 @50KW/m ²	Maximum Average Rate of Heat Emission (MAHRE) < 90 kW/m ²		
	Thermal and acoustical insulation ^{a,b}	ASTM E162	$I_s = 25$		
				ASTM E662	D_s (4.0) = - 100
		ASTM E1354 @50KW/m ²	Maximum Average Rate of Heat Emission (MAHRE) < 90 kW/m ²		
	HVAC ducting ^{a,b}	ASTM E162	$I_s = 25$		
				ASTM E662	D_s (4.0) = - 100
		ASTM E1354 @50KW/m ²	Maximum Average Rate of Heat Emission		

<u>Category</u>	<u>Function of Material</u>	<u>Test Method</u>	<u>Performance</u>	
			<u>Criteria</u>	
			(MAHRE) < 90 kW/m ²	
	Floor covering ^{b,k,l}	ASTM E648	CRF = 5 kW/m ²	
			ASTM E662	D_s (1.5) = 100 D_s (4.0) = 200
		Light diffusers, windows, and transparent plastic windscreens ^{b,i}	ASTM E162	I_s = 100
			ASTM E662	D_s (1.5) = 100 D_s (4.0) = 200
		Adhesives and sealants ^{a,b,p}	ASTM E162	I_s = 35
			ASTM E662	D_s (1.5) = 100 D_s (4.0) = 200
Elastomers ^{a,b,i,j}	Window gaskets, door nosings, intercar diaphragms, seat cushion suspension diaphragms, and roof mats	ASTM C1166	Flame propagation = 100 mm (4 in.)	
			ASTM E662	D_s (1.5) = 100 D_s (4.0) = 200
Wire and cable	All	See 8.6.7.1.1.1 through 8.6.7.1.3.	See 8.6.7.1.1.1 through 8.6.7.1.3.	
Structural components ^m	Flooring, ⁿ other ^o	ASTM E119	Pass	

^aSee 8.4.1.1.^bSee 8.4.1.2.^cSee 8.4.1.3.^dSee 8.4.1.4.^eSee 8.4.1.5.

^fSee 8.4.1.6.

^gSee 8.4.1.7.

^hSee 8.4.1.8.

ⁱSee 8.4.1.9.

^jSee 8.4.1.10.

^kSee 8.4.1.11.

^lSee 8.4.1.12.

^mSee 8.4.1.13.

ⁿSee 8.4.1.14.

^oSee 8.4.1.15.

^pSee 8.4.1.16.

Statement of Problem and Substantiation for Public Input

Analysis performed for the Federal Railroad Administration has shown that the ASTM E162 flame spread index requirement does not screen out all materials that may exhibit accelerated flame spread and potentially flashover when exposed to a plausible fire inside a railcar. This heat release rate requirement was demonstrated to screen out materials that may cause flashover. In addition, the requirement is in line with the EN 45545-2 material flammability requirement for similar materials in HL1/HL2 categories. The ASTM E162 requirement should be kept to ensure no flaming droplets. Technical basis is described in Ref. [1].

[1] Luo, C., Kraft, S., DiDomizio, M., McKinnon, M., Hodges, J., Yazdani, S., and Lattimer, B., "Heat Release Rate Requirements for Railcar Interior Finish," Final Report, Department of Transportation, Federal Railroad Administration, 2018. DOT/FRA/ORD-19/39

Submitter Information Verification

Submitter Full Name: Anil Kapahi

Organization: Jensen Hughes

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 17:11:08 EDT 2020

Committee: FKT-AAA

**Public Input No. 72-NFPA 130-2020 [Section No. 8.4.1.12]****8.4.1.12**

~~If padding is used in the actual installation, floor-~~ The floor covering shall be tested as installed, with padding, if applicable, and adhesive, in accordance with NFPA 253 or ASTM E648.

Statement of Problem and Substantiation for Public Input

It has been found that both the padding and the adhesive can alter the critical radiant flux obtained from the ASTM E648 test and the ASTM standard explicitly states that "The test specimen shall be the floor-covering system" and that the "floor covering system" is "a single material, composite or assembly comprised of the floor covering and related installation components (adhesive, cushion, etc.), if any".

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 71-NFPA 130-2020 [Section No. 8.4.1.16]	

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler
Organization: GBH International
Street Address:
City:
State:
Zip:
Submittal Date: Fri Jun 26 15:00:33 EDT 2020
Committee: FKT-AAA

**Public Input No. 122-NFPA 130-2020 [Section No. 8.4.1.15]****8.4.1.15***

Portions of the vehicle body that separate the major ignition source, energy sources, or sources of fuel load from vehicle interiors shall have fire resistance as determined by a fire hazard analysis acceptable to the authority having jurisdiction that addresses the location and quantity of the materials used, as well as vulnerability of the materials to ignition, flame spread, and smoke generation. These portions shall include equipment-carrying portions of a vehicle's roof and the interior structure separating the levels of a bi-level car but do not include a flooring assembly subject to Section 8.5. In those cases, the use of the ASTM E119 or UL 263 test procedure shall not be required.

Statement of Problem and Substantiation for Public Input

Reason: ASTM E119 and UL 263 are used to determine fire resistance ratings of different assemblies. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire resistance ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 123-NFPA 130-2020 [Section No. 8.5.1.3]	
Public Input No. 125-NFPA 130-2020 [Section No. 12.4.4]	
Public Input No. 126-NFPA 130-2020 [Section No. 12.5]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 10:10:20 EDT 2020
Committee: FKT-AAA



Public Input No. 71-NFPA 130-2020 [Section No. 8.4.1.16]

8.4.1.16* Testing of Adhesives and Sealants.

8.4.1.16.1 –

Adhesives and sealants shall be tested in accordance with both ASTM E162 and ASTM E662 as a composite system, including a substrate, as shown in 8.4.1.16.2 through 8.4.1.16.3, as appropriate.

8.4.1.16.2 –

In the absence of a specified assembly or system, or if the adhesive or sealant is used on several different assemblies or systems, adhesives and sealants intended for application to combustible base materials shall comply with 8.4.1.16.2.1 and 8.4.1.16.2.2.

8.4.1.16.2.1 –

The adhesive shall be applied to

by applying the adhesive or sealant to the smooth face of 6.4 mm ($\frac{1}{4}$ in.) thick

tempered hardboard, nominal density 800 kg/m³ to 960 kg/m³ (50 lb/ft³ to 60 lb/ft³), using recommended (or practical) application techniques and coverage rates.

8.4.1.16.2.2 –

Tests shall also be conducted on the hardboard alone, and these values shall be recorded as supplemental to the measured values for the composite specimen.

8.4.1.16.3 –

Adhesives and sealants intended for application to noncombustible substrate materials shall be applied to the smooth face of 6.4 mm ($\frac{1}{4}$ in.) thick

inorganic reinforced cement board, nominal density 1762 kg/m³ $\pm$ 160 kg/m³ (110 lb/ft³ $\pm$ 10 lb/ft³), using recommended (or practical) application techniques and coverage rates.

Additional Proposed Changes

<u>File Name</u>	<u>Description</u>	<u>Approved</u>
ASTM_E662_data_on_adhesives_and_hardboard.pdf	ASTM E662 data on adhesives and hardboard	

Statement of Problem and Substantiation for Public Input

An input and comment were accepted at the previous edition of NFPA 130 (my mistake) to require testing of adhesives or sealants intended for use with combustible substrates by testing on a specific hardboard. This resulted in information being presented that identified problems with the testing procedure, as follows:

1. The thick tempered hardboard being identified for use (at least since the 1983 edition of the ASTM E662 test method), which had a nominal density 50 to 60 lb./ft³ and a thickness of 0.25 inches) appears no longer to be a reasonable substrate for two reasons: (a) because typical hardboard now (per ANSI/AHA A135.4 "Basic Hardboard", with a minimum density specification of 31 lb./ft³ and a thickness range of 0.21 to 0.265 inches) is more common and (b) because it no longer appears to be commercially available. Although the hardboard in the standard is within the parameters of the ANSI/AHA standard it is no longer typical, and may not even be available.
2. The hardboard referenced in the standard is not referenced in other standards that use the same chamber, albeit with a different burner): ASTM E1995, NFPA 270 and ISO 5659-2.
3. The NFPA 130 standard uses ASTM E662 in combination with either ASTM E162 (for most materials) or ASTM D3675 (for plastics), for flame spread. Neither ASTM E162 nor ASTM D3675 reference that type of hardboard.
4. ASTM E162 does reference "thick tempered hardboard" (without any clarification) for use with "opaque sheet materials up to $\frac{1}{8}$ -in. (1.6-mm) thickness, and liquid films such as paints, etc. intended for application to combustible base materials" but not for adhesives. ASTM E162 also states that the hardboard shall have a "mean flame spread index of 130 to 180", which indicates that this section has not been updated for many years, since the ASTM E162 standard does not determine flame spread index but a radiant panel index, so that clearly this section of ASTM E162 has been ignored for years.

5. NFPA 130 was revised for the 2020 edition to require the use of the thick tempered hardboard for testing adhesives in accordance with both ASTM E162 and ASTM E662. That was a mistake that is intended to be corrected by this public input. An informal survey of users of adhesives for trains and underground rail vehicles for smoke emission indicates that the actual testing of adhesives is done by applying them to a noncombustible substrate and not using a system.

6. An informal survey of some fire test labs indicates that none use the thick tempered hardboard for testing adhesives.

7. Much more important, tests conducted on two commercial adhesives a commercial hardboard fairly close to the one in the ASTM E662 standard showed that it produces such a large amount of smoke that the smoke generated by the adhesive itself is dwarfed by the smoke from the hardboard (a table is attached).

Consequently, the section on testing adhesives needs to be reworded as follows:

1. The specific thick tempered hardboard required needs to be eliminated and the requirement to test adhesives with any type of hardboard needs to be eliminated.

2. Adhesives should simply be tested on the cement board used in the ASTM E662 standard, which is the same board also used in ASTM E162 and ASTM E84.

3. In terms of smoke emission it is very likely that the adhesive will be a small contributor.

4. Adhesives or sealants should be tested as individual materials and not as composite systems because neither ASTM E662 nor ASTM E162 (or ASTM D3675) are fully suited to testing composite systems. Other fire test standards, such as ASTM E1354 would be more suitable for that.

The language is proposed to read as follows:

8.4.1.16* Testing of Adhesives and Sealants.

Adhesives and sealants shall be tested in accordance with both ASTM E162 and ASTM E662 by applying the adhesive or sealant to the smooth face of 6.4 mm (¼ in.) thick inorganic reinforced cement board, nominal density 1762 kg/m³ ± 160 kg/m³ (110 lb/ft³ ± 10 lb/ft³), using recommended (or practical) application techniques and coverage rates.

An annex note will be an added PI to explain that this reverts much of the 2002 edition.

This analysis brings into question whether other items in the table should clarify that adhesives need to be included and the clear product is floor coverings (carpets) and a parallel PI addresses that.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 72-NFPA 130-2020 [Section No. 8.4.1.12]	
Public Input No. 73-NFPA 130-2020 [New Section after A.8.4.1.15]	

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submittal Date: Fri Jun 26 14:47:19 EDT 2020

Committee: FKT-AAA



Public Input No. 97-NFPA 130-2020 [New Section after 8.4.1.16.3]

8.4.1.17

The toxicity testing shall be performed in accordance with IMO FTP Annex 1: Part 2 using an irradiance of 25 kW/m² with and without a pilot flame. Materials shall meet the concentration performance requirements in IMO FTP Annex1: Part2.

Statement of Problem and Substantiation for Public Input

The rail industry currently performs toxicity testing on rail car materials as part of many of its acquisition contracts, but there is no requirement currently in NFPA 130. The toxicity testing currently used in the acquisition contracts (BSS 7239 or SMP 800C) are industry standards. In the last cycle, it was stated that a standard developed by an independent standards organization was desired. The International Maritime Organization (IMO) toxicity test standard was selected after review of existing toxicity standards, performance requirements, and analysis of existing data in the literature.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 96-NFPA 130-2020 [Section No. 8.4.1]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 17:24:26 EDT 2020
Committee: FKT-AAA

**Public Input No. 92-NFPA 130-2020 [Section No. 8.5.1.1.1.1]**

8.5.1.1.1.1 ~~The size of the exposed portion of the floor assembly shall be~~

~~at least 3.7 m (12 ft) long by~~

~~large enough to represent the full vehicle structural flooring design but need not exceed 3.7 m (12 ft) long and the normal width of the vehicle floor.~~

Statement of Problem and Substantiation for Public Input

Many railcar designs contain longitudinally repetitious structure or localized structural details. As a result, the ability of the structural flooring assembly to perform as a barrier against undervehicle fires could potentially be tested using a small subset of the assembly. Such a subset can be tested if the fire endurance of the full vehicle can be determined from such a test. If such a subset cannot be identified, the exposed portion of the floor assembly need not exceed 3.7 m (12 ft) in the longitudinal direction. Structural elements of the vehicle not part of the floor assembly but contributing to the floor assembly strength, such as parts of the vehicle superstructure directly above the assembly, may be included in the test assembly.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 93-NFPA 130-2020 [Section No. 8.5.1.3.1.2]	
Public Input No. 94-NFPA 130-2020 [Section No. A.8.4.1.14]	
Public Input No. 99-NFPA 130-2020 [New Section after A.8.4.2]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 16:45:18 EDT 2020
Committee: FKT-AAA



Public Input No. 123-NFPA 130-2020 [Section No. 8.5.1.3]

8.5.1.3 Test Details.

Fire resistance testing on assemblies shall be conducted in accordance with ASTM E119 or [UL 263](#).

8.5.1.3.1

Test assemblies shall be representative of the vehicle construction and shall be tested in a configuration to demonstrate that a fire will not extend into the passenger and crew areas during the fire exposure duration.

8.5.1.3.1.1

Unexposed side thermocouples shall be installed in accordance with or ASTM E119 or [UL 263](#).

8.5.1.3.1.2

The support of the test sample shall be limited to the transverse ends of the test sample only.

8.5.1.3.1.3

The test assembly shall contain one of each type of penetration included in the assembly construction.

(A)

Penetrations shall be installed in the test assembly in accordance with Section 7 of ASTM E814 or [UL 1479](#).

(B)

In cases in which there are multiple sizes of the same type of penetration, the penetration determined to be the most likely to allow hot gas or flame passage shall be included in the assembly.

(C)

No temperatures shall be required to be measured at the penetrations.

8.5.1.3.2

The minimum fire exposure duration shall be the greatest of the following:

- (1)* Twice the maximum expected time period under normal circumstances for a vehicle to stop completely and safely from its maximum operating speed, plus the time necessary to evacuate a full load of passengers from the vehicle under approved conditions
- (2)* 15 minutes for automated guideway transit (AGT) vehicles and low floor vehicles, 30 minutes for all other passenger-carrying vehicles
- (3) 15 minutes for roof assemblies

8.5.1.3.3

During the entire fire exposure, the following parameters shall apply:

- (1) Transmission of heat through the assembly shall not be sufficient to raise the temperature on its unexposed surface more than 139°C (250°F) average and 181°C (325°F) single point.
- (2)* The assembly shall not permit the passage of flame or gases hot enough to ignite cotton waste on the unexposed surface of the assembly.
- (3) The assembly shall support the representative loading.

Statement of Problem and Substantiation for Public Input

ASTM E119 and UL 263 are used to determine fire resistance ratings of different assemblies. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire resistance ratings are required.

UL 1479 is equivalent to ASTM E814 for fire testing penetration fire stops. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire stop ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 122-NFPA 130-2020 [Section No. 8.4.1.15]	
Public Input No. 124-NFPA 130-2020 [Section No. 8.5.3.2]	
Public Input No. 125-NFPA 130-2020 [Section No. 12.4.4]	
Public Input No. 126-NFPA 130-2020 [Section No. 12.5]	

Submitter Information Verification

Submitter Full Name: Kelly Nicolello
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 10:12:10 EDT 2020
Committee: FKT-AAA

**Public Input No. 93-NFPA 130-2020 [Section No. 8.5.1.3.1.2]****8.5.1.3.1.2**

The
support of the
test
sample
assembly shall be
~~limited to the transverse ends of the test sample only~~
supported in a manner representative of the full vehicle design .

Statement of Problem and Substantiation for Public Input

Floor assemblies should be supported by the members carrying the primary loads away from the assembly to the vehicle wheel trucks. Many designs contain primary structural members that carry load across the longitudinal span between the wheel trucks. These members within the test assembly should serve as the primary support locations while tertiary structural members are left unsupported.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 92-NFPA 130-2020 [Section No. 8.5.1.1.1.1]	
Public Input No. 100-NFPA 130-2020 [New Section after A.8.4.2]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 16:48:08 EDT 2020
Committee: FKT-AAA



Public Input No. 124-NFPA 130-2020 [Section No. 8.5.3.2]

8.5.3.2

Penetrations and access panels located between the locker and the passenger and crew areas shall be tested in accordance with ASTM E814 or UL 1479 and shall have an F rating of 15 minutes.

8.5.3.2.1

The separation assembly shall not allow the passage of flame for the entire exposure duration.

Statement of Problem and Substantiation for Public Input

UL 1479 is equivalent to ASTM E814 for fire testing penetration fire stops. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire stop ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 123-NFPA 130-2020 [Section No. 8.5.1.3]	
Public Input No. 126-NFPA 130-2020 [Section No. 12.5]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 10:15:06 EDT 2020
Committee: FKT-AAA

**Public Input No. 76-NFPA 130-2020 [Section No. 8.6.7.1.1 [Excluding any Sub-Sections]**

]

All wires and cables shall ~~be resistant to the spread of fire and shall have reduced smoke emissions by complying with~~ comply with APTA PR-E-RP-009-98 and 8.6.7.1.1.1 or 8.6.7.1.1.2.

Statement of Problem and Substantiation for Public Input

APTA PR-E-RP-009-98 title is "Ampacities for Wire and Cable Used on Passenger Rolling Stock with Flame, Smoke, and Toxicity Considerations ". APTA revised PR-E-RP-009-98 in 2020 to the new title and added the wires types that are used on rail cars in North America. The changes to APTA include adding thin wall wire, high temperature wires and Communication cables. APTA specifies the Flame, Smoke and Toxicity for all wire used in North America and the reference for this compliance needs to be in NFPA 130 and as part of "NFPA 130 compliant cable".

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Sat Jun 27 17:15:28 EDT 2020

Committee: FKT-AAA

**Public Input No. 78-NFPA 130-2020 [Section No. 8.6.7.1.2]****8.6.7.1.2**

Low voltage power and control wires and cables (i.e., less than 100 V ac and 150 V dc) except of Communication and Data cables shall comply with 8.6.7.1.1 and either of the following:

- (1) The physical, mechanical, and electrical performance requirements of ICEA S-95-658/NEMA WC-70 or ICEA S-73-532/NEMA WC-57, as applicable
- (2) The physical, mechanical, and electrical performance requirements of ANSI/UL 44 for thermosetting insulation and ANSI/UL 83 for thermoplastic insulation as applicable

Statement of Problem and Substantiation for Public Input

The standards mentioned in section 8.6.7.1.2 do not apply to communication cables and an exception is needed. Car builders and authorities are requesting communication cables to comply with 8.6.7.1.2 which is not possible, these standards cover 600V and 2000V cables. Communication cables use thin insulation and jacket that do not comply with the thicknesses and performance of the standards listed in section 8.6.7.1.2. In addition, some communication cables use foam insulation that is not covered by these standards.

The titles of the standards,

ICEA S-95-658/NEMA WC-70 " POWER CABLES RATED 2000 VOLTS OR LESS FOR THE DISTRIBUTION OF ELECTRIC ENERGY"

ICEA S-73-532/NEMA WC-57 " Standard for Control, Thermocouple Extension, and Instrumentation Cables"

ANSI/UL 44 "Thermoset-Insulated Wires and Cables"

ANSI/UL 83 "Thermoplastic-Insulated Wires and Cables"

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Sat Jun 27 17:25:02 EDT 2020

Committee: FKT-AAA

**Public Input No. 79-NFPA 130-2020 [Section No. 8.6.7.1.3]****8.6.7.1.3***

Communication and data cables shall have stranded conductors only and comply with UL 444, 8.6.7.1.1 and ~~the~~ any other corresponding specifications.

Statement of Problem and Substantiation for Public Input

Stranded conductor perform better in vibration, torque and flexing applications than solid conductor. All the cables mentioned in 8.6.7.1.3 are available with stranded conductor. The physical, mechanical and electrical performances referenced in 8.6.7.1.2 do not apply to communication and data cable. The correct standard for data and communication cables is UL 444.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Sat Jun 27 17:33:10 EDT 2020

Committee: FKT-AAA

**Public Input No. 81-NFPA 130-2020 [Section No. 8.6.7.1.4]****8.6.7.1.4**

Wires and cables used for heat, smoke, or other detection system shall comply with 8.6.7.1.1 and one of the following:

- (1) Be capable of having 15-minute circuit integrity when tested in accordance with IEC 60331-11
- (2) ~~Demonstrate that, if circuit integrity is tested during the vertical flame test, a current continues operating for at least 5 minutes during the test~~
- (3) Have circuit integrity cable in accordance with *NFPA 70*

Statement of Problem and Substantiation for Public Input

The test protocol is not defined with regard to which vertical flame test, existing standards, voltage and wiring configuration. There is no standard for this test and no lab is equipped to perform the test.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Sat Jun 27 17:49:23 EDT 2020

Committee: FKT-AAA



Public Input No. 82-NFPA 130-2020 [Section No. 8.6.7.2]

8.6.7.2 Minimum Wire Size.

In no case shall ~~single-conductor wire (not part of multi-conductor cable)~~ smaller than the following sizes be used:

- ~~14 AWG (cross-section 2.1 mm^2) for wire pulled through conduits or wireways or installed exposed between enclosures~~
- ~~22 AWG (cross-section 0.33 mm^2) for all wires, including those used on electronic units, equipment within a rack, cards, card racks, and wire laid in wireways~~

Power and control cables 600V and 2000V

a) Single conductors pulled through conduits or wireways - AWG No. 16.

b) Multi-conductor cables -AWG No. 20.

c) All other wire, including that which is not pulled through wireways and conduits - AWG No. 16.

d) Wire within control compartments - AWG No. 20.

Instrumentation, Communication and Data cables

a) Ethernet cables for signal transmission for train backbone and equipment control - AWG No. 24.

b) Wire on and within electronic units, cards, and card racks - AWG No. 28.

Statement of Problem and Substantiation for Public Input

The new information in 8.6.7.2 is the common practice that is used in modern transit vehicles, It adds more options, is less restrictive and reflects current vehicle design.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submission Date: Sat Jun 27 17:51:40 EDT 2020

Committee: FKT-AAA

**Public Input No. 83-NFPA 130-2020 [Section No. 8.6.7.3.3]****8.6.7.3.3**

~~Conductors shall be derated for grouping and shall be derated for ambient temperature greater than the manufacturer's design value in accordance with criteria specified by the authority having jurisdiction. Selection of wire types, sizes and insulation ratings shall be based on current-carrying capacity, voltage drop, mechanical strength, temperature, and flexibility requirements in accordance with applicable AAR, ICEA, and APTA "Installation of Wire and Cable on Passenger Rolling Stock" (APTA PR-E-RP-002-98) and "Ampacities for Wire and Cable Used on Passenger Rolling Stock with Flame, Smoke and Toxicity Considerations" (APTA PR-E-RP-009-98).~~

Statement of Problem and Substantiation for Public Input

The current wording is not enforceable and is too generic. APTA PR-E-RP-009-98 and APTA RP-E-002-98 were recently revised, they have all the needed wire types, ampacities and temperature deratings information for cables that are installed on North America cars. This wording is common to most transit authority specifications.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani
Organization: RSCC Wire & Cable
Street Address:
City:
State:
Zip:
Submittal Date: Sat Jun 27 18:02:01 EDT 2020
Committee: FKT-AAA

**Public Input No. 52-NFPA 130-2020 [Section No. 8.6.9]****8.6.9 Battery Installation.**

Batteries and their associated circuitry shall be installed with the following requirements:

- (1) Battery charging systems shall be designed to prevent overcharging of the battery.
- (2) The battery shall be designed with an emergency cutoff system.
- (3) The battery installation area shall be provided with a heat, smoke, or other fire detection system as appropriate for the environment in which it will operate.
- (4) The battery installation area shall be separated from the car interior by the use of materials that are noncombustible, in accordance with ~~the requirements of ASTM E136~~, Section 4.6.
- (5) The battery installation area shall not use materials with hygroscopic properties.
- (6) The battery installation area shall be provided with sufficient diffusion and ventilation of the gases from the battery to prevent the accumulation of an explosive mixture.
- (7) Battery casing material shall comply with Table 8.4.1.

Statement of Problem and Substantiation for Public Input

consistency with other references within NFPA 130

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submittal Date: Thu Jun 18 17:54:24 EDT 2020

Committee: FKT-AAA

**Public Input No. 102-NFPA 130-2020 [New Section after 9.3]****TITLE OF NEW CONTENT**

Type your content here ... * 15. [Fires greater than the systems were designed to address](#)

Statement of Problem and Substantiation for Public Input

Accidental or intentional acts which bring hazardous materials, or a failure of the ventilation system, or operator error can result in the fire ventilations system being unable to manage the smoke resulting in passenger exposure to heat, toxic gases, and decreased visibility to find their way to safety. Adding this language ensures the emergency management planning process will be aware of this possibility and make plans. (See proposed annex)

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 23:37:54 EDT 2020

Committee: FKT-AAA

**Public Input No. 114-NFPA 130-2020 [New Section after 9.11.3]****TITLE OF NEW CONTENT**

Type your content here ... 9.11.2.1 Exercises and drills shall be conducted with new mutual aid participating agencies prior to opening of additional stations, or rail extensions where they might be called to respond.

Statement of Problem and Substantiation for Public Input

Although regulations require response agency participation prior to opening within their response area, there is no requirement for adjacent response agencies to receive training if the rail system is not within their boundaries. Adjacent or nearby response agencies may be called upon in a mutual aid agreement and need to be trained prior to this occurring.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 01:12:42 EDT 2020

Committee: FKT-AAA

**Public Input No. 33-NFPA 130-2019 [Section No. 10.1]****10.1* General.****10.1.1**

An emergency communication system shall be provided throughout fixed guideway transit and passenger rail systems in accordance with this chapter.

10.1.

2—

2

Stations shall be provided with emergency voice/ alarm system, in accordance with NFPA 72, where the occupant load exceeds 1,000 persons.

10.1. 3

Emergency voice/alarm communications systems (EVACS) shall be designed, installed, inspected, tested, and maintained in accordance with *NFPA 72*, except as modified herein.

10.1.3 4

The design of the emergency communications systems shall consider background noise levels within the system resulting from the operation of emergency systems during various types of incidents.

10.1.4 5

Where a mass notification system is provided, the system shall be designed, installed, inspected, tested, and maintained in accordance with *NFPA 72*, except as modified herein.

Statement of Problem and Substantiation for Public Input

This change clarifies NFPA 101 12.3.4.3.5 requirement for a voice alarm system to be provided for stations with 1,000 occupants or more.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submission Date: Wed Dec 04 10:50:03 EST 2019

Committee: FKT-AAA



Public Input No. 118-NFPA 130-2020 [Section No. 10.1.2]

10.1.2

~~Emergency voice/alarm communications~~ Emergency communications systems (EVACS ECS) shall be designed, installed, inspected, tested, and maintained in accordance with *NFPA 72*, except as modified herein.

10.1.2.1 Emergency voice messages, where required by the applicable building code or the system operator, are permitted to be integrated into the notification system signals via other systems (such as the public address system).

10.1.2.2 Where voice messages are required, these should be integrated which provides a means to silence the alarm signals while the voice instructions are being transmitted, and re-activates the alarm signals after a pre-determined period.

Statement of Problem and Substantiation for Public Input

The three design and installation issues that need to be addressed are:

1. Why is voice notification required; and
2. If the standard deems this is the appropriate measure, can this be through other systems such as the public address system.
3. Terminology needs avoid implication of a requirement in other jurisdictions.

The proposed changes are to address the following three design and installation issues:

1. Why is voice notification required;
2. If the standard deems this is the appropriate measure, this should be permitted through other systems such as the public address system; and
3. Terminology needs avoid implication of a requirement.

#1: The standard is not clear on the intent as to why a voice component is required for emergency notification for all station configurations. Whilst voice messages do assist in emergency announcements specifically in complex integrated structures, providing voice notification in an elevated open station where egress points can be clearly identified, and the risk of exposure is lower, would not warrant a voice component. Suitable notification can be achieved through horns and strobes. The determination of the minimum requirement should be by the local building code or the operator. If voice messages are deemed a requirement, this can be supplemented with the public address (which was addressed in the 2014 edition), and requirements in the standard should not imply this is through the fire alarm system. the standard should specify the functional requirement and leave the design engineer to provide that functionality based on the jurisdictional design and installation standards.

#2: The reference to NFPA 72 can be interpreted to imply (moreso in jurisdictions outside of the US) that this required through the fire alarm system. While NFPA 72 provides flexibility in how this may be achieved (such as allowing other systems to interface with the fire alarm system), other fire alarm design standards are not which could result in duplicate speaker systems. The requirements should not impede integration of other systems (such as use of the public address) to achieve the functionality of voice messages whilst still permitting compliance with the local building codes.

#3: Further, terminology stated in the standard such as “emergency voice communication system” are defined terms in other codes and standards which can result in duplicate fire alarm and public address speakers to meet a requirement that wasn’t intended to mean dual systems. In the 2014 edition the wording existed that permitted the use of the Public Address system.

The proposed changes are to re-introduce functional requirements that permit other system to provide voice capability, provides flexibility on how this determined, and limits the potential of dual systems being provided.

Submitter Information Verification

Submitter Full Name: Andrew Coles

Organization: Senez Consulting Ltd.

Street Address:**City:****State:****Zip:****Submittal Date:** Tue Jun 30 02:37:55 EDT 2020**Committee:** FKT-AAA

**Public Input No. 32-NFPA 130-2019 [Section No. 10.2.6]****10.2.6**

The OCC shall be located in an area separated from other occupancies by 2-hour fire resistance construction, or provided with dedicated fire seperated exit enclosures .

Statement of Problem and Substantiation for Public Input

This edit seeks clarification on this requirement for 2 hour separation of the OCC. An alternative is to provide a dedicated route to allow for evacuation of occupants within the OCC building.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 21 10:22:58 EST 2019

Committee: FKT-AAA

**Public Input No. 38-NFPA 130-2019 [Section No. 10.3.1]****10.3.1**

Enclosed stations and enclosed trainways shall be provided with a public radio enhancement system.

Statement of Problem and Substantiation for Public Input

This change clarifies that public safety radio enhancement system is only required in enclosed trainway, not open trainways.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Mon Dec 23 23:20:50 EST 2019

Committee: FKT-AAA



Public Input No. 34-NFPA 130-2019 [Section No. 10.4]

10.4* Two-Way Wired Emergency Services Communication Systems.

10.4.1

Enclosed stations and all trainways shall be provided with a two-way wired emergency services communication system.

10.4.2

The system shall have a telephone network of fixed telephone lines and handsets capable of communication with all stations, fire command centers, ancillary structures, station master offices, traction power stations and substations, control towers, ancillary rooms and spaces, and locations first responders access points along the trainway.

10.4.3

Two-way wired emergency communications system telephone handsets shall be provided at the following locations:

- (1) Fire command center, where provided
- (2) Operations control center
- (3) Traction power substations
- (4) Blue light station locations
- (5) First responder access points along the trainway
- (6) Ventilation control plant rooms
- (7) Ancillary rooms and spaces as determined by the authority having jurisdiction
- (8) Other locations along the trainway as determined by the authority having jurisdiction

10.4.4

Telephones along the trainway shall have distinctive signs, lights, or both for identification.

Statement of Problem and Substantiation for Public Input

This change clarifies the required location of two-way communication system. The current text is very wide and generic, requiring 2-way communication with power stations which are not under the control of the trainway authority.

The edit also clarifies that two-way communication is required at access points to the trainway.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submission Date: Wed Dec 04 10:58:39 EST 2019

Committee: FKT-AAA

**Public Input No. 39-NFPA 130-2019 [Section No. 10.4.1]****10.4.1**

~~Enclosed stations-~~ Stations and ~~all~~ trainways shall be provided with a two-way wired emergency services communication system.

Statement of Problem and Substantiation for Public Input

This proposed change clarifies that all trainway and stations shall be provided with two-way communication systems. The code already requires open trainways & enclosed stations to be provided with 2-way communications, hence the requirement should extend to open stations too.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Mon Dec 23 23:26:10 EST 2019

Committee: FKT-AAA

**Public Input No. 44-NFPA 130-2020 [Section No. 11.1.2]****11.1.2 Application.**

These systems include the following:

- (1) Train control (signaling systems) as described in 7.2.4 5, 8.9.2.3, and in this chapter
- (2) Emergency communication systems as described in 6.4.2, 8.9.2.1, 8.9.2.2, 9.8.4, and Section 9.9
- (3) Traction power systems as described in 6.4.2, 7.2.4, 9.13.4, and 9.13.5
- (4) Supervisory control and data acquisition (SCADA) systems as they apply to fire emergencies

Additional Proposed Changes

<u>File Name</u>	<u>Description</u>	<u>Approved</u>
Issued_TIA_130-20-2_Final.pdf	TIA Log No. 1475	

Statement of Problem and Substantiation for Public Input

NOTE: This public input originates from Tentative Interim Amendment No. 20-2 (Log 1475) issued by the Standards Council on Month/Day/Year and per the NFPA Regs., needs to be reconsidered by the Technical Committee for the next edition of the Document.

Substantiation: Section 11.1.2(1) has cross-referenced Section 7.2.4 incorrectly since the 2010 edition. The correct reference should be to Section 7.2.5.

Emergency Nature: The Standard contains an error or an omission that was overlooked during the regular revision process.

Submitter Information Verification

Submitter Full Name: TC on FKT-AAA

Organization: NFPA

Street Address:

City:

State:

Zip:

Submission Date: Thu Mar 12 11:08:37 EDT 2020

Committee: FKT-AAA

**Public Input No. 91-NFPA 130-2020 [Section No. 11.1.2]****11.1.2 Application.**

These systems include the following:

- (1) Train control (signaling systems) as described in 7.2.5, 8.9.2.3, and in this chapter
- (2) Emergency communication systems as described in 6.4.2, 8.9.2.1, 8.9.2.2, 9.8.4, and Section 9.9
- (3) Traction power systems as described in 6.4.2, 7.2.4, 5 9.13.4, and 9.13.5
- (4) Supervisory control and data acquisition (SCADA) systems as they apply to fire emergencies

Statement of Problem and Substantiation for Public Input

Correction to incorrect Chapter 7 Section reference.

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund

Organization: JENSEN HUGHES Consulting Canad

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 29 16:14:35 EDT 2020

Committee: FKT-AAA



Public Input No. 131-NFPA 130-2020 [Section No. 12.1.1]

12.1.1 Scope.

This chapter ~~applies to~~ shall apply to wires and cables in all locations except in those vehicles addressed in Chapter 8.

Statement of Problem and Substantiation for Public Input

Clerical edit

Submitter Information Verification

Submitter Full Name: Andrew Coles

Organization: Senez Consulting Ltd.

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 12:10:42 EDT 2020

Committee: FKT-AAA



Public Input No. 35-NFPA 130-2019 [Section No. 12.1.2]

12.1.2

All wiring materials and installations other than for traction power shall conform to the requirements of *NFPA 70* except as modified herein. Where wiring is being used for both normal power and traction power, the wiring shall meet with with the requirements of this chapter.

Statement of Problem and Substantiation for Public Input

This change clarifies where the same cable(s) are being used for both normal power and traction power, the requirements of this chapter shall be applied.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Wed Dec 04 11:12:16 EST 2019

Committee: FKT-AAA

**Public Input No. 134-NFPA 130-2020 [Sections 12.1.2, 12.1.3]****Sections 12.1.2, 12.1.3****12.1.2**

All wiring materials and installations other than for traction power shall conform to the requirements of *NFPA 70* except as modified herein.

12.1.3 –

~~Traction power cables shall be listed and comply with the following:~~

- ~~(1) All relevant requirements for the environment in which they are to be used, including, but not limited to, being rated for not less than 90°C (194°F) and for wet locations~~
- ~~(2) The flame spread and smoke release requirements of Section 12.2~~

Statement of Problem and Substantiation for Public Input

This was added in the 2020 that should have been consolidated into 12.3. 12.1.2 states the requirement for installation, however, the requirements in 12.1.3 are a functional requirement for installation in wet environments that are already addressed in 12.3. This is addressed by edits to 12.3

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 135-NFPA 130-2020 [Section No. 12.3.1]	

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 12:37:26 EDT 2020
Committee: FKT-AAA

**Public Input No. 58-NFPA 130-2020 [Section No. 12.2]****12.2 Flame Spread and Smoke Release.****12.2.1**

All wires and cables used in enclosed stations and trainways, including traction power cables, shall be listed as being resistant to the spread of fire and shall have reduced smoke emissions, by complying with one of the following:

- (1) * All wires and cables shall comply with the requirements for char height [<1.5 m (5 ft) when measured from the lower edge of the burner face], total smoke released in 20 min [<150 m² (1615 ft²)], and peak smoke release rate [<0.40 m²/sec (4.3 ft²/sec)] when tested to the FT4/IEEE 1202 exposure of ANSI/UL 1685 or UL 2556 .
- (2) Wires and cables listed as having adequate fire-resistant and low-smoke-producing characteristics, by having a flame travel distance that does not exceed 1.5 m (5 ft) and generating a maximum peak optical density of smoke of 0.50 and a maximum average optical density of smoke of 0.15 when tested in accordance with NFPA 262, shall be permitted for use instead of the wires and cables specified in item (1).

Statement of Problem and Substantiation for Public Input

1202 was omitted as a typo from 2020 version. UL 1685 and UL 2556 are the same UL flame test FT4/IEEE 1202. UL standards reference UL 1685 or UL 2556. Example: UL 44 standard specify UL 2556.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani
Organization: RSCC Wire & Cable
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 22 15:04:05 EDT 2020
Committee: FKT-AAA



Public Input No. 139-NFPA 130-2020 [Section No. 12.2.1]

12.2.1

All ~~Except as permitted in 12.2.2, all~~ wires and cables used in ~~enclosed~~ stations and trainways, including traction power cables, shall be listed as ~~being resistant to the spread of fire and shall have reduced smoke emissions, by~~ complying with one of the following:

- (1)* ~~All wires and cables shall comply with the requirements for char height [~~<*~~Exhibit a char height less than 1.5 m (5 ft) when measured from the lower edge of the burner face], total smoke released in 20 min [less than <150 m² (1615 ft²)] , and peak smoke release rate [less than <0.40 m²/sec (4.3 ft²/sec)] when tested~~ when tested in accordance with ANSI/UL 1685 to the FT4/IEEE exposure of ANSI/UL 1685.

~~Wires and cables listed as having adequate fire resistant and low smoke-producing characteristics, by having a flame travel distance that~~

- (2) ~~criteira.~~
- (3) ~~Exhibit a flame travel distance that does not exceed 1.5 m (5 ft) and generating a~~
- (4) ~~generate a maximum peak optical density of smoke of~~
- (5) ~~density of 0.50 and a maximum average optical density of smoke of 0.15 when tested in accordance with NFPA 262, shall be permitted for use instead of the wires and cables specified in item (1).~~

12.2.2 ~~The requirements of 12.2.1 are not applicable where wires and cables comply with one of the following:~~

- (1) ~~are protected in accordance with 12.4.4.(1) or (2).~~
- (2) ~~either enclosed in noncombustible conduit or enclosed non-combustible cable trays~~
- (3) ~~are located in open stations, open trainways or aboveground enclosed stations~~

Additional Proposed Changes

<u>File Name</u>	<u>Description</u>	<u>Approved</u>
chapter_12_information.pdf	Supporting information related to Chapter 12 requirements	

Statement of Problem and Substantiation for Public Input

Proposed changes to 12.2.1 are interrelated with changes to 12.4.4 and the new 12.2.2 to address minimum requirements of wires in cables in various configuration of stations and trainways. As noted in the attached additional information the requirements for wires in cables circa 2003 deviated from the original intent of the standard and application of flame and smoke performance began to be applied without consideration of the method it is installed. The key issues that should be considered are:

- What are the minimum design requirements that is been asked of the standard, in context to minimum building codes and standard requirements
- Cable exposure to the hazard and required performance, and
- Methods of protection/installation (for fire and mechanical damage)

The last two points are interrelated as the installation methods can provide the inherent exposure protection to the cable that would not require the char and low smoke performance requirements of 12.2.1. As such, installation methods need to be considered relative to the requirements for cable char and smoke performance.

The proposed changes are to address what are considered appropriate requirements for wires and cable performance based on the method of installation.

Similarly, application of the char and low smoke production in all enclosed applications may not be commensurate with the exposure hazard or the risk. As such, performance exemptions are provided that would align with minimum building code or standard requirements for a typical above ground assembly building where the risk is perceived to be lower than an underground environment.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 144-NFPA 130-2020 [Section No. 12.4.4]</u>	
<u>Public Input No. 145-NFPA 130-2020 [New Section after 12.4.4]</u>	

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 13:47:47 EDT 2020
Committee: FKT-AAA

**Public Input No. 57-NFPA 130-2020 [Section No. 12.3]****12.3 Temperature, Moisture, and Grounding Requirements.****12.3.1**

Wires and cables except for Fiber Optic communications cables shall comply with both of the following temperature and moisture resistance characteristics:

- (1) All insulations shall be a moisture- and heat-resistant type carrying a temperature rating of 90°C (194°F).
- (2) All ~~insulated conductors~~ wires and cables shall be listed and marked for wet locations.

12.3.2

Ground wires shall comply with the following:

- (1) Ground wires installed in a metallic raceway shall be insulated.
- (2) In enclosed stations and trainways, other ground wires shall be permitted to be bare.

Statement of Problem and Substantiation for Public Input

This exception should apply only to fiber optic cables. Fiber optic cables cannot have 90°C ratings. Fiber optic cables do not have wet listings. The fiber cladding buffer materials around the glass fiber core is not considered an insulation and therefore fiber optics should not be covered in 12.3.1. Communication cables with copper conductors are capable of complying with 12.3.1.

An insulated conductor assume to be only a single conductor cable, 12.3.1 handles single and multi-conductor cables and wire is the appropriate term. The wire should be clearly marked for wet rating because of the installation in a tunnel which is a wet location.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submission Date: Mon Jun 22 14:21:18 EDT 2020

Committee: FKT-AAA

**Public Input No. 135-NFPA 130-2020 [Section No. 12.3.1]****12.3.1**

~~Wires and cables except~~ Except for communications cables, wires and cables, including traction power cables, shall comply with both of the following temperature and moisture resistance characteristics:

- (1) All insulations shall be a moisture- and heat-resistant type carrying a temperature rating of 90°C (194°F).
- (2) All insulated conductors and cables shall be listed for wet locations.

Statement of Problem and Substantiation for Public Input

Refer to PI# 134 realated to consilidation function requirment for traction power for installation in wet locations and temperature requirements.

Related Public Inputs for This Document

<u>Related Input</u>
Public Input No. 134-NFPA 130-2020 [Sections <u>12.1.2, 12.1.3</u>]

<u>Relationship</u>
Remove traction power functioinal requirments to the existing 12.3

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 12:41:11 EDT 2020
Committee: FKT-AAA

**Public Input No. 59-NFPA 130-2020 [Section No. 12.4.3]****12.4.3**

Within the emergency ventilation air distribution system, the following wiring methods are acceptable:

- (1) Type MI cable with or without an overall protected nonmetallic covering complying with 12.4.1 and 12.4.2
- (2) Type MC cable employing a smooth or corrugated impervious metal sheath or MC cable with or without an overall nonmetallic covering complying with 12.4.1 and 12.4.2
- (3) Conductors in electrical metallic tubing, flexible metallic tubing, intermediate metal conduit, or rigid metal conduit all without an overall nonmetallic covering

Statement of Problem and Substantiation for Public Input

The option for MI and MC cables should read the same with or without an overall jacket.
Both MI and MC are impervious sheath and a jacket should be optional.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 22 15:14:02 EDT 2020

Committee: FKT-AAA



Public Input No. 145-NFPA 130-2020 [New Section after 12.4.4]

12.4.5 The circuits in Section 12.4.4(1) and (2) shall be protected for a period of not less than 1-hour when exposed to fire conditions corresponding to the time-temperature curve in ASTM E119.

12.4.6* Emergency power, emergency lighting, and emergency communications circuits shall be protected from physical damage

A.12.4.6 The intent is to provide physical protection of the circuits from incidental damage such as rodents or the scrubbing effects of the ventilation system

12.4.7* Branch circuits of emergency power, emergency lighting, and emergency communications circuits need not conform to 12.4.4 or 12.4.6.

A.12.4.7 Where connection of branch circuits to the main feeds are configured such that the loss of the device does not result in failure of the main feed then the branch circuit does not require protection. However, consideration of appropriate protection of the branch circuit connection to the main feed is necessary to prevent failure.

Statement of Problem and Substantiation for Public Input

The proposed changes in PI# 144 removes the reasons why the system is protected as this cluttered the requirement for the methods of protection. The proposed new sections are to re-introduce/clarify the performance criteria (duration and test regime) for those that are protected, the rational why emergency circuits require protection of physical damage, and that branch circuits if connected to a main distribution feed to not need to be protected if the design of the circuit and loss of the device permits the circuit to operate as intended.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 144-NFPA 130-2020 [Section No. 12.4.4]	
Public Input No. 139-NFPA 130-2020 [Section No. 12.2.1]	

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 15:16:34 EDT 2020
Committee: FKT-AAA



Public Input No. 125-NFPA 130-2020 [Section No. 12.4.4]

12.4.4

The emergency power, emergency lighting, and emergency communications circuits shall be protected from physical damage by system vehicles or other normal system operations and from fires in the system for at least 1 hour, but not less than the time of tenability, when exposed to fire conditions corresponding to the time-temperature curve in the ASTM E119 or UL 263 fire resistance test by any of the following:

- (1) Circuits are embedded in concrete or protected by a fire barrier system in accordance with UL 1724. The cables or conductors shall maintain functionality at the temperature within the embedded conduit or fire barrier system.
- (2) Circuits are routed outside the enclosed portion of the system.
- (3) There is diversity in system routing (such as separate redundant circuits or multiple circuits separated by a fire barrier with a fire resistance rating so that a single fire or emergency event will not lead to a failure of the system).
- (4) All circuits consist of listed fire-resistive cable systems with a fire resistance rating in accordance with Section 12.5.

Statement of Problem and Substantiation for Public Input

Reason: ASTM E119 and UL 263 are used to determine fire resistance ratings of different assemblies. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire resistance ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 122-NFPA 130-2020 [Section No. 8.4.1.15]	
Public Input No. 123-NFPA 130-2020 [Section No. 8.5.1.3]	
Public Input No. 126-NFPA 130-2020 [Section No. 12.5]	

Submitter Information Verification

Submitter Full Name: Kelly Nicolello
Organization: UL LLC
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 10:28:02 EDT 2020
Committee: FKT-AAA

**Public Input No. 128-NFPA 130-2020 [Section No. 12.4.4]****12.4.4**

The emergency power, emergency lighting, and emergency communications circuits shall be protected from physical damage by system vehicles or other normal system operations and from fires in the system for at least 1 hour, but not less than the time of tenability, ~~when exposed to fire conditions corresponding to the time-temperature curve in the ASTM E119 fire resistance test by any of the following :~~ One of the following methods shall be used to achieve the 1 hour fire protection when tested .

- (1) * Circuits are embedded in concrete or protected by a fire barrier system in accordance with UL 1724. The cables or conductors shall maintain functionality at the temperature within the embedded conduit or fire barrier system.
- (2) ~~Circuits are routed outside the enclosed portion of the system.~~
- (3) There is diversity in system routing (such as separate redundant circuits or multiple circuits separated by a listed or cercertified fire barrier with a fire resistance rating so that a single fire or emergency event will not lead to a failure of the system).
- (4) All circuits consist of listed fire-resistive cable systems with a fire resistance rating in accordance with Section 12.5.

Statement of Problem and Substantiation for Public Input

Change wording in 12.4.4 - The ASTM E119 time temperature curve is the test method and not the actual fire condition. This change separates the requirements from the test conditions.
Add an Annex note to 12.4.4 (1) - In 2018 the NFPA Research Foundation published a report "Fire Resistance of Concrete For Electrical Conductors". This would be very helpful information.
Delete 12.4.4 (2) - the requirements in 12.4.4 are for circuits that are run within the transit system i.e. the tunnel. How would you test a circuit to ASTM E119 if it is not exposed to the actual fire conditions.
Add a listing or certified requirement to 12.4.4 (3) - if a fire barrier or some other method is used to protect critical circuits it should be tested the same as a fire resistive cable and either have a certified report or be listed.

Submitter Information Verification

Submitter Full Name: James Conrad
Organization: RSCC Wire & Cable
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 10:59:22 EDT 2020
Committee: FKT-AAA



Public Input No. 144-NFPA 130-2020 [Section No. 12.4.4]

12.4.4

~~The Except as permitted in 12.4.7, the emergency power, emergency lighting, and emergency communications circuits shall be protected from physical damage by system vehicles or other normal system operations and from fires in the system for at least 1 hour, but not less than the time of tenability, when exposed to fire conditions corresponding to the time-temperature curve in the ASTM E119 fire resistance test by any of the following:~~

- ~~(1) Circuits are embedded in concrete or protected by a fire barrier system in accordance with UL 1724. The cables or conductors shall maintain functionality at the temperature within the embedded conduit or fire barrier system. _~~
- ~~(2) Circuits are routed through service rooms that are fire-separated from the station or trainway.~~
- ~~(3) Circuits are routed outside the enclosed portion of the system.~~
- ~~(4) There is diversity in system routing (such as separate redundant circuits or multiple circuits separated by a fire barrier with a fire resistance rating so that a *Circuit routing provides diversity such that a single fire or emergency event will not lead to a failure of the system) circuit .~~
- ~~(5) All circuits- Circuits consist of listed fire-resistive cable systems with a fire resistance rating in accordance with Section 12.5.~~

A.12.4.4.(4) Diversity in this case refers to provisions such as separate redundant circuits or multiple circuits separated by a fire barrier

Statement of Problem and Substantiation for Public Input

Refer to PI# 139 for additional rational.

Changes to 12.4.4 are to provide focus on the method of protection and installation, not the reason why. The reason for the protection is broken out as new Subsections for fire duration and mechanical protection. The rational for the reason why it is protected can be provided as an annex note.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 139-NFPA 130-2020 [Section No. 12.2.1]</u>	Proposed changes to support 12.2.2 changes
<u>Public Input No. 145-NFPA 130-2020 [New Section after 12.4.4]</u>	

Submitter Information Verification

Submitter Full Name: Andrew Coles
Organization: Senez Consulting Ltd.
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 15:02:18 EDT 2020
Committee: FKT-AAA



Public Input No. 126-NFPA 130-2020 [Section No. 12.5]

12.5 Fire-Resistive Cables.

12.5.1

Fire-resistive cables shall be certified or listed as having been tested to the normal (ASTM E119 or UL 263) time-temperature curve in accordance with ANSI/UL 2196.

12.5.2

The cables shall comply with the requirements for no less than a 1-hour fire resistance rating when tested in accordance with ANSI/ UL 2196.

12.5.3*

The cables and systems shall comply with the following:

- (1) Be tested as a complete system, in both the vertical and horizontal orientation, of conductors, cables, and raceways, as applicable
- (2) For fire-resistive cables intended for installation in a raceway, be tested in the type of raceway in which they are intended to be installed
- (3) Have installation instructions that describe the tested assembly, with only the components included in the tested assembly acceptable for installation

Statement of Problem and Substantiation for Public Input

ASTM E119 and UL 263 are used to determine fire resistance ratings of different assemblies. These standards are referenced throughout NFPA standards and codes such as NFPA 101 and NFPA 5000 wherever fire resistance ratings are required.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 47-NFPA 130-2020 [Section No. 2.3.9]	
Public Input No. 122-NFPA 130-2020 [Section No. 8.4.1.15]	
Public Input No. 123-NFPA 130-2020 [Section No. 8.5.1.3]	
Public Input No. 124-NFPA 130-2020 [Section No. 8.5.3.2]	
Public Input No. 125-NFPA 130-2020 [Section No. 12.4.4]	

Submitter Information Verification

Submitter Full Name: Kelly Nicoletto

Organization: UL LLC

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 30 10:30:55 EDT 2020

Committee: FKT-AAA



Public Input No. 136-NFPA 130-2020 [Sections 12.5.1, 12.5.2, 12.5.3]

Sections 12.5.1, 12.5.2, 12.5.3

12.5.1

Fire-resistive cables shall be certified or listed as having been tested to the ~~normal~~ (ASTM E119 (or similar)- time-temperature curve in accordance with ANSI/UL 2196.

~~12.5.2~~ –

The cables shall comply with the requirements for time-temperature curve for no less than a 1-hour fire resistance rating when tested in duration in accordance with ANSI/UL 2196.

12.5.3 2 *

The Fire resistive cables and systems shall comply with the following:

- (1) Be tested as a complete system, in both the vertical and horizontal orientation, of conductors, cables, and raceways, as applicable
- (2) ~~For fire~~ Fire -resistive cables intended for installation in a raceway, shall be tested in the type of raceway in which they are intended to be installed
- (3) ~~Have~~ Shall include installation instructions that describe the tested assembly, with only the components included in the tested assembly acceptable for installation

Statement of Problem and Substantiation for Public Input

12.5.2 is a redundant requirement and is consolidated into one requirement in 12.5.1. The term "normal" in reference to ASTM E119 is removed as that time temperature curve used for building material fire resistive compliance; stating normal is not required unless abnormal conditions are stated elsewhere. Specification of ASTM E119 is redundant, but has been retained for continuity. Clarification that "similar" time temperature curves are permissible as ULC S101 or ISO 834 are similar curves to avoid compliance verification issues. Clerical changes in the new 12.5.2 dot points provided

Submitter Information Verification

Submitter Full Name: Andrew Coles

Organization: Senez Consulting Ltd.

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 12:45:22 EDT 2020

Committee: FKT-AAA

**Public Input No. 56-NFPA 130-2020 [Section No. 12.5.3]****12.5.3***

The cables and systems shall comply with the following:

- (1) Be tested as a complete system and described in UL FHIT or ULC FHIT 7 , in both the vertical and horizontal orientation, of conductors, cables, splices and raceways, as applicable
- (2) For fire-resistive cables intended for installation in a raceway, be tested in the type of raceway in which they are intended to be installed
- (3) Have installation instructions that describe the tested assembly, with only the components included in the tested assembly acceptable for installation

Statement of Problem and Substantiation for Public Input

UL FHIT and ULC FHIT7 describe in detail the installation details. Splices are always part of a tunnel lighting wiring and should be part of the details in NFPA 130. The splices are also detailed in UL FHIT and ULC FHIT 7.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 22 14:15:15 EDT 2020

Committee: FKT-AAA

**Public Input No. 60-NFPA 130-2020 [Section No. 12.5.3]****12.5.3***

The Fire Resistive cables and systems shall comply with the following:

- (1) Be tested as a complete system ~~, in both the vertical and horizontal orientation, of conductors, cables, and raceways, as applicable~~ as described in UL 2196 including a minimum 1-hour fire resistive splice.
- (2) For fire-resistive cables intended for installation in a raceway, be tested in the type of raceway in which they are intended to be installed
- (3) Have installation instructions that describe the tested assembly, with only the components included in the tested assembly acceptable for installation

Statement of Problem and Substantiation for Public Input

Emergency lighting circuits are required to be protected from a fire within the system therefore fire resistive splices are needed to meet this requirement.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Mon Jun 22 15:16:53 EDT 2020

Committee: FKT-AAA



Public Input No. 104-NFPA 130-2020 [New Section after A.1.1.1]

TITLE OF NEW CONTENT

Type your content here ... A 9.3.15

Larger and faster fires could occur due to prohibited materials brought onto train, either accidentally or intentionally, or incorrect design fire size, or incorrect activation of systems by operators. Modern testing has demonstrated even modern trains can have fires greater than previously used for design fires. Tunnel operators and responders should be aware of this potential and plan to address this type of incident.

Passenger may not be aware of prohibitions on hazardous materials and may accidentally (or intentionally) bring material which can create fires larger and faster than system was designed for. For example a portable and easily available container of gasoline could induce a flashover i.e. faster than the planned fire growth rate, thereby severely limiting passenger ability to safely evacuate and causing ignition of carried on fire loads. For tunnels shared with freight trains, consideration may be made to limited shared use of tunnels where credible arson threats have been made against rail agencies. Note this section should not drive changes in system designs, but ensure rail agencies and responders are aware of the potential and plan for this occurrence.

Statement of Problem and Substantiation for Public Input

Emergency management planning may not be aware of the potential for fires to occur larger than the design fire. Unintentional or illegal acts could bring on materials, such as gasoline, which could result in a larger and faster growing fire. In addition, operator delay or failure to activate the systems might result in a larger fire than ventilation was designed to handle. This language alerts emergency planners to this possibility.

Submitter Information Verification

Submitter Full Name: Gary English
Organization: Underground Command And Safety
Affiliation: NFPA 130 technical committee alternate
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 23:52:03 EDT 2020
Committee: FKT-AAA



Public Input No. 166-NFPA 130-2020 [Section No. A.1.1.3(6)]

A.1.1.3(6) 3.XX

A shelter stop is a location along a fixed guideway transit or passenger rail system refers to a place for the loading and unloading of passengers that is located in a public way and is designed for unrestricted movement of passengers. A shelter stop can have a cover but from a light rail vehicle that is either at or slightly raised above grade. A stop may include a sheltered area but is not fully enclosed and has no walls or barriers that would significantly restrict passenger movement to and from the loading and unloading area .

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to address application of NFPA 130 to Passenger Rail and Light Rail Transit Systems. Existing requirements do not adequately address differences in those systems from typical rapid transit systems relative to fire-life safety hazards. Refer to related proposed revisions to 1.1.3, new definition for "stop", new annex language associated with the definition for "station", proposed new sections 5.6 and 5.7, and proposed new sections 6.6 and 6.7.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]	
Public Input No. 164-NFPA 130-2020 [Section No. 1.1.3]	
Public Input No. 165-NFPA 130-2020 [New Section after 3.3]	
Public Input No. 167-NFPA 130-2020 [Section No. 3.3.57]	
Public Input No. 168-NFPA 130-2020 [Section No. 5.1.1]	
Public Input No. 169-NFPA 130-2020 [Section No. 6.1.1]	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 18:10:35 EDT 2020
Committee: FKT-AAA

**Public Input No. 11-NFPA 130-2019 [Section No. A.5.2.1.4]****A.5.2.1.4**

See A.6.3.5.9.

A.5.2.2.2.

Reference to NFPA 5000 Chapter 7 for height and area limitations should be used to confirm construction type.

Statement of Problem and Substantiation for Public Input

The inclusion of this appendix material refers to used to NFPA 5000 to confirm height and area. NFPA 220 does not contain this height and area table.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:

State:

Zip:

Submittal Date: Thu Nov 07 11:41:36 EST 2019

Committee: FKT-AAA

**Public Input No. 54-NFPA 130-2020 [Section No. A.5.2.7.2]****A.5.2.7.2 —**

Rubbish containers that are used in the station on a temporary basis (e.g., during cleaning operations) should be manufactured of noncombustible materials or of materials that comply with a peak heat release rate not exceeding 300 kW/m^2 ($26.4 \text{ Btu/ft}^2 \cdot \text{sec}$) when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m^2 ($4.4 \text{ Btu/ft}^2 \cdot \text{sec}$), in the horizontal orientation.

Statement of Problem and Substantiation for Public Input

PI 53 converts this section into a requirements and thus this annex material becomes superfluous.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 53-NFPA 130-2020 [Section No. 5.2.7.2]</u>	

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler
Organization: GBH International
Street Address:
City:
State:
Zip:
Submittal Date: Thu Jun 18 18:02:03 EDT 2020
Committee: FKT-AAA

**Public Input No. 146-NFPA 130-2020 [Section No. A.5.3.1]****A.5.3.1**

Where codes other than NFPA 101 are in effect, reference to NFPA 101 can be used as an Alternative Method to the lawful prescriptions in the adopted building code. replaced by reference to relevant requirements in the locally applicable building code.

Statement of Problem and Substantiation for Public Input

Problem is: with this advice we advocate breaking sovereign law... for the not too veiled intent of advancing its... Change is inevitable. Changing some nation's sovereign building code to NFPA 5000 may be possible. But for a process that claims inclusion and consensus, then let us at the NFPA start the change from an honest basis. Begin with the law, move to equivalencies and Alternative Methods after recognizing the baseline. This is international standard of practice, and law. Imagine how a designer in New York would feel if a crack team of London Tube exit engineers came over with their best practices manual, and in their design guide, they said that, local New York designer might consider substituting their local Building Code prescriptions for LU best practices, if they felt the need. The author of the book "Nudge" received a Nobel for a reason. The default condition is important because so few "think" to take alternatives. The default, baseline condition should be proper and justified, in this case on political truth, we we can not rest upon the laws of Mother Nature and absolute truth.

Submitter Information Verification

Submitter Full Name: Scot Deal
Organization: Excelsior Fire Engineering
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 15:31:40 EDT 2020
Committee: FKT-AAA



Public Input No. 143-NFPA 130-2020 [Section No. A.5.3.2.5]

A.5.3.2.5

The determination of maximum occupant load at a platform often requires comparison of calculations based on different peak periods. For example, to determine the maximum peak period platform occupant load for stations serving predominantly commuter ridership, the calculations described in 5.3.2.5(1) through 5.3.2.5(7) can be computed based on both the a.m. and the p.m. peak ridership for each platform and then compared to determine the maximum platform occupant load.

The designers and Employers do few a favor when value engineering exit capacity after sinking billions into Metro systems. Designers can use clairvoyance to downsize occupancy and/or exit capacity based on ridership predictions 15 years into the future, or they can apply the logic of: 1) 'if we build it they will come', 2). urban populations are growing, 3). design need consider the increasing embrace sustainable transportation holds for all generations, 4). increasing costs of private transportation, and 5). increasing population. Thus ridership has a clear bias for increase with aging stations. While the locally adopted Building Code may not apply to deep underground stations, the locally adopted Building Code legally works in tandem with NFPA 130 on egress design of shallow, at-grade and elevated stations . The Building Codes literally have millions of building-years of proven performance with their occupancy load tables. The Building Code wisdom bases occupancy on floor capacity, not punditry of passenger density twenty years into the future. A conscientious Employer will design egress capacity based on what many cities find to be an eventuality, fully occupied, even crush-capacity platforms. This platform occupancy load is in place, when loaded train arrives.

Additional Proposed Changes

<u>File Name</u>	<u>Description</u>	<u>Approved</u>
toronto_subway_2015.jpg	platform occupancy is a judgment every responsible stakeholder should weigh in on	

Statement of Problem and Substantiation for Public Input

problem is pound-wise, penny foolish. We build Metro systems worth tens of billions of euros in 2020, and waste substantial fraction of these sunk costs by value engineering exit capacity to save millions. Millions of euros is a lot of money, and worthy of directing towards causes of merit. But in building safety, exit capacity is a top tier merit. Cut costs on a 2nd standpipe along a fixed-guideway. Cut costs on excessive fire pumps. Cut costs on 3-hour fire separations between rooms of the same occupancy. Cut costs on EXCESSIVE tunnel exit stair shafts But exit capacity on the platform is not an area to be looking to value engineer.

Submitter Information Verification

Submitter Full Name: Scot Deal
Organization: Excelsior Fire Engineering
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 14:54:00 EDT 2020
Committee: FKT-AAA



Public Input No. 172-NFPA 130-2020 [Section No. A.5.3.2.5(3)]

A.5.3.2.5(3)

For purposes of calculating simultaneous occupant loads on center platforms, the intent of 5.3.2.5(3) is that the service disruption factor be applied only in the direction that results in the highest platform occupant load for the peak periods. For side platform stations, it is necessary to evaluate service disruption for both peak periods at each platform, but for simultaneous station evacuation, the principles for center platforms would apply. ~~However, the potential for a service disruption in one direction to cause a service disruption in the other direction should also be considered.~~

Terminus stations require consideration of train operational procedures that may allow for additional trains to be stored during off peak periods to service peak demands, or alternating train arrivals to the different platform edges, and the compounding of missed inbound trains affecting outbound service should be evaluated for its credibility if these scenarios can be mitigated.

It is important that the passenger load and headway capture the potential buildup of passengers that might occur before an emergency event is recognized as requiring evacuation but recognizing that assumptions which exceed the systems service capacity may be remote occurrences that require multiple compounding events which are not credible. The determination of the appropriate accumulation factor should reflect system-specific characteristics such as the following:

- (1) The type of system (e.g., automated/driverless vs. manually driven)
- (2) The amount and type of surveillance
- (3) The distance between stations
- (4) Train headways

~~For systems with longer headways, a factor of two headways might be adequate to approximate accumulation and response time. For systems with very short headways, a fixed time (e.g., 5 minutes to 10 minutes) might be more appropriate to approximate the potential passenger buildup.~~

~~Consideration should also be given to whether the entraining and train loads should be subject to the same accumulation factor.~~

- (1) Service demand operational characteristics

Statement of Problem and Substantiation for Public Input

The proposed revisions are intended to provide further guidance on the application of the emergency occupant load calculation methodology for terminus stations and to raise awareness that system service capacity and operational measures require consideration in these specific circumstances. End of line stations (terminus) may/may not have unique circumstances that warrant a different approach to the platform occupant load calculations which are not addressed in the current language. The assumptions made should consider how the system is intended to operate and that the assumptions and results are not over inflating the occupant load, specifically for stations with low ridership.

Current language related to missed headways does not providing guidance on how the requirements should be applied and that providing ranges is too ambiguous for the end user. The proposal is to remove this language and to state a minimum requirement, 2 x headway. If further conservatism is required that is upon the user or operator. Alternatively, if this is to remain it is suggested the annex language is more detailed and as rational as to why more than two headways should be considered is provided.

Submitter Information Verification

Submitter Full Name: Andrew Coles

Organization: Senez Consulting Ltd.

Street Address:

City:**State:****Zip:****Submittal Date:** Tue Jun 30 21:59:52 EDT 2020**Committee:** FKT-AAA



Public Input No. 151-NFPA 130-2020 [Section No. A.5.3.3.7]

A.5.3.3.7

Where automated spreadsheet calculations or computer-based software programs are used, the egress analysis should include documentation detailing all input parameters and algorithm(s).

When requested by the plan reviewer, the design should release the input files which memorialize the boundary conditions in a manner not as opaque as prose. In matters of life safety, there is almost no conceivable explanation (either legal or ethical) for withholding baseline assumptions contained within engineering assumptions cast as simulation boundary conditions with input files.

Statement of Problem and Substantiation for Public Input

One major design firm has withheld input files and the engineering assumptions contained therein, from review for three years. This is not life safety, this is business impudence. Obviously the design firm would share liability with whomever reviewed their engineering assumptions. Would could motivate such behavior? Does might make right or do we right a wrong with the consensus process of fairness. Everyone makes mistakes. This note serves not to point fingers of blame, but to put an independent set of eyes on material directly linked to life safety.

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 16:02:03 EDT 2020

Committee: FKT-AAA

**Public Input No. 160-NFPA 130-2020 [Section No. A.5.4.4.1]****A.5.4.4.1**

Escalators constructed of combustibles should be protected with an approved automatic sprinkler or fire suppression system installed in the truss area and designed to control or extinguish a fire. Sprinkler protection is not required in station areas used for public circulation and in trainways. Fire protection for public circulation areas is provided by limitations on the permitted type of construction and on permitted interior finishes and furnishings. Protection in the event of a train fire in an enclosed station is provided by requirements for an emergency ventilation system. Refer also to A.4.2.1 regarding the potential for reconsideration of these requirements where sprinkler protection in addition to that specified in 5.4.4.1 is provided.

Statement of Problem and Substantiation for Public Input

Proposed revisions are necessary to clarify the intended provision of sprinkler protection in stations relative to the fire hazard. Refer also to related proposed revisions to Section 5.4.4.1.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 161-NFPA 130-2020 [Section No. 3.3.37]</u>	
<u>Public Input No. 156-NFPA 130-2020 [Sections 5.4.4.1, 5.4.4.2]</u>	
<u>Public Input No. 156-NFPA 130-2020 [Sections 5.4.4.1, 5.4.4.2]</u>	
<u>Public Input No. 161-NFPA 130-2020 [Section No. 3.3.37]</u>	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submittal Date: Tue Jun 30 16:59:25 EDT 2020
Committee: FKT-AAA




Public Input No. 27-NFPA 130-2019 [Section No. A.6.3.2.1]

A.6.3.2.1

Maintaining a clear space above the walking surface is important to ensure that projections do not encroach into the means of egress. The envelope created by the boundary limits defined by this paragraph is intended to change gradually and symmetrically from point to point. With respect to clearances to the vehicle, the measurements should be to the static vehicle envelope. (See Figure A.6.3.2.1.) This dimension does not address accessible means of egress within the trainway. Should this be required by the applicable local codes, the width should be increased based upon a hazard analysis.

Figure A.6.3.2.1 Unobstructed Clear Width for Trainway Walkway.



Statement of Problem and Substantiation for Public Input

This edit seeks to confirm that the dimension shown does not address accessible means of egress. Should this be required by the local applicable codes/ standards, the design should comply with the local standards.

Submitter Information Verification

Submitter Full Name: Daniel Ford

Organization: WSP Middle East

Street Address:

City:**State:****Zip:****Submittal Date:** Thu Nov 14 09:45:52 EST 2019**Committee:** FKT-AAA



Public Input No. 154-NFPA 130-2020 [Sections A.6.3.3.5, A.6.3.3.8]

Sections A.6.3.3.5, A.6.3.3.8

A.6.3.3.5

It is important that guards be configured so that they do not interfere with either the vehicle dynamic envelope or with egress from the train onto the walkway. For that reason, guards are not required on the trainway side of walkways, provided that the bottom of the trainway is closed by deck or grating so that persons could not fall through the bottom of the guideway. Small gaps in continuity of the guard--as may be required for expansion joints--may be considered acceptable provided the gaps do not exceed the dimension that would be permitted for openings in guards by the locally applicable building code.

A.6.3.3.8—6

Handrails along horizontal walkways are intended for guidance and support and should therefore be continuous to the extent practicable, but gaps to facilitate access to emergency equipment and egress doors may be considered acceptable. It is important that handrails be configured so that they do not interfere with either the vehicle dynamic envelope or with egress from the train onto the walkway. For that reason, handrails are not required on the trainway side of walkways. Likewise, walkways located between trainways are not required to have handrails, provided they are a minimum width of 1120 mm (44 in.).

Statement of Problem and Substantiation for Public Input

Proposed revisions to annex language are to more adequately address intended application for conditions that are commonly found in transit system trainways. Refer also to related proposed revisions in Chapter 6.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 153-NFPA 130-2020 [Sections 6.3.3.5, 6.3.3.6, 6.3.3.7, 6.3.3.8, 6.3.3.9]	
Public Input No. 153-NFPA 130-2020 [Sections 6.3.3.5, 6.3.3.6, 6.3.3.7, 6.3.3.8, 6.3.3.9]	

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund
Organization: JENSEN HUGHES Consulting Canad
Street Address:
City:
State:
Zip:
Submission Date: Tue Jun 30 16:20:46 EDT 2020
Committee: FKT-AAA

**Public Input No. 94-NFPA 130-2020 [Section No. A.8.4.1.14]****A.8.4.1.14**

Only- A minimum of one specimen need be tested provided that the minimum fire endurance of the full vehicle can be determined . A proportional reduction can be made in the dimensions of the specimen, provided the specimen represents a true test of the ability of the structural flooring assembly to perform as a barrier against undervehicle fires.

Statement of Problem and Substantiation for Public Input

Rather than stating only one specimen need be tested, a statement should be added that a minimum of one specimen need be tested provided that the minimum fire endurance of the full vehicle can be determined.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 92-NFPA 130-2020 [Section No. 8.5.1.1.1.1]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 16:50:25 EDT 2020
Committee: FKT-AAA



Public Input No. 73-NFPA 130-2020 [New Section after A.8.4.1.15]

A.8.4.1.16

The 2020 edition of NFPA 130 required adhesives and sealants tested to ASTM E162 or to ASTM E662 and intended for application on a generic combustible substrate to be tested on a dense hardboard. Subsequent investigation indicated that such hardboard produced copious amount of smoke and that the effect of the adhesive or sealant would not be able to be identified. This requirement was deleted for the 2023 edition.

Statement of Problem and Substantiation for Public Input

Explanation for the revised section 8.4.1.16.

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 71-NFPA 130-2020 [Section No. 8.4.1.16]	

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler
Organization: GBH International
Street Address:
City:
State:
Zip:
Submittal Date: Fri Jun 26 15:12:15 EDT 2020
Committee: FKT-AAA



Public Input No. 100-NFPA 130-2020 [New Section after A.8.4.2]

A.8.5.1.3.1.2

Floor assemblies should be supported by the members carrying the primary loads away from the assembly to the vehicle wheel trucks. Many designs contain primary structural members that carry load across the longitudinal span between the wheel trucks. These members within the test assembly should serve as the primary support locations while tertiary structural members are left unsupported.

Statement of Problem and Substantiation for Public Input

Annex material to section 8.5.1.3.1.2

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 93-NFPA 130-2020 [Section No. 8.5.1.3.1.2]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 18:00:39 EDT 2020
Committee: FKT-AAA

**Public Input No. 99-NFPA 130-2020 [New Section after A.8.4.2]****A.8.5.1.1.1.1**

Many railcar designs contain longitudinally repetitious structure or localized structural details. As a result, the ability of the structural flooring assembly to perform as a barrier against undervehicle fires could potentially be tested using a small subset of the assembly. Such a subset can be tested if the fire endurance of the full vehicle can be determined from such a test. If such a subset cannot be identified, the exposed portion of the floor assembly need not exceed 3.7 m (12 ft) in the longitudinal direction. Structural elements of the vehicle not part of the floor assembly but contributing to the floor assembly strength, such as parts of the vehicle superstructure directly above the assembly, may be included in the test assembly.

Statement of Problem and Substantiation for Public Input

Annex material to section 8.5.1.1.1.1

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 92-NFPA 130-2020 [Section No. 8.5.1.1.1.1]	

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 17:28:48 EDT 2020
Committee: FKT-AAA



Public Input No. 65-NFPA 130-2020 [New Section after A.8.5.1.3.3(2)]

A.8.5.2.3

Design features may include an automatic fire detection system to control the vehicle ventilation and to activate an on-board suppression system

Statement of Problem and Substantiation for Public Input

The explanation is intended to help those that are not familiar with capabilities of automatic fire detection and on-board fire suppression systems

Submitter Information Verification

Submitter Full Name: Jonathan Redding

Organization: FOGTEC Fire Protection

Street Address:

City:

State:

Zip:

Submittal Date: Fri Jun 26 08:01:12 EDT 2020

Committee: FKT-AAA

**Public Input No. 80-NFPA 130-2020 [Section No. A.8.6.7.1.3]****A.8.6.7.1.3**

The electrical properties of data and communication cables should comply with requirements for category cable or local electrical requirements. Different system authorities specify data and communication cables that have specific electrical requirement other than voltage. Some examples of designations for cables potentially used in rail transportation vehicles include CAT 5, CAT 5E, CAT 6, CAT 6A, CAT 7, MVB, WTB, CANBUS, and RS-485. Flexible conductor is better in vibrations, torque and flexibilty than a solid conductor.

Statement of Problem and Substantiation for Public Input

CAT 6A is available and should be included in the annex.

Flexible conductors on communication cables shall be used on rolling stock because of vibrations, torque and flexing applications. AAR RP-585 covers flexible conductor for 600V and 2000V cables but not for communication cables.

Submitter Information Verification

Submitter Full Name: Gilad Shoshani

Organization: RSCC Wire & Cable

Street Address:

City:

State:

Zip:

Submittal Date: Sat Jun 27 17:37:23 EDT 2020

Committee: FKT-AAA



Public Input No. 42-NFPA 130-2020 [New Section after A.12.5.3]

A.12.5 Fire-Resistive Cables

For clarification purposes, I recommend creating A12.5 as follows:

Fire resistive cables are intended for use to supply power to control panels, fans, dampers, etc during an emergency situation. However, within the damper scope of work, the dampers, actuators and position switches are rated to the max temperature of the ventilation equipment requirements (i.e. 250C for 1 hour). furthermore, it falls within the scope of the damper supplier to factory wire the actuators and position switches to a local junction box mounted on the damper for a single point connection for incoming electrical supply and monitoring wires. Within the damper boundary (between the junction box, actuators and position switches), a 2-hour fire rated cabling system is not required. However, a wiring system rated (or tested) to the same temperature requirements, or better, than the damper, actuator and position switches is required to meet.

Statement of Problem and Substantiation for Public Input

The problems is that many design engineers or municipalities are unsure if damper wiring should comply with the 2-hour fire rating. when discussing with NFPA, it sounds like the 2-hour fire rated cables were not intended to be included inside the damper boundary. This addition to the appendix A will help clarify that situation.

Submitter Information Verification

Submitter Full Name: William Lampkin

Organization: Greenheck Fan Corporation

Street Address:

City:

State:

Zip:

Submission Date: Mon Mar 02 11:07:18 EST 2020

Committee: FKT-AAA

**Public Input No. 41-NFPA 130-2020 [Section No. B.3.5.1]****B.3.5.1**

Air velocities in enclosed stations and trainways should be greater than or equal to 0.75 m/sec (150 fpm) in the path of egress up to an Exit or Point of Safety.

Statement of Problem and Substantiation for Public Input

This requirement could be applied to the non-incident tunnel which could be construed to already be a Point of Safety. Having this requirement imposes the need to having a minimum velocity in a location where it is not required. The additional words gives clarity that the minimum velocity requirement should only apply along the egress path.

Submitter Information Verification

Submitter Full Name: Ian Ong

Organization: Mott MacDonald

Affiliation: Santa Clara Valley Transportation Authority

Street Address:

City:

State:

Zip:

Submittal Date: Thu Jan 30 13:45:07 EST 2020

Committee: FKT-AAA



Public Input No. 66-NFPA 130-2020 [Section No. B.9.2.3]

B.9.2.3 Computational Fluid Dynamics.

Computational fluid dynamics modelling has been employed in some studies to estimate fire development. Computational analysis of fire development using material properties is complex, and the context of model parameter uncertainty and the limitations of the methodology that are employed should be fully understood and maintained within the evaluation of model results. The approaches that have been employed include a prescribed burning rate approach [13], [18], and [19], with model parameters for material burning characteristics derived from heat release testing with a cone calorimeter [35], and more advanced pyrolysis modelling approaches [20] and [21].

The ignition and potential fire development characteristics of modern transit materials have been further examined using a coupled CFD/pyrolysis model in conjunction with bench-scale and assembly-scale fire testing [20].

The following parameters are important considerations when conducting a CFD analysis of fire development:

- (1) Initiating fire size and characteristics
- (2) Fire characteristic of car interior materials
- (3) Layout of the car interiors, including seating layouts, orientations, and dimensions
- (4) Other fuel load, such as bags and luggage carried by passengers
- (5) Overall thermal transmission value for vehicle body
- (6) Openings and protectives, including windows and doors
- (7) Oxygen levels
- (8) Mechanical and natural ventilation interior and exterior to the vehicle
- (9) On-board fire suppression system

Statement of Problem and Substantiation for Public Input

An on-board fire suppression system can have a significant effect on the fire development and is therefore an important parameter for the analysis

Submitter Information Verification

Submitter Full Name: Jonathan Redding
Organization: FOGTEC Fire Protection
Street Address:
City:
State:
Zip:
Submittal Date: Fri Jun 26 08:05:50 EDT 2020
Committee: FKT-AAA

**Public Input No. 98-NFPA 130-2020 [New Section after B.9.2.4]****B.9.2.5 Reduced-Scale Vehicle Testing**

An alternative to full-scale railcar testing is reduced-scale testing where the test conditions have been scaled according to scaling laws. Preliminary work on this was performed in Refs. [1-4] using Froude scaling laws; however, the heat release rate was not preserved across all scales. Recently, these scaling laws were modified based on conserving the burning rate per unit area of the material and the opening factor to conserve compartment fire dynamics behavior [5]. Results were shown to scale fire dynamics from full-scale to one-quarter scale [5].

References

- [1] H. Ingason, "Model scale railcar fire tests," *Fire Saf. J.*, vol. 42, no. 4, pp. 271–282, 2007.
- [2] A. Lönnemark, J. Lindström, and Y. Z. Li, "Model-scale metro car fire tests," *Fire Technol. SP Rep. 201133*, p. 115, 2011.
- [3] Y. Z. Li and H. Ingason, "Correlations between different scales of metro carriage fire tests," *Fire Technol. SP Rep. 201313*, p. 46, 2013.
- [4] Y. Z. Li, H. Ingason, and A. Lönnemark, "Fire development in different scales of metro carriages," *Fire Saf. Sci. Elev. Int. Symp.*, pp. 302–315, 2014.
- [5] Yang, F., Hodges, J., Rippe, C., Kraft, S., and Lattimer, B., "Predicting Fully-Developed Railcar Fire Heat Release Rate," *Final Report, Department of Transportation, Federal Railroad Administration, 2019.*

Statement of Problem and Substantiation for Public Input

This section is being added to highlight that there is a more cost effective option to quantify the heat release rate of a railcar other than full-scale testing. This allows for the actual materials used in the railcar to be tested and is sufficiently small-scale that more than one test could be conducted to assess the impact of different parameters (e.g., incipient fire location, initial number of doors open, etc.) on the overall railcar heat release rate.

Submitter Information Verification

Submitter Full Name: Anil Kapahi
Organization: Jensen Hughes
Street Address:
City:
State:
Zip:
Submittal Date: Mon Jun 29 17:26:23 EDT 2020
Committee: FKT-AAA

**Public Input No. 171-NFPA 130-2020 [Section No. C.1]****C.1 Station Occupant Load.**

The station platform dimensions are a function of the length of trains served and the train load. Thus the length of a platform at an outlying station might be equal to those of central business district transit stations where the train loads are significantly higher. Consequently, the platform and station occupant loads are a function of the train load and the simultaneous entraining load. This concept differs from that of NFPA 101, in which the occupant load is determined by dividing the floor area by an occupant load factor assigned to that use. Applying the NFPA 101 approach to determine the station platform occupant load is inappropriate.

C.1.1 Calculating Occupant Load Ridership .

Projected ridership figures serve as the basis for determining transit system design. Per this standard, ~~the methodology used to determine ridership figures must also include~~ consider peak ridership figures for new transit systems and existing operating systems. ~~Events~~ , as well as events at stations such as civic centers, sports complexes, and convention centers that establish occupant loads not included in normal passenger loads ~~must also be included~~ . These ridership figures serve as the basis for calculating train and entraining loads and the station occupant load. The methodology used for determining passenger ridership figures can vary by transit system. ~~The use of statistical methods for determining~~ *calculated train loads* and *calculated entraining loads* ~~will provide a more accurate indication of the required means of egress facilities within a station.~~

C.1.2

-

C.1.2 Train Operations and Maximum Train Load

Train headways will have a significant effect on the outcome of the occupant load calculations. For example, for the same ridership input, assumed train service of 20 trains per hour (3 minute headways) versus 30 trains per hour (2 minute headways) may increase the calculated platform occupant load by 50%.

The maximum train capacity acts as a "capping" factor when occupant load calculations consider link loads based on ridership. Care should be taken to use a realistic maximum train load that considers number of seats as well as standing capacity based on achievable pedestrian density (where standing is permitted).

C.1.3 Sample Occupant Load Calculations

The methodology described herein is intended only as examples of how to determine platform and station occupant loads for different station configurations. Inputs such as surge factors and service delays should be carefully considered for each system application, keeping in mind that small changes in those inputs can have a significant effect on the calculations results. Likewise,

C.1.3.1 Centre Platform

C.1.3.2 Side Platform

C.1.3.3 Multi-line Station

C.2 Calculating Egress Capacity and Evacuation Time

C.2.1 Calculating Evacuation Time.

The total evacuation time is the sum of the walking travel time for the longest egress route plus the waiting times at the various circulation elements. The trainway can be considered as an auxiliary egress from the station under certain fire scenarios.

The waiting time at each of the various circulation elements is calculated as follows:

- (1) For the platform means of egress, by subtracting the walking travel time on the platform from the platform egress flow time
- (2) For each of the remaining circulation elements, by subtracting the maximum of all previous element flow times

The symbols used in the sample calculations in this annex represent the walking times, flow times, and waiting times as follows:

T = total walking travel time for the longest egress route

T_p = walking travel time on the platform

T_X = walking travel time for the Xth segment of the egress route

F_p = platform egress flow time

F_{fb} = fare barrier flow time

F_c = concourse egress flow time

F_N = flow time for any additional circulation element

$W_p = F_p - T_p$ = waiting time at platform points of egress

$W_{fb} = F_{fb} - F_p$ = waiting time at fare barriers

$W_c = F_c - \max(F_p \text{ or } F_{fb})$ = waiting time at concourse points of egress

$W_N = F_N - \max(F_c, F_{fb}, \text{ or } F_p)$ = waiting time at any additional circulation element


Note that the waiting time at any circulation element cannot be less than zero.

C. 1.3 2.2 Sample Egress Capacity and Evacuation Time Calculations

C.2.2.1 _ Center-Platform Station Sample Calculation. **Station**

The sample center-platform station is an elevated station with the platform above the concourse, which is at grade (see Figure C.1.3). The platform is 183 m (600 ft) long to accommodate the train length. The vertical distance from the platform to the concourse is 9.1 m (30 ft).

Figure C.1.3 Center Platform Station.



The sample station has one paid area separated from the outside by a fare array containing four electronic fare gates and one 1220 mm (48 in.) handicapped/service gate. In addition, two 1830 mm (72 in.) wide emergency exits are provided. Six open wells communicate between the platform and the concourse. Each well contains one stair or one escalator. Station ancillary spaces are located at the concourse level.

Elevators (not shown in Figure C.1.3) are provided for use by handicapped persons or service personnel. Open emergency stairs are provided at each end of the platform and discharge directly to grade through grille doors with panic hardware.

Escalators are nominal 1220 mm (48 in.) wide. Stairs regularly used by patrons are 1830 mm (72 in.) wide, and emergency stairs are 1220 mm (48 in.) wide. Gates to emergency stairs are 1220 mm (48 in.) wide.

The station occupant load is 2314 persons.

Table C.1.3 lists the data for the egress analysis of the sample center-platform station.

Table C.1.3 Sample Calculations — Center-Platform Station

Egress Element	mm	in.	p/mm-min	pim	-	p/min
<i>Platform to concourse (downward)</i>						
Stairs (4)	7320	288	0.0555	1.41	-	406
Escalators (2*)	1220	48	0.0555	1.41	-	68
Emergency stairs (2)	2440	96	0.0555	1.41	-	135
Escalator test: 8.67% (Not > 50%)				-	-	609
-	-	-	-	-	-	-
<i>Through fare barriers</i>						
Fare gates (4) (capacity = 50 per gate)					-	200
Service gates (1)	1 gate	1 gate	60 p/gate/min	60 p/gate/min	-	60
Emergency exit doors (2 × double doors)	3660	144	0.0819	2.08	-	300
					-	560
<i>Fare barriers to safe area (fare barriers discharge to outside)</i>						
Stairs	0	0	0.0555	1.41	-	0
Escalators	0	0	0.0555	1.41	-	0
Emergency stairs	0	0	0.0555	1.41	-	0
Escalator test: 0.00% (Not > 50%)				-	-	0
Walking Time for Longest Egress Route						
Route	m	ft	m/min	fpm	-	min
<i>Platform to safe area</i>						
On platform, T ₁	41.5	136	37.7	124	-	1.09
Platform to concourse, T ₂	9.1	30	14.6	48	-	0.62

<u>Egress Element</u>	<u>mm</u>	<u>in.</u>	<u>p/mm-min</u>	<u>pim</u>	<u>=</u>	<u>p/min</u>
On concourse, T_3	16.5	54	37.7	124	-	0.44
Concourse to grade, T_4	0	0	14.6	48	-	0
On grade to safe area, T_5	3.05	10	37.7	124	-	0.08
Total walking time, $T = T_1 + T_2 + T_3 + T_4 + T_5$				-	-	2.23

*One escalator discounted.

Test No. 1. Evacuate platform occupant load(s) from platform(s) in 4 minutes or less.

$$F_p \text{ (time to clear platform)} = \frac{\text{Platform occupant load}}{\text{Platform egress capacity}} \quad [\text{C.1.3a}]$$

$$F_p = \frac{2314}{609}$$

$$F_p = 3.80 \text{ minutes}$$

In Test No. 1, the time to clear the platform is found to be 3.80 minutes. This meets the requirement of 5.3.3.1.

Test No. 2. Evacuate platform occupant load from most remote point on platform to a point of safety in 6 minutes or less.

$$W_p \text{ (waiting time at platform points of egress)} = F_p - T_1$$

$$W_p = 3.80 - 1.09 = 2.71 \text{ minutes}$$

$$\text{Concourse occupant load} = \text{Platform occupant load} - (F_p \times \text{emergency stair capacity})$$

$$\text{Concourse occupant load} = 2314 - 513 = 1801 \text{ persons}$$

$$W_{fb} \text{ (waiting time at fare barriers)} = F_f - F_p$$

$$F_{fb} \text{ (fare barrier flow time)} = \frac{\text{Concourse occupant load}}{\text{Fare barrier egress capacity}} \quad [\text{C.1.3b}]$$

$$F_{fb} = \frac{1801}{560} = 3.22 \text{ minutes}$$

$$W_c = F_{fb} - F_p$$

$$W_{fb} = 3.22 - 3.80 = 0.000 \text{ minutes}$$

$$W_c \text{ (waiting time at concourse points of egress)} = [F_c - \max(F_{fb} \text{ or } F_p)]$$

$$F_c \text{ (concourse egress flow time)} = \frac{\text{Concourse occupant load}}{\text{Concourse egress capacity}} \quad [\text{C.1.3c}]$$

$$F_c = \frac{1801}{0} = 0.000 \text{ minutes}$$

$$W_c = F_c - \max(F_{fb} \text{ or } F_p)$$

$$W_c = 0.000 - 3.80 = 0.000 \text{ minutes}$$

$$\text{Total egress time} = T + W_p + W_{fb} + W_c$$

$$\text{Total egress time} = 2.23 + 2.71 + 0.000 + 0.000$$

$$\text{Total egress time} = 4.94 \text{ minutes}$$

In Test No. 2, the time to reach a point outside any enclosing structure is found to be 4.94 minutes. This meets the requirement of 5.3.3.2.


If the concourse of this station is considered to meet the point of safety definition by the authority having jurisdiction, the calculation for Test No. 2 would be modified. The time to reach a point of safety would

include the walking travel time from the remote point on the platform to the concourse only, plus the waiting time at the platform points of egress. The area of the concourse would have to be large enough to accommodate the concourse occupant load calculated in Test No. 2.

C.1 2 .4 2.2 Side-Platform Station Sample Calculation. Station

The sample side-platform station is an enclosed station with a concourse above the platform level but below grade. (See Figure C.1.4.) The platform is 183 m (600 ft) long to accommodate the train length. The vertical distance from grade to concourse is 8 m (26 ft). The concourse is 5.5 m (18 ft) above the platform.

Figure C Figure C .1.4 Side 2.2.2 Side -Platform Station.



The sample station has two entrances normally used by patrons, each containing one escalator and one stair. The entrances are covered at grade level to a point 3.05 m (10 ft) beyond the top of the stairs.

The concourse is divided into two free areas and one paid area separated by fare arrays. Each fare array contains 12 fare gates of the turnstile type and one swinging service gate, 1220 mm (48 in.) wide, equipped with panic hardware for use by handicapped persons and service personnel.

Three open wells, containing two stairs and one escalator, communicate between each platform and the concourse.

Elevators are provided from grade level to concourse and from the concourse to each platform for use by handicapped persons and service personnel. Station ancillary spaces are located at concourse level.

Enclosed emergency stairs that discharge directly to grade are provided at both ends of each platform. Escalators are nominal 1220 mm (48 in.) wide. Stairs regularly used by patrons are 1830 mm (72 in.) wide. Emergency stairs are 1220 mm (48 in.) wide. Doors to emergency stairs are 1220 mm (48 in.) wide.

The station occupant load is 1600 persons, 228 on the outbound platform and 1372 on the inbound platform.

Table C.1.4 lists the data for the egress analysis of the sample side-platform station.

Table C.1.4 Sample Calculations — Side-Platform Station

Egress Element	mm	in.	p/mm-min	pim	p/min
<i>Inbound platform to concourse (upward)</i>					
Stairs (2)	3660	144	0.0555	1.41	203
Escalators (1*)	1220	48	0.0555	1.41	68
Emergency stairs (2)	2440	96	0.0555	1.41	135
					406
Walking Time for Longest Egress Route	m	ft	m/min	fpm	min
<i>Inbound platform</i>					
On platform, T_1	50.3	165	37.7	124	1.33
Platform to concourse, T_2	5.5	18	14.6	48	0.38
On concourse, T_3	35.1	115	37.7	124	0.94
Concourse to grade, T_4	7.9	26	14.6	48	0.54
On grade to safe area, T_5	3.05	10	37.7	124	0.08
Total walking time, $T = T_1 + T_2 + T_3 + T_4 + T_5$					3.26
Element	mm	in.	p/mm-min	pim	p/min
<i>Outbound platform to concourse (upward)</i>					
Stairs (2)	3660	144	0.0555	1.41	203
Escalators (1*)	1220	48	0.0555	1.41	68
Emergency stairs (2)	2440	96	0.0555	1.41	135

<u>Egress Element</u>	<u>mm</u>	<u>in.</u>	<u>p/mm-min</u>	<u>pim</u>	<u>p/min</u>	
						- - - 406
Walking Time for Longest Egress Route	m	ft	m/min	fpm	min	
<i>Outbound platform</i>						
On platform, T_1	18.2	60	37.7	124	0.49	
Platform to concourse, T_2	5.5	18	14.6	48	0.38	
On concourse, T_3	39.6	130	37.7	124	1.05	
Concourse to grade, T_4	7.9	26	14.6	48	0.54	
On grade to safe area, T_5	3.05	10	37.7	124	0.08	
Total walking time, $T = T_1 + T_2 + T_3 + T_4 + T_5$				-	2.54	
-	-	-	-	-	-	
-	-	-	-	-	-	
Concourse:	-	-	-	-	-	
<i>Throughfare barriers</i>						
Turnstiles (12) capacity = 25 p/min				-	300	
Service gate (1)	1 gate	1 gate	60 p/gate/min	60 p/gate/min	60	
					-	- - - 360
<i>Fare barriers to safe areas</i>						
Stairs (2)	3660	72	0.0555	1.41	204	
Escalator (2*)	1220	48	0.0555	1.41	68	
					-	- - - 272

*One escalator discounted (See 5.3.6.)

The egress capacity from platform to concourse meets the criteria of 5.3.3.1 in Test No. 1, where the time to clear the platform is found to be 3.38 minutes for the inbound platform and 0.56 minute for the outbound platform.

In Test No. 2, the total egress time (i.e., the maximum egress time for the two paths examined) is found to be 5.85 minutes. This meets the criteria of 5.3.3.2.

Evacuate platform occupant load(s) from platform(s) in 4 minutes or less.

Inbound platform:

$$F_{p-i}(\text{time to clear platform}) = \frac{\text{Platform occupant load}}{\text{Platform egress capacity}}$$

$$F_{p-i} = \frac{1372}{406}$$

$$F_{p-i} = 3.38 \text{ minutes}$$
[C.1.4a]

Outbound platform:

$$F_{p-o}(\text{time to clear platform}) = \frac{\text{Platform occupant load}}{\text{Platform egress capacity}}$$

$$F_{p-o} = \frac{228}{406}$$

$$F_{p-o} = 0.56 \text{ minutes}$$
[C.1.4b]

F_p for inbound and outbound occupant loads satisfies the criterion of 4 minutes.

Test No. 2. Evacuate platform occupant load from most remote point on platform to a point of safety in 6 minutes or less.

Inbound platform:

$$W_{p-i} \text{ (waiting time at platform egress elements)} = F_{p-i} - T_{1p-i}$$

$$W_{p-i} = 3.38 - 1.33 = 2.05 \text{ minutes}$$

$$\text{Concourse occupant load} = \text{Platform occupant load} - (F_{p-i} \times \text{emergency stair capacity})$$

$$\text{Concourse occupant load} = 1372 - 456 = 916 \text{ persons}$$

Outbound platform:

$$W_{p-o} \text{ (waiting time at platform egress elements)} = F_{p-o} - T_{1p-o}$$

$$W_{p-o} = 0.56 - 0.49 = 0.07 \text{ minute}$$

$$\text{Concourse occupant load} = \text{Platform occupant load} - (F_{p-o} \times \text{emergency stair capacity})$$

$$\text{Concourse occupant load} = 228 - 76 = 152 \text{ persons}$$

$$\text{Total concourse occupant load} = \text{Concourse load (inbound)} + \text{Concourse load (outbound)}$$

$$\text{Total concourse occupant load} = 916 - 152 = 1068 \text{ persons}$$

Concourse:

$$W_{fb} \text{ (waiting time at fare barriers)}$$

$$F_{fb} = \frac{\text{Concourse occupant load}}{\text{Fare barrier egress capacity}} \quad [\text{C.1.4c}]$$

$$F_{fb} = \frac{1065}{360}$$

$$F_{fb} = 2.96 \text{ minutes}$$

$$W_{fb} = F_{fb} - \max(F_{p-i} \text{ or } F_{p-o})$$

$$W_{fb} = 2.96 - 3.38 = 0.00 \text{ minutes}$$

$$W_C \text{ (waiting time at concourse egress elements)}$$

$$F_c \text{ (concourse flow time)} = \frac{\text{Concourse occupant load}}{\text{Concourse egress capacity}} \quad [\text{C.1.4d}]$$

$$F_c = \frac{1065}{272}$$

$$F_C = 3.92 \text{ minutes}$$

$$W_C = F_C - \max(F_{fb} \text{ or } F_{p-i} \text{ or } F_{p-o})$$

$$W_C = 3.92 - 3.38 = 0.54 \text{ minutes}$$

$$F_c \text{ (concourse flow time)} = \frac{\text{Concourse occupant load}}{\text{Concourse egress capacity}} \quad [\text{C.1.4e}]$$

$$F_c = \frac{533}{156}$$

$$\text{Total egress time} = \max(T_{p-i} + W_{p-i} \text{ or } T_{p-o} + W_{p-o}) + W_{fb} + W_C$$

$$\text{Total} = 3.26 + 2.05 + 0.00 + 0.54$$

$$\text{Total} = 5.85 \text{ minutes}$$

C. 1.5—2.2.3 Multilevel-Platform Stations.

The procedures for calculating egress times for multilevel platform stations are similar to the sample calculations in C.1.3 and C.1.4. The changes in the egress calculations are for multilevel-platform stations primarily a function of the concurrent occupant load determinations for the two platform levels.

The step-by-step procedure relating to the occupant load calculations generally is recommended as follows:

- (1) Calculate the occupant load for each platform level as in the appropriate examples in C.1.3 and C.1.4 for the same assumed time(s) of day. Refer also to 5.3.2.3(2) and A.5.3.2.3(2).
- (2) In a multilevel enclosed station, if the fire is on a platform that has routes that egress via another platform, an assumption can be made as to the percentage of occupants who might be expected to evacuate the lower level through the normal egress routes versus the percentage who might be expected to egress via emergency exit stairs. These assumptions will be unique for each system as a function of various parameters, including physical configuration of stations, means of egress, and location of emergency exits; communications facilities to advise passengers, both verbal and signing; level of transit personnel working in stations; and transit personnel emergency procedure responsibilities established for the transit operating authority.
- (3) The upper-level occupant load is increased by the people evacuating from the lower level through the normal egress routes in accordance with C.1.5(2).
- (4) For a fire on the lower level, appropriate assumptions relative to the distribution of the occupant loads to the available means of egress are calculated in a fashion similar to the procedures described above.

The remainder of the egress calculations essentially are unchanged from the other sample calculations in C.1.3 and C.1.4.

Statement of Problem and Substantiation for Public Input

NFPA 130 contains sample calculations for egress capacity and evacuation time, but not for occupant load. Given that the intent of NFPA 130 with respect to platform and station occupant load calculations is often misapplied, it is proposed that sample occupant load calculations be added to Appendix C. The current proposal is intended as a place-holder and should be expanded to include the actual calculations. Additionally, Annex A should be reviewed and revised to eliminate explanatory text that is better addressed in Appendix C, in favour of cross-reference.

Submitter Information Verification

Submitter Full Name: Katherine Fagerlund

Organization: JENSEN HUGHES Consulting Canad

Street Address:

City:

State:

Zip:

Submission Date: Tue Jun 30 20:16:34 EDT 2020

Committee: FKT-AAA

**Public Input No. 158-NFPA 130-2020 [New Section after C.1.5]****TITLE OF NEW CONTENT**

Tenability simulation need present sentivity analyses with respect to fire size.

Statement of Problem and Substantiation for Public Input

Sensitivity analyses with respect to grid size is cute, but cliché ...sensitivity analyses on the most influential independent variable (other than occupant load and the virtually immutalbe station geometry) cuts to the core. It is unimaginable that a fire-life safety engineer can be paid salary, without a sensitivity analyses on life subject to one of the most uncertain and most influential variables: the fire

Submitter Information Verification

Submitter Full Name: Scot Deal

Organization: Excelsior Fire Engineering

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 30 16:51:19 EDT 2020

Committee: FKT-AAA



Public Input No. 70-NFPA 130-2020 [New Section after E.3.4]

Automatic fire detection and on-board fire suppression

1. General

The purpose of this annex is to provide information about beneficial effects of automatic fire detection and on-board fire suppression systems in rail vehicles on fire life safety as well as on the holistic design of rail systems.

2. Automatic fire detection

2.1

The early detection of a fire on a rail vehicle is key to the effectiveness of mitigation measures intended to reduce the impact of the fire incident on fire life safety. A fire detection system can automatically detect a fire and communicate the information to initiate and facilitate emergency operational procedures.

2.2

A detection system can be used, not only to communicate the fire detection to personnel, but also to initiate other measures directly such as; turning on CCTV cameras in the affected areas for personnel to view the situation; controlling the vehicle ventilation system to stop smoke from spreading; automatically closing fire barrier doors; providing PA messages; cutting power to equipment enclosures where fire has been detected; activating an on-board fire suppression system.

2.3

The presence of an automatic fire detection system should be considered during the fire hazard analysis.

2.4

The performance of a smoke detection system on a rail vehicle is affected by vehicle parameters, in particular the vehicle heating, cooling and ventilation system. CFD modeling of the vehicle interior and air flows can aid the design of the smoke detection system. Smoke tests on the vehicle are used for design and verification of the detection performance.

3. On-board fire suppression

3.1 Design objective

The goal of an on-board fire suppression system is to slow or stop the fire growth rate or otherwise mitigate the impact of fire and in passenger areas to improve tenability for vehicle occupants during a fire condition until the vehicle is able to come to a safe stopping place where the occupants can egress the vehicle.

3.2

In compact enclosed areas such as diesel engine compartments, electrical cabinets and other equipment enclosures the systems are designed to extinguish the fire.

3.3

For passenger and crew areas a suppression system should be water mist based, intended to sharply reduce the heat release rate of a fire and prevent its growth.

3.4 Tenable environment

The tenability of the environment within a rail vehicle immediately after a fire has started until the vehicle is able to come to a safe stopping place where the occupants can egress the vehicle can be significantly improved with an on-board fire suppression system. Such systems typically improve thermal conditions in proximity to the fire, reduce the rate of smoke generation and its rate of spreading to other areas as well as keeping carbon monoxide levels well below critical levels.

3.5

The ability to suppress a fire on a rail vehicle at the fire's incipient stage is essential to reduce the fire growth and control the fire. If approved by the AHJ, the design fire scenario can be reduced as well as the peak heat release rate.

3.6 Design impact on other systems

The use of an on-board fire suppression system may:

- Limit damage to the train, tunnel and the station which it has entered;
- Reduce or eliminate potential use of station sprinklers;

- [Significantly reduce the impact of designing for fire emergencies on station architecture;](#)
- [Reduce tunnel ventilation capacity requirements](#)
- [Reduce the number and/or diameter of emergency ventilation fans required](#)
- [Decrease tunnel ventilation shaft and portal areas required](#)
- [Reduce the weight of vehicles by eliminating fire barrier doors](#)
- [Allow for improved vehicle design with open gangways](#)

Statement of Problem and Substantiation for Public Input

On-board fire suppression system was previously included as annex G to NFPA 130 since the 2014 edition. In the 2020 revision it was intended to merge annex G with annex B. This however resulted in the entirety of annex G being omitted from annex B. The proposed text is based on the original text of the former annex G and now includes fire detection. Both fire detection and fire suppression can provide significant improvement on the fire life safety of rail and transit systems. These systems are already mentioned within the NFPA130 and this annex intends to provide information on aspects of these systems those that are not familiar with them on rail vehicles.

This proposal is the third of 3 alternative proposals:

- 1 Create a new annex with the proposed text
- 2 Restore the previous text from annex G from NFPA 130 2014 and 2017 in its entirety to a new annex
- 3 Add the proposed new text to Annex E Fire Hazard Analysis Process for Vehicle Assessment and Evaluation

For information the following is the original text from Annex G NFPA 130 2014 and 2017:

On-board fire suppression systems (e.g., mist systems), while relatively new in the passenger rail and rail transit fixed guideway industry have been successfully used on a number of passenger rail and diesel powered light rail systems outside of the United States. The applications for this type of system can range from protection of diesel engine compartments to the interior of passenger rail vehicles. The use of a fire suppression system may: save lives in the incident vehicle during a fire condition; minimize damage to the train, tunnel and the station which it has entered; reduce or eliminate potential use of station sprinklers; reduce or eliminate the need for downstands; significantly reduce the impact of designing for fire emergencies on station architecture; reduce tunnel ventilation capacities by approximately 40%; may reduce the number and/or diameter of emergency ventilation fans at each end of each station and within the tunnels, thus reducing structure sizes; decrease shaft airflow cross section areas by approximately 40%; and decrease tunnel ventilation shaft portal areas that correspond to the required fans sizes/velocities. When considering the addition of a fire suppression system, several design challenges should be met by the rail vehicle manufacturer. These challenges include: the type of extinguishing medium used; which all must be approved by the AHJ the size and number of medium canisters and where on the vehicle to place them for easy access for maintenance; the resultant increased energy consumption caused by the increase in weight of the suppression system; the maintenance intervals; the cost of the system; the testing and commissioning of the system; and the cost and difficulties associated with retrofitting vehicle

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
Public Input No. 67-NFPA 130-2020 [New Section after G.3]	Alternative
Public Input No. 69-NFPA 130-2020 [New Section after G.3]	Alternative
Public Input No. 67-NFPA 130-2020 [New Section after G.3]	
Public Input No. 69-NFPA 130-2020 [New Section after G.3]	

Submitter Information Verification

Submitter Full Name: Jonathan Redding
Organization: FOGTEC Fire Protection
Street Address:
City:
State:
Zip:
Submittal Date: Fri Jun 26 08:39:39 EDT 2020
Committee: FKT-AAA



Public Input No. 75-NFPA 130-2020 [Chapter G]

Annex G – Informational References

G.1 – Referenced Publications.

The documents or portions thereof listed in this annex are referenced within the informational sections of this standard and are not

.. (this is a proposed new annex. Current Annex G would become Annex H so is shown deleted here under Annex G)

Annex “G” – RECOMMENDED METHODS OF ENSURING COOPERATION BETWEEN RAIL AGENCIES (RA) AND THE AUTHORITY HAVING JURISDICTION (AHJ)

This annex is not a part of the requirements of this

document unless also listed in Chapter 2 for other reasons.

G.1.1 – NFPA Publications.

National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 72[®], National Fire Alarm and Signaling Code[®], 2019 edition.

NFPA 92, Standard for Smoke Control Systems, 2018 edition.

NFPA 101[®], Life Safety Code[®], 2018 edition.

NFPA 472, Standard for Competence of Responders to Hazardous Materials/Weapons of Mass Destruction Incidents, 2018 edition.

NFPA 1006, Standard for Technical Rescue Personnel Professional Qualifications, 2017 edition.

NFPA 1670, Standard on Operations and Training for Technical Search and Rescue Incidents, 2017 edition.

NFPA 1710, Standard for the Organization and Deployment of Fire Suppression Operations, Emergency Medical Operations, and Special Operations to the Public by Career Fire Departments, 2020 edition.

NFPA 1720, Standard for the Organization and Deployment of Fire Suppression Operations, Emergency Medical Operations, and Special Operations to the Public by Volunteer Fire Departments, 2020 edition.

G.1.2 – Other Publications.

G.1.2.1 – APTA Publications.

American Public Transportation Association, 1300 I Street NW, Suite 1200 East, Washington, DC 20005.

APTA PR-PS-RP-005-00, Recommended Practice for Fire Safety Analysis of Existing Passenger Rail Equipment, 2000, edited 3/22/2004.

APTA PR-E-S-013-99, Rev. 1, Standard for Emergency Lighting System Design for Passenger Cars, 1999, revised 2007.

G.1.2.2 – ASHRAE Publications.

ASHRAE Inc., 1791 Tullie Circle, NE, Atlanta, GA 30329-2305.

ASHRAE Handbook — Fundamentals, 2013.

ASHRAE Handbook — Applications, 2015.

ASHRAE Handbook — Systems and Equipment, 2012.

G.1.2.3 – ASME Publications.

ASME Technical Publishing Office, Two Park Avenue, New York NY 10016-5990.

ANSI/ASME A17.1, Safety Code for Elevators and Escalators, 2013.

G.1.2.4 – ASTM Publications.

ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D3675, *Standard Test Method for Surface Flammability of Flexible Cellular Materials Using a Radiant Heat Energy Source*, 2017.

ASTM E162, *Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source*, 2016.

ASTM E1354, *Standard Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter*, 2017.

ASTM E1537, *Standard Test Method for Fire Testing of Upholstered Furniture*, 2016.

ASTM E1590, *Standard Test Method for Fire Testing of Mattresses*, 2017.

ASTM E2061, *Standard Guide for Fire Hazard Assessment of Rail Transportation Vehicles*, 2018.

G.1.2.5 – CENELEC Publications.

CENELEC, 35, European Committee for Electrotechnical Standardization, CEN-CENELEC Management Centre, Rue de la Science 23, B-1040, Brussels, Belgium.

EN 50124-1, *Railway Applications — Insulation Coordination. Part 1: Basic Requirements — Clearances and Creepage Distances for All Electrical and Electronic Equipment*, 2001, revised 2010.

G.1.2.6 – FAA Publications.

U.S. Federal Aviation Administration, U.S. Government Publishing Office, Washington, DC 20402.

FAR 25.853(c), *Oil Burner Test for Seat Cushions*.

G.1.2.7 – FRA Publications.

Federal Railroad Administration, 1200 New Jersey Avenue SE, Washington, DC 20590.

Title 49, Code of Federal Regulations, Part 238, Section 103, *Passenger Equipment Safety Standards*, 2014.

G.1.2.8 – ISO Publications.

International Organization for Standardization, ISO Central Secretariat, BIBC II, Chemin de Blandonnet 8, CP 401, 1214 Vernier, Geneva, Switzerland.

ISO/DIS 13571, *Life threat from fires — Guidance on the estimation of time available for escape using fire data*, 2006.

G.1.2.9 – NIST Publications.

National Institute of Standards and Technology, 100 Bureau Drive, Gaithersburg, MD 20899-1070.

NIST IR 4730, *Routine for Analysis of the People Movement Time for Elevator Evacuation*, Klote and Alvord, 1992.

G.1.2.10 – OSHA Publications.

Occupational Safety and Health Administration, 200 Constitution Avenue, NW, Washington, DC 20210.

Title 29, Code of Federal Regulations, Part 1910.95, "Occupational Noise Exposure," 2008.

G.1.2.11 – SFPE Publications.

Society of Fire Protection Engineers, 9711 Washingtonian Boulevard, Suite 380, Gaithersburg, MD 20878.

SFPE Engineering Guide to Performance-Based Fire Protection, 2nd edition, 2007.

G.1.2.12 – TDC Publications.

Transit Development Corporation, Inc., 1666 K Street NW, Washington, DC 20006.

Subway Environmental Design Handbook: Vol. 1, Principles and Applications, 2nd edition, 1976.

Associated Engineers: A joint venture by Parsons, Brinckerhoff, Quade & Douglas, Inc.; Deleuw, Cather and Company; and Kaiser Engineers under the direction of TDC, Inc.

G.1.2.13 – Other Publications.

"Acute Exposure Guideline Levels for Selected Airborne Chemicals," Vol. 8, Committee on Acute Exposure Guideline Levels, Committee on Toxicology, National Research Council. National Academies Press, Washington DC, 2010.

Ahrens, M., *U.S. Vehicle Fire Trends and Patterns for Rail Transport Vehicle Fires: U.S. Rail Passenger or Diner Car Fires 1986–1997*. Quincy, MA: NFPA, 1999.

Bothe C., G. M. Wolinski, and A. J. Breunese, "Spalling of concrete tunnel linings in fire," *(Re)Claiming the Underground Space*, J. Saver, ed., pp. 227–231, Swets & Zeitlinger Lisse, 2003.

Bukowski, R. W., et al. *Fire Hazard Assessment Method*, NIST Handbook 146, Gaithersburg, MD: NIST, 1989.

Chiam, Boon Hui, "Numerical Simulation of a Metro Train Fire," Fire Engineering Research Report 05/1, Department of Civil Engineering, University of Canterbury, Christchurch, New Zealand, June 2005.

"Escalator Handling Capacity," *Elevator World*, December 1996.

Federal Railroad Administration, Title 49, Code of Federal Regulations, Transportation, Parts 216, 223, 229, 231, 232, and 238, "Passenger Equipment Safety Standards: Final Rule," *Federal Register*, Vol. 64, No. 91, May 12, 1999, 25540–25705. Washington, DC: National Archives and Records Administration.

Federal Railroad Administration, Title 49, Code of Federal Regulations, Transportation, Part 238, "Passenger Equipment Safety Standards: Final Rules," *Federal Register*, Vol. 67, No. 122, June 25, 2014, 42892–42912. Washington, DC: National Archives and Records Administration.

Fleming, J. M. "Code Official's View of Performance-Based Codes," *Research and Practice: Bridging the Gap*, Proceedings, Fire Suppression and Detection Research Application Symposium, NFPA Research Foundation, Orlando, FL, February 12–14, 1997, pp. 234–251.

Fruin, J. J. *Pedestrian Planning and Design*. 1979 (revised ed.). Mobile, AL: Elevator World Inc., Educational Services Division, 354 Morgan Avenue, Mobile, AL, 36606.

Gross, D. "The Use of Fire Statistics in Assessing the Fire Risk of Products," *Interflam 1985 Conference Workbook*, No. 26–28, March 1985, pp. 11–18.

Hadjisophcleous, G., Lee, D. H. and Park, W. H., "Full-scale Experiments for Heat Release Rate Measurements of Railcar Fires," presented at the Fifth International Symposium on Tunnel Safety and Security, New York, 14–16 March, 2012.

Hirschler, M. M. "A New Mattress Fire Test for Use in Detention Environments," Business Communications Company Eighth Annual Conference on Recent Advances in Flame Retardancy of Polymeric Materials, Stamford, CT, June 2–4, 1997.

Karter, M. J., Jr. "Fire Loss in the United States During 1984," *Fire Journal*, Vol. 79, No. 3: 67–70, 73, 75–76, September 1985.

Kennedy, W. D., Ray, R. E., and Guinan, J. W., "A Short History of Train Fire Heat Release Calculations," presented at the 1998 ASHRAE Annual Meeting, Toronto, Ontario, Canada, June 1998.

Khoury, G. A. "Passive Protection Against Fire," *Tunnels and Tunneling International*, pp. 40–42. November 2002.

Kuligowski, E. D., "Compilation of Data on the Sublethal Effects of Fire Effluent," Technical Note 1644, National Institute of Standards and Technology, 2009.

Li, S., Louie, A., and Fuster, E. "The Impacts of Train Fire Profiles on Station Ventilation System Design," presented at the 15th International Symposium on Aerodynamics, Ventilation & Fire in Tunnels, Barcelona, Spain, 18–20 September 2013.

London Underground Ltd., *LUL Station Planning Guidelines*, London, 2015.

Lonnemark, A., et al., "Large-scale Commuter Train Fire Tests — Results from the METRO Project," presented at the Fifth International Symposium on Tunnel Safety and Security, New York, 14–16 March 2012.

Ontario Building Code, "Rapid Transit Stations," Canada, 2012.

Parsons, Brinckerhoff, Quade & Douglas, Inc., "Subway Environmental Design Handbook (SEDH), Volume II, Subway Environment Simulation Computer Program, SES Version 4.1, Part I User's Manual," 2nd edition, February 2002, U.S. Department of Transportation, Washington, DC.

Peacock, R. D., et al. *Fire Safety of Passenger Trains, Phase II, Application of Fire Hazard Analysis Techniques*. Prepared for Federal Railroad Administration (FRA), U.S. Department of Transportation (USDOT). National Institute of Standards and Technology (NIST) Interim Report, Report No. DOT/FRA/ORD-01/16, December 2001 and NISTR 6825, December 2002.

Schachenmayr, Martin P. *Application Guidelines for the Egress Element of the Fire Protection Standard for*

Fixed Guideway Transit Systems, Parsons, Brinckerhoff, Quade & Douglas, 1998.

Sørli, R. and Mathisen, H.M., EUREKA-EU 499 Firetun-Project: Fire Protection in Traffic Tunnels, SINTEF, Applied Thermodynamics, 1994.

Strege, S., B. Y. Lattimer, and C. Beyler. January 2003. "Fire-Induced Failure of Polycarbonate Windows in Railcars," *Proceedings of Fire and Materials*. London, UK: Interscience Communications, Ltd., 269–278, January 2003.

Subway Environmental Design Handbook (SEDH), National Technical Information, December 1993.

Tatnall, P. C. "Shotcrete in Fires: Effects of Fibers on Explosive Spalling," American Shotcrete Association, Farmington Hills, Michigan, 2002.

White, N., Dowling, V., and Barnett, J., "Full-scale Fire Experiment on a Typical Passenger Train, in Fire Safety Science," *Proceedings of the Eighth International Symposium*, Beijing, International Association for Fire Safety Science, Boston, MA, 2005.

G.2 – Informational References.

The following documents or portions thereof are listed here as informational resources only. They are not a part of the requirements of this document.

ANSI/ASA S3.5, *American National Standard Methods for Calculation of the Speech Intelligibility Index*, 1997 (R2012).

ANSI/ASA S12.65, *American National Standard for Rating Noise with Respect to Speech Interference*, 2006 (R2011).

BS-EN 50129, *Railway Applications. Communication, Signaling and Processing Systems. Safety-Related Electronic Systems for Signaling*, 2003, Corrigendum 2010.

Building Type Basics for Transit Facilities, K. W. Griffin, ed., John Wiley & Sons, 2004.

Friedman, R. "An International Survey of Computer Models for Fire and Smoke," *SFPE Journal of Fire Protection Engineering*, 4(3), 1992, pp. 81–92.

International Standards Organization Technical Committee 92/SC 3/WG5, "ISO 13571 — Life Threatening Components of Fire — Guidance on the Estimation of Time to Compromised Tenability in Fires." Document ISO/TC 92/SC 3/N203, 2012.

ISO 1999, *Acoustics — Estimation of noise-induced hearing loss*, 2013.

MIL-STD-882D, *Standard Practice for System Safety*, 2012.

NFPA, *Fire Protection Handbook*, 20th edition, 2008.

Smith, Edwin E., Phase I Report, *Transit Vehicle Material Specification Using Release Rate Tests for Flammability and Smoke*, October 1976.

Society of Fire Protection Engineers. SFPE, *Engineering Guide to Predicting 1st and 2nd Degree Skin Burns*, 1st edition, Gaithersburg, MD, 2000.

SFPE, *Handbook of Fire Protection Engineering*, 5th edition, 2016, Chapter 61, "Visibility and Human Behavior in Fire Smoke," Chapter 62, "Combustion Toxicity," and Chapter 63, "Engineering Assessment of Hazards to Occupants from Smoke, Toxic Gases, and Heat."

G.3 – References for Extracts in Informational Sections.

NFPA 921, *Guide for Fire and Explosion Investigations*, 2017 edition.

NFPA document but is included for informational purposes only.

This new annex expands A .3.2.2 Authority Having Jurisdiction (AHJ)

1. INTRODUCTION

This annex suggests recommendations which have been successfully used to promote cooperation between Fixed Guideway Transit and Passenger Rail Systems- Operator/Owners (known as Rail Agencies (RA)) and those Authority(ies) Having Jurisdiction (AHJ) that have been given the responsibility of ensuring that codes and/or standards are clearly and properly interpreted and enforced.

Many railroad properties pass through multiple city and state jurisdictions; all of which may establish fire and life safety guidance, interpretation's, and enforcement for their local jurisdictions. Given the range of AHJs and their different regulations as well as their conformance to different versions of the same regulations, conflicts will undoubtedly occur in language, interpretations and enforcement. Generally, where direct conflicts exist as they might with federal regulations, these typically supersede state or local regulations including this standard. Where a higher-level authority (i.e. federal government vs. state and local government) exists but where those regulations are silent on regulatory language on the subject matter in question, it becomes acceptable to utilize applicable language of a lower-level authority that exists.

To minimize delays and costs, RA's and AHJ's should come to an agreement to apply each jurisdiction's versions of a code and/or standard through an executed Memorandum of Understanding (MOU) between associated parties. An MOU is intended to document which codes, and interpretations of codes and standards are to be applied to a specific property and project. The development of this form of joint understanding agreement (MOU) between RA's and AHJ's should be initiated as soon as a project is formulated by the RA so as not to lose time and to move the projects design along expeditiously. Wherever possible an the MOU should be used for every AHJ to minimize changes to the RA.

Although, this standard (NFPA 130) is often written for new railroad properties it is can easily be adapted to modifications and/or additions to existing railroad properties. When new properties are added which pass through multiple jurisdictions, often the regulations between the existing and new jurisdictions will require a thorough review of applicability and acted upon accordingly. NFPA standards, such as this one, have limited legal authority unless it has been otherwise adopted by an enforcement agency, such as state and/or by city legislation. In states, counties, and cities a building or a fire code are often adapted and adopted from International Codes Council by legislation as minimum requirements. In almost all cases, the legislation establishes the AHJ as the entity set to enforce the code and possibly a standard. Most commonly the AHJ achieves its authority by a City, County, State or Federal Authority legislation. Where this standard has not been adopted in total but in part, the standard is generally recognized as a 'best practice or a minimum standard guideline' document which has legal merit.

2. REGULATION CHALLENGES

What is most beneficial to any project is to establish a "Fire and Life Safety Committee (FLSC)", whose members include, but are not limited to RA's, AHJ's and emergency response officials from the communities served. The FLSC will then agree on the following policies: that all members agree on applicable regulations, the regulation version (adopted or not); identify minimum requirements, provide a process for resolution of conflicts to fire and life safety regulations; identify and resolve gaps in regulations. While at the same time, ensuring all responsible agencies are properly represented that all agreed to regulations are included in SOP's; provide consistent regulations for designers and engineers, and finally to escalate conflicts to policy makers for any issues that cannot be resolved within the FLSC realm. . :

2.1 Fire and Life Safety Committee (FLSC):

The FLSC committee's membership of all affected agencies will help assure that fire/life safety requirements are accounted for in the design, construction, and final operation (revenue service) of the Project/Program. However, due to the sensitive nature and content of the information and decisions that will be shared throughout the course of the Fire Life Safety process, it will be necessary that all members participating in the review of and making recommendations to a projects formulation shall sign a confidentiality agreement. The Fire/Life Safety Committee will be the reviewing committee for fire/life safety considerations in a projects' design and construction operations and shall assist in the development of the emergency preparedness plan, including a response and operational requirements program. Note the FLSC does not have authority over AHJ's but provides a forum to resolve conflicts through discussion.

2.2 Coordinating Multiple Agency Responses

The FLSC also provides a forum to integrate emergency response agencies activities. Often the Fire Department is the regulatory AHJ, therefore fire department participation is simplified as this often includes response for fire, medical, rescue emergencies. However, other emergency response agencies (law enforcement, ambulance, RA, utilities, etc.) should be included in all relevant discussions and decisions. This inclusion could be significant when rail properties extend through multiple law enforcement and utility agency jurisdictions.

2.3 FLSC Structure

2.3.1 The RA normally assigns their Chief Safety Officer as the FLSC committee 'chairperson' who invites all AHJ representatives and develops the FLSC structure. The chairperson has the responsibility for ensuring that the FLSC includes members from all associated fire and life safety agencies.

2.3.2 Where AHJs choose not to participate it is necessary for them to provide to the FLSC chairperson a officially signed document stating their non-participation in the project so that they cannot return at a later date to request changes to the project, unless they, again in writing, request re-instatement on the project. This should specify if they will apply their authority on a project. In another case, some AHJ's may choose to opt out of exerting their authority for small, relatively insignificant, or low impact projects, or may defer to another AHJ.

2.3.3 The FLSC is normally comprised of AHJ's, state safety oversight's (SSO), first responder organizations and recognized international enforcement bodies as many may reference this standard as it is adopted rule. There may also be in some cases that a rail agency becomes its own Authority Having Jurisdiction. It is imperative in this case that they follow local codes and standards as a way of ensuring compliance with state and local laws.

2.3.4 With the help of the FLSC chairperson along with the approval of the RA operator, group members shall prepare and issue a charter for the committee members that establishes its scope, establish clearly defined roles and responsibilities of its members establish methods for the conflict resolution processes, and membership status for its members (voting and no-voting). The FLSC must finally establish the governing rules for a quorum so that all member can vote on all issues.

2.3.5 Representatives that are assigned to the FLSC should attend throughout the project's duration. Should that not be possible, each representative member agency should, in the early stages of the project designate alternates. Committee membership alternates should attend all meetings. Given distances between AHJ offices, tele-meetings may be most effective method of maintaining meeting dates and times.

2.3.7 Minutes of meetings and shared documents should be provided to all participating agencies. An RA managed secure internet site should be maintained with authorized access to committee members, alternates, and their supervisors. It is important to present preliminary designs of the project so that members can have a visual understanding of what the project entails, including but not limited to current and planned track and station alignments corresponding to jurisdictions crossed.

2.3.8 Once FLSC team members and their alternates have been set, establish a work plan and schedule for future meetings. For new properties and/or new AHJ representative participation to an existing FLSC, it will be necessary to explain the overall project scope, schedule, available RA resources, known AHJ regulations and fire and life safety systems/concerns should be provided.

2.3.9 For more complex RA properties with simultaneously occurring and potentially interfacing projects a sub committees to the FLSC would be advisable to address local project issues. Results from the local project FLSC should be addressed at the full FLSC to integrate the findings across all projects.

2.4 FLSC Resources

The FLSC should consider both internal and external resources, starting with this standard, other regulations, guidelines, other rail properties documents and publications to assist in resolving conflicts.

RA experts (designers), such as Fire Protection Engineers, Architects, Traction Power Specialists, Track Engineers, Mechanical Engineers, tunnel operators, etc. are essential resources to have attend specific meetings to provide technical advice to AHJs needed to inform AHJs and other RA members.

As the project progresses from initial planning through the various other stages of design and construction, the committee should meet with designers and contractors to formulate best methods for producing a safe and reliable rail station/tunnels, etc. On the train orientation meetings will usually be required.

FLSC Subcommittees or task groups should be considered for specific issues. They can investigate possible solutions, prepare materials and recommendations for the full FLSC.

Site visits by FLSC members should be arranged to provide a firsthand understanding of the challenges and discuss resolutions applied resulting from committee discussions and voting.

2.5 Conflicts

FLSC members should identify regulation conflicts at the earliest time in the projects' formulation as possible and forward them to the FLSC chairperson for dissemination to all members. Once identified, whether they be code conflict(s) (or gaps, i.e. where regulations do not provide clear guidance), the committee should identify a method to identify regulation intent and a documented process to resolve conflicts or provide agreed clarification. The resolution should be distributed to affected AHJs and included in design guide, if available.

2.6 Level of Compliance - The RA should assume that they will adopt the most stringent applicable language, or, adopt less stringent code/standards along with necessary supporting documentation as to why a less stringent code/standard was adopted in each case; Consulting legal advice is advisable prior to any adoption. For example, if this standard has been adopted as the design and construction guideline, but does not address specific circumstances, a language should be considered to address requirements from other building and fire codes whichever is applicable.

2.7 Lead Agency - As any number of railroad properties pass-through multiple jurisdictions, all with different representative values and regulations it may be advisable to select one as the lead agency representing the project and, based on the size and complexity of the project, it may be appropriate to establish lead jurisdictions for each critical section/element. E.g. For a major tunnel that connected into New York, all Fire Departments involved opted to have New York City Fire Department as the lead because of its size and expertise; for State Safety Oversight (SSO), with both NY and NJ as the two states involved, NJ SSO became the lead.

2.8 Design Guide or Technical Requirements - Are created to document operating facility requirements that will be addressed while developing the design of a specific project. The document assembles design elements such as: architectural guidelines; mechanical guidelines; fire and life safety guidelines and depending on the involvement of multiple jurisdictions the document becomes of the utmost importance.

Specifically, this document, as it relates to all applicable fire and life safety regulations along with the inclusion of modified by local ordinances as jointly agreed to by the AHJs and RA should be established as soon as practical. In some cases, to reduce the extensive review of multiple, potentially conflicting regulations, a Fire and Life Safety design guide has been developed. This would include related excerpts from the regulations, along with resolutions to conflicts' and language to fill regulation gaps. This document allows designers a common ground to ensure their design will meet the RA project fire and life safety requirements. This becomes the basis for design work on any projects relative to fire and life safety, for example RA stations

Although using a single edition design guide for the life of the RA is desirable to ensure all fire and life safety systems are the same, this is not usually possible as fire and life safety regulations which affect applicability, testing and maintenance can change as regulations are revised, and projects can be extended or new projects added into a time period when new regulations are adopted. The design guide should be reviewed, conflicts and changes to requirements updated and approved and a revised version of the design guide issued.

For small changes in regulations, rather than issue an entirely new design guide, a process for documenting distribution and receipt of agreed changes should be established as appendix language in design guide. For example, there are occasionally Temporary Interim Agreements (TIA) which are issued procedurally by the NFPA to correct a standard at the request of the Technical Committee.

The design guide, once approved by the AHJ should not be changed for the specific project under which the design guide was approved, i.e. unless serious problems with the adopted version of a regulation occur.

If local changes to the design guide are necessary, a document expressly identifying why the change is

necessary, identifying the sections of the applicable regulations, the intent, and be signed by affected parties. This document has been referred to as a Letter of Concurrence, or LOC.

Although a FLSC approved design guide is available, this does not supersede specific language in applicable regulations, nor does the presence of a design guide limit the authority vested in their regulations of the AHJ to make retroactive changes if deemed necessary.

3. EMERGENCY OPERATIONS PLANNING, TRAINING

The FLSC provides a logical venue to develop interagency training for RA, notably the Operations Control Center (OCC), and responding agencies. Since not all responders are from fire jurisdictions, other agencies should be included in planning and training. For larger rail properties a FLSC a standing subcommittee on training is often used. Since all agencies, including RA are required to comply with National Incident Management System federal requirements, the command structure of response is already defined. Specific training is required of the RA for responding agencies and this standard.

Given the potential for large scale mass casualty incidents with several jurisdictions responding, the FLSC is a logical location to develop, and coordinate required drills, tabletops, exercises, etc. to meet federal commissioning requirements typically included in funding packages. This is specifically applicable where multiple agencies will respond, i.e. fire department, law enforcement, RA, utilities such as power, local municipalities, etc.

Training includes pre-opening, as well as ongoing training and training when changes are made which might impact emergency responders and RA. Training types are identified in Homeland Security Exercise and Evaluation Program (1) and includes, seminars, drills, tabletops, functional and large-scale exercises.

Statement of Problem and Substantiation for Public Input

NFPA has no guidance on the relationships between NFPA 130 Standard for Fixed Guideway Transit and Passenger Rail Systems and the the Authorities Having Jurisdiction. The proposed annex becomes Annex G and current Annex G becomes Annex H. Proposed annex submitted by Harold Levitt, member emeritus and Gary English, former AHJ. Following suggestions in this annex can streamline design, construction processes for new properties and property retrofits which will save time and money. Suggestions are made based on proven practices.

Submitter Information Verification

Submitter Full Name: Gary English

Organization: Underground Command And Safety

Affiliation: NFPA 130 technical committee alternate

Street Address:

City:

State:

Zip:

Submittal Date: Sat Jun 27 16:55:55 EDT 2020

Committee: FKT-AAA

**Public Input No. 49-NFPA 130-2020 [Section No. G.1.2.4]****G.1.2.4** ASTM Publications.

ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D3675, *Standard Test Method for Surface Flammability of Flexible Cellular Materials Using a Radiant Heat Energy Source*, 2017 2019 .

ASTM E162, *Standard Test Method for Surface Flammability of Materials Using a Radiant Heat Energy Source*, 2016.

ASTM E1354, *Standard Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter*, 2017.

ASTM E1537, *Standard Test Method for Fire Testing of Upholstered Furniture*, 2016.

ASTM E1590, *Standard Test Method for Fire Testing of Mattresses*, 2017.

ASTM E2061, *Standard Guide for Fire Hazard Assessment of Rail Transportation Vehicles*, 2018 2020 .

Statement of Problem and Substantiation for Public Input

updates

Submitter Information Verification

Submitter Full Name: Marcelo Hirschler

Organization: GBH International

Street Address:

City:

State:

Zip:

Submittal Date: Tue Jun 16 18:16:12 EDT 2020

Committee: FKT-AAA



Public Input No. 67-NFPA 130-2020 [New Section after G.3]

New Annex

Automatic fire detection and on-board fire suppression

(1) General

The purpose of this annex is to provide information about beneficial effects of automatic fire detection and on-board fire suppression systems in rail vehicles on fire life safety as well as on the holistic design of rail systems.

(1) Automatic fire detection

2.1

The early detection of a fire on a rail vehicle is key to the effectiveness of mitigation measures intended to reduce the impact of the fire incident on fire life safety. A fire detection system can automatically detect a fire and communicate the information to initiate and facilitate emergency operational procedures.

2.2

A detection system can be used, not only to communicate the fire detection to personnel, but also to initiate other measures directly such as; turning on CCTV cameras in the affected areas for personnel to view the situation; controlling the vehicle ventilation system to stop smoke from spreading; automatically closing fire barrier doors; providing PA messages; cutting power to equipment enclosures where fire has been detected; activating an on-board fire suppression system.

2.3

The presence of an automatic fire detection system should be considered during the fire hazard analysis.

2.4

The performance of a smoke detection system on a rail vehicle is affected by vehicle parameters, in particular the vehicle heating, cooling and ventilation system. CFD modeling of the vehicle interior and air flows can aid the design of the smoke detection system. Smoke tests on the vehicle are used for design and verification of the detection performance.

(1) On-board fire suppression

(1) 3.1 Design objective

- (2) The goal of an on-board fire suppression system is to slow or stop the fire growth rate or otherwise mitigate the impact of fire and in passenger areas to improve tenability for vehicle occupants during a fire condition until the vehicle is able to come to a safe stopping place where the occupants can egress the vehicle.

(3) 3.2

- (4) In compact enclosed areas such as diesel engine compartments, electrical cabinets and other equipment enclosures the systems are designed to extinguish the fire.

(5) 3.3

- (6) For passenger and crew areas a suppression system should be water mist based, intended to sharply reduce the heat release rate of a fire and prevent its growth.

(7) 3.4 Tenable environment

- (8) The tenability of the environment within a rail vehicle immediately after a fire has started until the vehicle is able to come to a safe stopping place where the occupants can egress the vehicle can be significantly improved with an on-board fire suppression system. Such systems typically improve thermal conditions in proximity to the fire, reduce the rate of smoke generation and its rate of spreading to other areas as well as keeping carbon monoxide levels well below critical levels.

3.5

The ability to suppress a fire on a rail vehicle at the fire's incipient stage is essential to reduce the fire growth and control the fire. If approved by the AHJ, the design fire scenario can be reduced as well as the peak heat release rate.

3.6 Design impact on other systems

The use of an on-board fire suppression system may:

- Limit damage to the train, tunnel and the station which it has entered;
- Reduce or eliminate potential use of station sprinklers;
- Significantly reduce the impact of designing for fire emergencies on station architecture;
- Reduce tunnel ventilation capacity requirements
- Reduce the number and/or diameter of emergency ventilation fans required
- Decrease tunnel ventilation shaft and portal areas required
- Reduce the weight of vehicles by eliminating fire barrier doors
- Allow for improved vehicle design with open gangways

Statement of Problem and Substantiation for Public Input

On-board fire suppression system was previously included as annex G to NFPA 130 since the 2014 edition. In the 2020 revision it was intended to merge annex G with annex B. This however resulted in the entirety of annex G being omitted from annex B. The proposed text is based on the original text of the former annex G and now includes fire detection. Both fire detection and fire suppression can provide significant improvement on the fire life safety of rail and transit systems. These systems are already mentioned within the NFPA130 and this annex intends to provide information on aspects of these systems those that are not familiar with them on rail vehicles.

This proposal is the first of 3 alternative proposals:

- 1 Create a new annex with the proposed text
- 2 Restore the previous text from annex G from NFPA 130 2014 and 2017 in its entirety to a new annex
- 3 Add the proposed new text to Annex E Fire Hazard Analysis Process for Vehicle Assessment and Evaluation

For information the following is the original text from Annex G NFPA 130 2014 and 2017:

On-board fire suppression systems (e.g., mist systems), while relatively new in the passenger rail and rail transit fixed guideway industry have been successfully used on a number of passenger rail and diesel powered light rail systems outside of the United States. The applications for this type of system can range from protection of diesel engine compartments to the interior of passenger rail vehicles. The use of a fire suppression system may: save lives in the incident vehicle during a fire condition; minimize damage to the train, tunnel and the station which it has entered; reduce or eliminate potential use of station sprinklers; reduce or eliminate the need for downstands; significantly reduce the impact of designing for fire emergencies on station architecture; reduce tunnel ventilation capacities by approximately 40%; may reduce the number and/or diameter of emergency ventilation fans at each end of each station and within the tunnels, thus reducing structure sizes; decrease shaft airflow cross section areas by approximately 40%; and decrease tunnel ventilation shaft portal areas that correspond to the required fans sizes/velocities. When considering the addition of a fire suppression system, several design challenges should be met by the rail vehicle manufacturer. These challenges include: the type of extinguishing medium used; which all must be approved by the AHJ the size and number of medium canisters and where on the vehicle to place them for easy access for maintenance; the resultant increased energy consumption caused by the increase in weight of the suppression system; the maintenance intervals; the cost of the system; the testing and commissioning of the system; and the cost and difficulties associated with retrofitting vehicle

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 69-NFPA 130-2020 [New Section after G.3]</u>	Alternative
<u>Public Input No. 70-NFPA 130-2020 [New Section after E.3.4]</u>	Alternative
<u>Public Input No. 69-NFPA 130-2020 [New Section after G.3]</u>	
<u>Public Input No. 70-NFPA 130-2020 [New Section after E.3.4]</u>	

Submitter Information Verification

Submitter Full Name: Jonathan Redding
Organization: FOGTEC Fire Protection
Street Address:
City:
State:
Zip:
Submittal Date: Fri Jun 26 08:09:25 EDT 2020
Committee: FKT-AAA



Public Input No. 69-NFPA 130-2020 [New Section after G.3]

New Annex

On-board fire suppression systems

On-board fire suppression systems (e.g., mist systems), while relatively new in the passenger rail and rail transit fixed guideway industry have been successfully used on a number of passenger rail and diesel powered light rail systems outside of the United States. The applications for this type of system can range from protection of diesel engine compartments to the interior of passenger rail vehicles. The use of a fire suppression system may: save lives in the incident vehicle during a fire condition; minimize damage to the train, tunnel and the station which it has entered; reduce or eliminate potential use of station sprinklers; reduce or eliminate the need for downstands; significantly reduce the impact of designing for fire emergencies on station architecture; reduce tunnel ventilation capacities by approximately 40%; may reduce the number and/or diameter of emergency ventilation fans at each end of each station and within the tunnels, thus reducing structure sizes; decrease shaft airflow cross section areas by approximately 40%; and decrease tunnel ventilation shaft portal areas that correspond to the required fans sizes/velocities. When considering the addition of a fire suppression system, several design challenges should be met by the rail vehicle manufacturer. These challenges include: the type of extinguishing medium used; which all must be approved by the AHJ the size and number of medium canisters and where on the vehicle to place them for easy access for maintenance; the resultant increased energy consumption caused by the increase in weight of the suppression system; the maintenance intervals; the cost of the system; the testing and commissioning of the system; and the cost and difficulties associated with retrofitting vehicles

Statement of Problem and Substantiation for Public Input

On-board fire suppression system was previously included as annex G to NFPA 130 since the 2014 edition. In the 2020 revision it was intended to merge annex G with annex B. This however resulted in the entirety of annex G being omitted from annex B. The proposed text is based on the original text of the former annex G and now includes fire detection. Both fire detection and fire suppression can provide significant improvement on the fire life safety of rail and transit systems. These systems are already mentioned within the NFPA130 and this annex intends to provide information on aspects of these systems those that are not familiar with them on rail vehicles.

This proposal is the second of 3 alternative proposals:

- 1 Create a new annex with the proposed text
- 2 Restore the previous text from annex G from NFPA 130 2014 and 2017 in its entirety to a new annex
- 3 Add the proposed new text to Annex E Fire Hazard Analysis Process for Vehicle Assessment and Evaluation

Related Public Inputs for This Document

<u>Related Input</u>	<u>Relationship</u>
<u>Public Input No. 67-NFPA 130-2020 [New Section after G.3]</u>	Alternative
<u>Public Input No. 70-NFPA 130-2020 [New Section after E.3.4]</u>	Alternative

Submitter Information Verification

Submitter Full Name: Jonathan Redding
Organization: FOGTEC Fire Protection
Street Address:
City:
State:
Zip:
Submission Date: Fri Jun 26 08:27:10 EDT 2020
Committee: FKT-AAA