



Tentative Interim Amendment

NFPA[®] 2

Hydrogen Technologies Code

2023 Edition

Reference: 8.3.1.2.6.1

TIA 23-3

(SC 23-8-45 / TIA Log #1725)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 2, *Hydrogen Technologies Code*, 2023 edition. The TIA was processed by the Technical Committee on Hydrogen Technology and was issued by the Standards Council on August 25, 2023, with an effective date of September 14, 2023.

1. Revise paragraph 8.3.1.2.6.1 to read as follows:

8.3.1.2.6.1 Specific locations for the Class 1, Division 1, Group B (hydrogen) and Class 1, Division ~~1~~2, Group B (hydrogen) areas shall be classified in accordance with Table 8.3.1.2.6.1.

Issue Date: August 25, 2023

Effective Date: September 14, 2023

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2023 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION