



Tentative Interim Amendment

NFPA[®] 2

Hydrogen Technologies Code

2023 Edition

Reference: 7.3.2.3.1.4(A)

TIA 23-4

(SC 24-12-5 / TIA Log #1784)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 2, *Hydrogen Technologies Code*, 2023 edition. The TIA was processed by the Technical Committee on Hydrogen Technologies and was issued by the Standards Council on December 4, 2024, with an effective date of December 24, 2024.

1. *Revise paragraph 7.3.2.3.1.4(A) to read as follows:*

7.3.2.3.1.4(A)* Passive Means. The distances to Group 1 and Group 2 exposures shown in Table 7.3.2.3.1.2(B)(a), Table 7.3.2.3.1.2(B)(b), and Table 7.3.2.3.1.2(B)(c) ~~are~~ shall be permitted to be reduced by one-half, and the distance to Group 3 exposures in Table 7.3.2.3.1.2(B)(a), Table 7.3.2.3.1.2(B)(b), and Table 7.3.2.3.1.2(B)(c) shall be permitted to be reduced to 0 ft (0 m), where fire barrier walls are located between the system and the exposure and constructed in accordance with all of the following:

...

Issue Date: December 4, 2024

Effective Date: December 24, 2024

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2024 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION