



Tentative Interim Amendment

NFPA[®] 20

Standard for the Installation of Stationary Pumps for Fire Protection

2022 Edition

Reference: 10.4.5.4.1 and 10.4.5.4.2

TIA 22-3

(SC 24-8-16/ TIA Log #1799)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2022 edition. The TIA was processed by the Technical Committee on Fire Pumps, and was issued by the Standards Council on August 29, 2024, with an effective date of September 18, 2024.

I Revise paragraphs 10.4.5.4.1 and 10.4.5.4.2 to read as follows:

10.4.5.4.1 Starting reactors and autotransformers shall comply with the requirements of UL 508, *Industrial Control Equipment*, Table ~~92.1~~ 113.1.

10.4.5.4.2 Starting reactors and autotransformers over 200 hp shall be permitted to be designed to Table 113.1, Part 3, of UL 508, *Industrial Control Equipment*, ~~Table 92.1~~, in lieu of Table 113.1, Part 4.

Issue Date: August 29, 2024

Effective Date: September 18, 2024

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2024 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION