



Tentative Interim Amendment

NFPA® 20

Standard for the Installation of Stationary Pumps for Fire Protection

2025 Edition

Reference: 10.4.5.4.1 and 10.4.5.4.2

TIA 25-1

(SC 24-8-16/ TIA Log #1799)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1 Revise paragraphs 10.4.5.4.1 and 10.4.5.4.2 to read as follows:

10.4.5.4.1 Starting reactors and autotransformers shall comply with the requirements of Table ~~92.4~~ 113.1 of UL 508, *Industrial Control Equipment*.

10.4.5.4.2 Starting reactors and autotransformers over 200 hp shall be permitted to be designed to Table ~~92.4~~ 113.1, Part 3, of UL 508, *Industrial Control Equipment*, in lieu of Table 113.1, Part 4.

Issue Date: August 29, 2024

Effective Date: September 18, 2024

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2024 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION