



## Errata

# NFPA 2001

## *Standard on Clean Agent Fire Extinguishing Systems*

### 2022 Edition

**Reference:** Table A.7.2.2.2.1

**Errata No:** 2001-22-1

The Technical Committee on Gaseous Fire Extinguishing Systems notes the following error in the 2022 edition of NFPA 2001, *Standard on Clean Agent Fire Extinguishing Systems*.

1. Correct the “MEC” values in Table A.7.2.2.2.1 to read as follows:

**Table A.7.2.2.2.1 Minimum Flame Extinguishing Concentration (Fuel: n-heptane)**

Agent	MEC (vol %)	Note
FK-5-1-12	<del>4.5</del> <u>4.5</u>	Muller, 2002
HFC-125	<del>8.7</del> <u>8.7</u>	Harrison and Robin, 2001
HFC-227ea	6.62	Senecal, 2008
HFC-23	<del>12.9</del> <u>12.9</u>	Hainsworth and Hammel, 2003
HFC-236fa	<del>6.3</del> <u>6.3</u>	Harrison and Robin, 2001
IG-01	<del>43.2</del> <u>43.2</u>	FM Approvals, 2005
IG-100	32.6	FM Approvals, 2005
IG-541	<del>34.4</del> <u>34.4</u>	FM Approvals, 2005
IG-55	<del>36.2</del> <u>36.2</u>	FM Approvals, 2005
HB-55	5.5	

Notes: [remain unchanged]

Issue Date: September 27, 2022

(Note: For current information about the NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2022 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION