



Tentative Interim Amendment

NFPA[®] 409

Standard on Aircraft Hangars

2026 Edition

Reference: 7.4.6.7, 7.5.4.10, 7.5.5.6, 7.5.12.2.4(new), and 7.5.13.6

TIA 26-1

(SC 25-12-10 / TIA Log #1850)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise paragraph 7.4.6.7 to read as follows:*

7.4.6.7 Sprinklers shall be control mode and permitted to be a have a minimum nominal K-factor of K-80 (K-5.6) and larger. Suppression mode sprinklers shall be allowed when the hangar occupancy is covered by other applicable NFPA standards (e.g., the storage protection provisions in NFPA 13). Sprinklers shall be listed for their application, and designed and installed in accordance with NFPA 13 ~~or~~ and their listings.

2. *Revise paragraph 7.5.4.10 to read as follows:*

7.5.4.10 ~~The~~ Discharge devices with a nominal K-40 (K-2.8) and larger shall be permitted ~~shall have a minimum nominal 6.4 mm (1/4 in.) orifice and shall be where~~ listed for use with the particular type of foam concentrate to be used in the system.

3. *Revise paragraph 7.5.5.6 to read as follows:*

7.5.5.6 ~~Sprinklers shall be n~~ Nominal K-80 (K-5.6) or K-115 (K-8.0) and larger sprinklers shall be permitted.

4. *Add a new paragraph 7.5.12.2.4(new) to read as follows:*

7.5.12.2.4 Nominal K-80 (K-5.6) and larger sprinklers shall be permitted.

5. *Revise paragraph 7.5.13.6 to read as follows:*

7.5.13.6 ~~Sprinklers shall be n~~ Nominal K-80 (K-5.6) or K-115 (K-8.0) and larger sprinklers shall be permitted.

Issue Date: December 2, 2025

Effective Date: December 22, 2025

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION