

SR 27:

12.3.2 Appliances Not Required to Be Vented.

The following appliances shall not be required to be vented:

1. Listed ranges
2. Built-in cooking units listed and marked for optional venting
3. Listed hot plates
4. Listed Type 1 clothes dryers exhausted in accordance with Section 10.4
5. A single listed booster-type (automatic instantaneous) water heater, when designed and used solely for the sanitizing rinse requirements of a dishwashing machine, provided that the appliance is installed with the draft hood in place and unaltered, if a draft hood is required, in a commercial kitchen having a mechanical exhaust system [Where installed in this manner, the draft hood outlet shall not be less than 36 in. (910 mm) vertically and 6 in. (150 mm) horizontally from any surface other than the appliance.]
6. Listed refrigerators
7. Counter appliances
8. Room heaters listed for unvented use
9. Direct gas-fired make-up air heaters
10. Other appliances listed for unvented use and not provided with flue collars
11. Specialized appliances of limited input such as laboratory burners or gas lights

SR 34: (detail)

12.3.2 Appliances Not Required to Be Vented.

The following appliances shall not be required to be vented:

1. Listed ranges
2. Built-in domestic cooking units listed and marked for optional venting
3. Listed hot plates
4. Listed Type 1 clothes dryers exhausted in accordance with Section 10.4
5. A single listed booster-type (automatic instantaneous) water heater, when designed and used solely for the sanitizing rinse requirements of a dishwashing machine, provided that the appliance is installed with the draft hood in place and unaltered, if a draft hood is required, in a commercial kitchen having a mechanical exhaust system [Where installed in this manner, the draft hood outlet shall not be less than 36 in. (910 mm) vertically and 6 in. (150 mm) horizontally from any surface other than the appliance.] (*see 12.3.2.1*)
6. Listed refrigerators
7. Counter appliances
8. Room heaters listed for unvented use
9. Direct gas-fired make-up air heaters
10. Other appliances listed for unvented use and not provided with flue collars
11. Specialized appliances of limited input such as laboratory burners or gas lights

12.3.2.1

Where an appliance is installed as stated in 12.3.2(5), the draft hood outlet shall not be less than 36 in. (910 mm) vertically and 6 in. (150 mm) horizontally from any surface other than the appliance.