



Tentative Interim Amendment

## NFPA<sup>®</sup> 58

### *Liquefied Petroleum Gas Code*

#### 2024 Edition

**Reference:** 6.31.5.2 and 6.31.5.2(E)(new)

**TIA 24-1**

(SC 23-8-53 / TIA Log #1703)

**Note:** Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise paragraph 6.31.5.2 and add a new paragraph 6.31.5.2(E) to read as follows:*

**6.31.5.2** Transfer into ASME containers permanently installed on vehicles shall meet the provisions of 6.31.5.2(A) through 6.31.5.2(~~D~~E).

(A) The delivery valve and nozzle combination shall mate with the filler valve in the receiving container in such a manner that, when they are uncoupled following a transfer of LP-Gas, not more than 0.24 in.<sup>3</sup> (4 cm<sup>3</sup>) of LP-Gas (liquid equivalent) is released to the atmosphere.

(B) Fixed Maximum liquid level gauges that are installed on engine fuel and mobile containers in accordance with Table 5.9.4.1(B) shall not be used to determine the maximum permitted filling limit at a low-emission transfer site.

(C) ...

(D) ...

(E) Paragraphs 6.31.5.2(A) and 6.31.5.2(B) shall not apply to LP-Gas transfers and equipment used for testing, maintenance, or repair.

**Issue Date:** August 25, 2023

**Effective Date:** September 14, 2023

(Note: For further information on NFPA Codes and Standards, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))

Copyright © 2023 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION