



Tentative Interim Amendment

NFPA[®] 58

Liquefied Petroleum Gas Code

2024 Edition

Reference: 5.2.8.2, and A.5.2.8.2

TIA 24-2

(SC 24-8-18/ TIA Log #1774)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 58, *Liquefied Petroleum Gas Code*, 2024 edition. The TIA was processed by the Technical Committee on Liquefied Petroleum Gases, and was issued by the Standards Council on August 29, 2024, with an effective date of September 18, 2024.

1. *Revise paragraph 5.2.8.2 to read as follows:*

5.2.8.2* Cylinders shall be marked with the following information:

- (1) Water capacity of the cylinder in pounds or liters
- (2) Tare weight of the cylinder in pounds or kilograms, fitted for service

2. *Revise Annex A.5.2.8.2 to read as follows:*

A.5.2.8.2 The water capacity of the cylinder is the determination of the cylinder volume with water at approximately 60°F (16°C). Cylinders with DOT markings have water capacity marked in pounds (lb); however, Transport Canada cylinders have water capacity marked in liters (L). The tare weight is the cylinder weight plus the weight of all permanently attached valves and other fittings but does not include the weight of protecting devices that are removed in order to load the cylinder. DOT markings utilize “TW” to indicate tare weight, followed by the weight in pounds (lb), whereas Transport Canada cylinders utilize “T” to indicate tare weight, followed by the weight in kilograms (kg).

Issue Date: August 29, 2024

Effective Date: September 18, 2024

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2024 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION