



Errata

NFPA 70®

National Electrical Code®

2023 Edition – First Printing Only

Reference: 210.11(C)(3) Exception, and 210.11(C)(4) Exception No. 2

Errata No: 70-23-1

The National Electrical Code Panel 2, and the NEC Correlating Committee note the following errors in the First Printing only of the 2023 edition of NFPA 70®, *National Electrical Code®*.

1. *Correct the reference in paragraph 210.11(C)(3) Exception to read as follows:*

210.11 Branch Circuits Required.

...

(C) Dwelling Units.

...

(3) Bathroom Branch Circuits.

Exception Where the 20-ampere circuit supplies a single bathroom, outlets for other equipment within the same bathroom shall be permitted to be supplied in accordance with 210.23(B)(1) and ~~(A)(2)~~ (B)(2).

2. *Correct the reference in paragraph 210.11(C)(4) Exception No 2 to read as follows:*

210.11 Branch Circuits Required.

...

(C) Dwelling Units.

...

(4) Garage Branch Circuits. ...

Exception No. 2: Where the 20-ampere circuit supplies a single vehicle bay garage, outlets for other equipment within the same garage shall be permitted to be supplied in accordance with 210.23~~(A)(1)~~ and ~~(A)(2)~~ (B)(1) and (B)(2).

Issue Date: September 1, 2022

(Note: For current information about the NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2022 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION