



Errata

NFPA 70®

National Electrical Code®

2023 Edition

Reference: 555.53, 702.4(A)(2), and Annex C Listing of Tables

Errata No: 70-23-2

The National Electrical Code Panels 7, 8, 13, and the NEC Correlating Committee note the following errors in the 2023 edition of NFPA 70®, *National Electrical Code®*.

1. *Correct the reference in section 555.53 to read as follows:*

555.53 Ground-Fault Protection. The main overcurrent protective device that feeds the floating building shall have ground-fault protection not exceeding 100 mA. Ground-fault protection of each individual branch or feeder circuit shall be permitted as a suitable alternative. Outdoor outlets, shore power outlets, and boat hoists located at floating buildings shall comply with 555.35-~~(C)~~ and ~~(D)~~ (B) and (C).

2. *Correct the reference in section 702.4(A)(2) to read as follows:*

702.4 Capacity and Rating.

(A) System Capacity.

(1) Manual and Nonautomatic Load Connection. ...

(2) Automatic Load Connection. If the connection of load is automatic, an optional standby system shall comply with 702.4(A)(2)(a) or ~~(B)~~ (A)(2)(b) in accordance with Parts I through IV of Article 220 or by another approved method.

...

3. *Correct the page numbers for each Table listed for Annex C to read as follows:*

Informative Annex C Conduit, Tubing, and Cable Tray Fill Tables for Conductors and Fixture Wires of the Same Size

This informative annex is not a part of the requirements of this NFPA document but is included for informational purposes only.

Table	Page
C.1 — Electrical Metallic Tubing (EMT)	<u>730774</u>
C.1(A)* — Electrical Metallic Tubing (EMT)	<u>734777</u>
C.2 — Electrical Nonmetallic Tubing (ENT)	<u>736778</u>
C.2(A)* — Electrical Nonmetallic Tubing (ENT)	<u>740781</u>
C.3 — Flexible Metal Conduit (FMC)	<u>742782</u>
C.3(A)* — Flexible Metal Conduit (FMC)	<u>746785</u>
C.4 — Intermediate Metal Conduit (IMC)	<u>748786</u>
C.4(A)* — Intermediate Metal Conduit (IMC)	<u>752789</u>
C.5 — Liquidtight Flexible Nonmetallic Conduit (LFNC-A)	<u>754790</u>
C.5(A)* — Liquidtight Flexible Nonmetallic Conduit (LFNC-A)	<u>758793</u>

C.6 — Liquidtight Flexible Nonmetallic Conduit (LFNC-B)	<u>760794</u>
C.6(A)* — Liquidtight Flexible Nonmetallic Conduit (LFNC-B)	<u>764797</u>
C.7 — Liquidtight Flexible Nonmetallic Conduit (LFNC-C)	<u>766798</u>
C.7(A)* — Liquidtight Flexible Nonmetallic Conduit (LFNC-C)	<u>770802</u>
C.8 — Liquidtight Flexible Metal Conduit (LFMC)	<u>772803</u>
C.8(A)* — Liquidtight Flexible Metal Conduit (LFMC)	<u>776806</u>
C.9 — Rigid Metal Conduit (RMC)	<u>778807</u>
C.9(A)* — Rigid Metal Conduit (RMC)	<u>782810</u>
C.10 — Rigid PVC Conduit, Schedule 80	<u>784811</u>
C.10(A)* — Rigid PVC Conduit, Schedule 80	<u>788814</u>
C.11 — Rigid PVC Conduit, Schedule 40 and HDPE Conduit	<u>790815</u>
C.11(A)* — Rigid PVC Conduit, Schedule 40 and HDPE Conduit	<u>794818</u>
C.12 — Type A, Rigid PVC Conduit	<u>796819</u>
C.12(A)* — Type A, Rigid PVC Conduit	<u>800822</u>
C.13 — Type EB, PVC Conduit	<u>802823</u>
C.13(A)* — Type EB, PVC Conduit	<u>806826</u>
C.14 — Type MC Cables Permitted in Cable Tray	<u>808827</u>
C.15 — Type MC Cables Permitted in Cable Tray	<u>809828</u>
C.16 — Type TC Cables Permitted in Cable Tray	<u>810829</u>
C.17 — Type TC Cables Permitted in Cable Tray	<u>814830</u>
C.18 — Single Conductor Cables Permitted in Cable Tray	<u>812831</u>
C.19 — Single Conductor Cables Permitted in Cable Tray	<u>813832</u>
C.20 — Single Conductor Cables Permitted in Cable Tray	<u>814833</u>

*Where this table is used in conjunction with Tables C.1 through C.13, the conductors installed must be of the compact type.

Issue Date: September 15, 2022

(Note: For current information about the NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2022 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION