



Errata

NFPA 70®

National Electrical Code®

2026 Edition

Reference: 240.86(C)

Errata No: 70-26-1

The Code-Making Panel 10 and National Electrical Code Correlating Committee note the following error in the 2026 edition of *NFPA 70®*, *National Electrical Code®*.

1. Correct section paragraph 240.86(C) to read as follows:

(C) Motor Contribution. Series ratings shall not be used ~~where in the following situations:~~

- (1) ~~Where m~~Motor circuits are connected between the higher-rated OCPD of a series-rated combination and on the lower-rated circuit breaker, and
- (2) ~~Where t~~The sum of these motor full-load currents exceeds 1 percent of the interrupting rating of the lower-rated circuit breaker.

Issue Date: August 12, 2025

(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see www.nfpa.org/docinfo)

Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION