



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2023 Edition

Reference: 250.114(3)e and 250.114(4)e

TIA 23-1

(SC 21-12-13 / TIA Log #1608)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise 250.114(3)e and (4)e to read as follows:*

250.114 Equipment Connected by Cord and Plug. Exposed, normally non-current-carrying metal parts of cord-and-plug-connected equipment shall be connected to the equipment grounding conductor under any of the following conditions:

...

(3) In residential occupancies:

...

e. Portable handlamps ~~and portable luminaires~~

(4) In other than residential occupancies:

...

e. Portable handlamps ~~and portable luminaires~~

...

Issue Date: December 8, 2021

Effective Date: December 28, 2021

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2021 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION