



Tentative Interim Amendment

NFPA® 70®

National Electrical Code®

2023 Edition

Reference: 408.6
TIA 23-12
(SC 23-8-56 / TIA Log #1699)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70®, *National Electrical Code®*, 2023 edition. The TIA was processed by Code-Making Panel 9 and the Correlating Committee on National Electrical Code, and was issued by the Standards Council on August 25, 2023, with an effective date of September 14, 2023.

1. Revise 408.6 to read as follows:

408.6 Short-Circuit Current Rating. Switchboards, switchgear, and panelboards shall have a short-circuit current rating not less than the available fault current. In other than one- and two-family dwelling units, the available fault current and the date the calculation was performed shall be field marked on the enclosure at the point of supply. The marking shall be of sufficient durability to withstand the environment involved. ~~comply with 110.21(B)(3).~~

Issue Date: August 25, 2023

Effective Date: September 14, 2023

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2023 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION