



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2023 Edition

Reference: 430.132(new)

TIA 23-20

(SC 25-8-13 / TIA Log #1843)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70[®], *National Electrical Code[®]*, 2023 edition. The TIA was processed by Code-Making Panel 11 and the National Electrical Code Correlating Committee, and was issued by the Standards Council on August 20, 2025, with an effective date of September 9, 2025.

1. Add a new section 430.132 to read as follows:

430.132 GFCI and SPGFCI Between Power Conversion Equipment and Motors. Ground-fault circuit interrupters and special purpose ground-fault circuit interrupters shall not be installed between power conversion equipment output terminals and the motor.

Issue Date: August 20, 2025

Effective Date: September 9, 2025

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION