



Tentative Interim Amendment

NFPA® 70®

National Electrical Code®

2023 Edition

Reference: 210.8(F) and Exception No. 2(new)

TIA 23-3

(SC 22-8-17 / TIA Log #1654)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Revise paragraph 210.8(F) to read as follows:

210.8(F) Outdoor Outlets.

For dwellings, all outdoor outlets, other than those covered in 210.8(A), Exception No. 1, including outlets installed in the following locations, and supplied by single-phase branch circuits rated 150 volts or less to ground, 50 amperes or less, shall be provided with GFCI protection:

- (1) Garages that have floors located at or below grade level
- (2) Accessory buildings
- (3) Boathouses

If equipment supplied by an outlet covered under the requirements of this section is replaced, the outlet shall be supplied with GFCI protection.

Exception No. 1: GFCI protection shall not be required on lighting outlets other than those covered in 210.8(C).

Exception No. 2: GFCI protection shall not be required for listed HVAC equipment. This exception shall expire September 1, 2026.

Issue Date: August 12, 2022

Effective Date: September 1, 2022

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2022 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION