



Tentative Interim Amendment

NFPA[®] 70[®]

National Electrical Code[®]

2026 Edition

Reference: 690.12(C)
TIA 26-2
(SC 25-8-12 / TIA Log #1835)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise section 690.12(C) to read as follows:*

(C) Initiation Devices. Where circuits identified in 690.12(A) are required to meet the requirements in 690.12(B), initiation devices meeting the requirements in 690.12(C)(1) through 690.12(C)(3) shall be provided to initiate the rapid shutdown function.

(1) Type and Location.

(a) Initiation devices shall be readily accessible and consist of one or more of the following as specified in the rapid shutdown equipment instructions:

- (1) Service disconnecting means
- (2) PV system disconnecting means
- (3) Listed switches

(b) For one- and two-family dwellings, initiation devices, where required, shall be located at an outdoor location.

Issue Date: August 20, 2025

Effective Date: September 9, 2025

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION