



Tentative Interim Amendment

NFPA® 70®

National Electrical Code®

2026 Edition

Reference: 430.132(new)

TIA 26-3

(SC 25-8-13 / TIA Log #1843)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Add a new section 430.132 to read as follows:*

430.132 GFCI and SPGFCI Between Power Conversion Equipment and Motors. Ground-fault circuit interrupters and special purpose ground-fault circuit interrupters shall not be installed between power conversion equipment output terminals and the motor.

Issue Date: August 20, 2025

Effective Date: September 9, 2025

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION