Tentative Interim Amendment

NFPA® 70®

National Electrical Code®

2026 Edition

Reference: 505.30(A)
TIA 26-6
(SC 25-8-16 / TIA Log #1848)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Revise section 505.30(A) to read as follows:

505.30 Bonding in Hazardous (Classified) Locations.

(A) Specific Bonding Means Permitted.

Regardless of the voltage of the electrical system, the bonding of normally non-current-carrying metal parts of electrical equipment, raceways, metal-clad cable, and metal enclosures containing electrical equipment in any hazardous (classified) location through the point of grounding for service equipment or point of grounding for a separately derived system shall be provided by one or more of the following bonding means whether or not equipment grounding conductors of the wire type are installed in the raceway or in a multiconductor cable assembly:

(1) Connections made up wrenchtight using threaded couplings, threaded entries, or listed threaded hubs on enclosures
(2) Threadless couplings and connectors if made up tight for metal raceways and metal-clad cables
(3) Other listed devices, such as bonding-type locknuts, bushings, or bushings with bonding jumpers

Exception: Uninsulated exposed parts meeting the requirements of 505.19 shall not be subjected to this bonding requirement.

Issue Date: August 20, 2025

Effective Date: September 9, 2025

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo**)**
Copyright © 2025 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION