Tentative Interim Amendment

NFPA® 704

Standard System for the Identification of the Hazards of Materials for Emergency Response

2022 Edition

Reference: Annex Equation B.1b
TIA 22-1
(SC 26-4-17 / TIA Log #1877)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 704, *Standard System for the Identification of the Hazards of Materials for Emergency Response*, 2022 edition. The TIA was processed by the Technical Committee on Classification and Properties of Hazardous Chemical Data, and was issued by the Standards Council on April 15, 2026, with an effective date of May 5, 2026.

1. Revise Annex Equation B.1b to read as follows:

$$\text{SVC} = \frac{\text{Vapor pressure (mmHg)} \times 106}{760}$$

$$\text{SVC} = \frac{\text{Vapor pressure (mmHg)} \times 10^6}{760}$$

Issue Date: April 15, 2026

Effective Date: May 5, 2026

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo**)**
Copyright © 2026 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION