



Errata

NFPA 72

National Fire Alarm and Signaling Code®

2025 Edition

Reference: 26.2.11.1

Errata No: 72-25-1

The Technical Committee on Supervising Station Fire Alarm and Signaling Systems, notes the following error in the 2025 edition of NFPA 72, *National Fire Alarm and Signaling Code®*.

1. *Correct the cross reference in paragraph 26.2.11.1, from issued TIA 25-2, to read as follows:*

26.2.11.1 Where an auxiliary service provider (ASP) is used, the requirements of 26.2.11.2 through ~~26.2.11.8~~ 26.2.11.3 shall be met.

Issue Date: August 29, 2024

(Note: For current information about the NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2024 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION