



Tentative Interim Amendment

NFPA[®] 72[®]

National Fire Alarm and Signaling Code[®]

2025 Edition

Reference: 26.6.4.2.4.1 and A.26.6.4.2.4.1(new)

TIA 25-1

(SC 24-4-11/ TIA Log #1770)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. *Revise 26.6.4.2.4.1 to read as follows:*

26.6.4.2.4.1* A system employing a DACT that uses shall employ a single legacy POTS telephone line (number) shall also include and one of the following transmission means channels:

- (1) One-way private radio alarm system
- (2) Transmission means complying with 26.6.3
- (3) A second telephone line (number), where all of the following conditions are met:
 - a. Access to one of the technologies in 26.6.4.2.4.1(1); or 26.6.4.2.4.1(2); ~~or 26.6.4.2.4.1(3)~~ is not available at the protected premises.
 - b. The AHJ approves the arrangement.
 - c. The DACT is programmed to call a second DACR line (number) when the signal transmission sequence to the first called line (number) is unsuccessful.
 - d. The DACT is capable of selecting the operable means of transmission in the event of failure of the other means.
 - e. Each telephone line is tested in accordance with 26.6.4.2.4.2 or at alternating 6-hour intervals.

2. *Add a new A.26.6.4.2.4.1 to read as follows:*

A.26.6.4.2.4.1 The requirements in 26.6.4.2.4 are not intended to prevent a system using a DACT from employing two transmission channels from a managed facilities-based voice network (MFVN) in accordance with 26.6.4.2.1.

Issue Date: April 18, 2024

Effective Date: May 8, 2024

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2024 All Rights Reserved

NATIONAL FIRE PROTECTION ASSOCIATION