



Tentative Interim Amendment

NFPA[®] 750

Standard on Water Mist Fire Protection Systems

2023 Edition

Reference: 12.5.5.4

TIA 23-1

(SC 22-12-11 / TIA Log #1673)

Pursuant to Section 5 of the NFPA *Regulations Governing the Development of NFPA Standards*, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 750, *Standard on Water Mist Fire Protection Systems*, 2023 edition. The TIA was processed by the Technical Committee on Water Mist Fire Suppression Systems, and was issued by the Standards Council on December 8, 2022, with an effective date of December 28, 2022.

1. *Revise paragraph 12.5.5.4 to read as follows:*

12.5.5.4 For low-pressure water mist systems ~~with system design pressures less than or equal to 12 bar (175 psi)~~, the connection of the fire department connection to the system shall be made on the downstream (discharge) side of the pressure source component.

Issue Date: December 8, 2022

Effective Date: December 28, 2022

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2022 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION