



NATIONAL FIRE PROTECTION ASSOCIATION

The leading information and knowledge resource on fire, electrical and related hazards

AGENDA

NFPA Technical Committee on Venting Systems for Cooking Appliances (VEN-AAA) NFPA NFPA 96 Second Draft Meeting (A2026)

September 8th, 2025
11:00 a.m. – 5:00 p.m. (ET)

Microsoft Teams
To join the meeting, please contact Ylee@nfpa.org

1. **Call to order.** Stephen Hill.
2. **Introductions.** See committee roster attached.
3. **Staff liaison report.** Stephen Ganoe.
4. **Previous meeting minutes.** September 2024, Quincy, MA. See attached.
5. **Meeting Items.**
 - a. **Public Comment(s).** See attached.
 - b. **Committee Input(s).** See attached.
 - c. **Task Group(s).**
 - i. **Meat Smoking Task Group.**
 1. Scope: Review the PI's associated with Meat Smoking as submitted by Society Insurance and create requirements for solid fuel meat smoking appliances.
 2. Member: Dave de Vries (Chair), Chip Barnhart, Doc Reisman, Rob Carmichael, Derek Wester, Frank Norton, Mark Skierkiewicz, Kevin Richards.
 - ii. **CO Detector and Alarm in Kitchens and Food Trucks.**
 1. Scope: Review PI-47 and PI-49 and determine the appropriateness of detectors and alarms in kitchens and food trucks, adjust any requirements, and create annex material as needed..
 2. Member: Kurt Ruchala (Chair), Derek Wester, R. T. Leicht, Mark Skierkiewicz, Dave de Vries.
 - iii. **High Rise Exhaust Duct Requirements Review.**
 1. Scope: Review rooftop and wall termination clearance requirements and determine if the use of ecology units can reduce the clearances.

2. Member: Chip Barnhart (Chair), Jim Valentine, Frank Mitarotonda, Mark Skierkiewicz, Rob Carmichael, Chris Heiner, Ellen McFarland-Humphreys, Matt Gorrell.

6. Staff Items for Consideration

7. Other Business.

8. Future meetings.

9. Adjournment.

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoe
VEN-AAA

Stephen M. Hill SE 08/17/2017
Chair VEN-AAA
Hillfire Forensics, Inc.
P.O. Box 531
Olney, MD 20830-0531
Phone/Cell: 240-338-7599 240-338-7599
Fax:
Email : stevehill@hillfireforensics.com

Phil Ackland SE 1/1/1988
Principal VEN-AAA
Phillip Ackland Holdings Ltd.
11704 Prairie Valley Road
PO Box 856
Summerland, BC V0H 1Z0 Canada
Alternate: Michael A. Schlatman
Phone/Cell: 250-494-1361
Fax: 250-494-4216
Email : philjackland@gmail.com

Larry Angle IM 04/03/2019
Principal VEN-AAA
M. Jacks Fire & Safety
538 Sandau Road
San Antonio, TX 78216
National Association of Fire Equipment Distributors
Alternate: Ed Giles
Phone/Cell: 210-344-2361
Fax: 210-344-2616
Email : langle@mjacks.com

Ted Cabaniss I 10/23/2013
Principal VEN-AAA
QBE Insurance
128 West Woodglen Road
Spartanburg, SC 29301
Phone/Cell: 864-313-9772 864-313-9772
Fax:
Email : ted.cabaniss@us.qbe.com

Zainul Abedeen SE 04/02/2020
Principal VEN-AAA
WSP Middle East
2703 U Bora Tower
Business Bay
PO Box 7497
Dubai, DUBAI 7497 United Arab Emirates
Phone/Cell: 971-56412-7191 971-56412-7191
Fax: 971-6598-1777
Email : zainul.abedeen@wsp.com

Brian Anderson I 04/09/2025
Principal VEN-AAA
Society Insurance
W310s2736 Wild Rose Ln
Waukesha, WI 53188-9130
Alternate: Adam Olijnyk
Phone/Cell: 262-385-5497 920-204-1277
Fax:
Email : banderson386@yahoo.com

Corey Bartlett M 08/29/2024
Principal VEN-AAA
Van-Packer Company
302 Mill Street
Buda, IL 62314
Phone/Cell: 779-239-9775 779-239-9775
Fax:
Email : region2kvp@vpstack.com

Robert Carmichael, P.E M 04/02/2020
Principal VEN-AAA
Gaylord Industries
303 Hillpine Drive
Woodstock, GA 30189
Alternate: Bruce Lukens
Phone/Cell: 770-265-2562 770-265-2562
Fax:
Email : rob.carmichael@gaylordventilation.com

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoë
VEN-AAA

Mark T. Conroy M 3/2/2010
Principal VEN-AAA
Brooks Equipment Company
3229 Cranberry Highway
Suite 5
Buzzards Bay, MA 02532
Alternate: Paul Erickson
Phone/Cell: 774-274-7461
Fax:
Email : mconroy@brooksequipment.com

David A. de Vries SE 04/03/2019
Principal VEN-AAA
Firetech Engineering Inc.
8052 Monticello Avenue
Suite 202
Skokie, IL 60076-3438
International Association of Arson Investigators, Inc.
Alternate: William (Chip) Cyrus Barnhart
Phone/Cell: 224-251-7228 773-315-6035
Fax:
Email : dave@firetecheng.net

Robert Andrew Diaz L 04/09/2025
Principal VEN-AAA
SMART Local 88 Sheet Metal Workers
2560 Marco Street
Las Vegas, NV 89115
Phone/Cell: 725-279-3070 725-279-3070
Fax: 702-452-7284
Email : rdiaz@smw88.org

W. Nelson Dilg IM 9/30/2004
Principal VEN-AAA
Nelbud Services Group
160 5th Avenue
Estell Manor, NJ 08319
International Kitchen Exhaust Cleaning Association
Alternate: Frank Mitarotonda
Phone/Cell: 609-703-1770
Fax:
Email : wndilg@hotmail.com

Christopher Grant Driesel M 04/09/2025
Principal VEN-AAA
Greenheck Group
6610 East 108th Street
Tulsa, OK 74133
Phone/Cell: 918-574-1886 918-574-1886
Fax:
Email : cdriesel@gmail.com

Scott Eckstein E 12/04/2024
Principal VEN-AAA
Richardson Fire Department
300 N. Greenville Avenue
Richardson, TX 75081
Phone/Cell: 972-744-5750
Fax:
Email : scott.eckstein@cor.gov

Bruce J. Euler M 04/09/2025
Principal VEN-AAA
Buckeye Fire Equipment Company
110 Kings Road
PO Box 428
Kings Mountain, NC 28086-0428
Fire Equipment Manufacturers' Association
Alternate: Derek P. Wester
Phone/Cell: 704-739-7415
Fax: 704-739-7418
Email : beuler@buckeyef.com

David Lee Hensel SE 12/07/2018
Principal VEN-AAA
SSA Foodservice Consultants
601 S Harbour Island Boulevard
Suite 211
Tampa, FL 33602
Foodservice Consultants Society International (FCSI)
Phone/Cell: 813-575-6907 813-966-1882
Fax:
Email : david@studiofs.com

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoe
VEN-AAA

Christopher M. Hiener E 08/09/2012
Principal VEN-AAA
Union Fire District of South Kingstown
131 Asa Pond Road
Wakefield, RI 02879
Phone/Cell: 401-789-8354 401-255-5921
Fax: 401-789-8750
Email : chiener@unionfiredistrict.com

Joseph W. Kuesis M 08/10/2022
Principal VEN-AAA
Flame Guard USA
1000 Butterfield Road
Suite 1029
Vernon Hills, IL 60061
Phone/Cell: 815-219-4074 815-382-2581
Fax: 847-387-3824
Email : jkuesis@flameguardusa.com

R. T. Leicht E 1/1/1992
Principal VEN-AAA
Springfield Township
4 Drummond Drive
Wilmington, DE 19808
International Fire Marshals Association (IFMA)
Alternate: John W. Rudd
Phone/Cell: 302-892-9071 302-438-5900
Fax:
Email : deputy44@aol.com

Richard T. Long, Jr. SE 04/14/2021
Principal VEN-AAA
Exponent, Inc.
17000 Science Drive
Suite 200
Bowie, MD 20715-4427
Alternate: Joshua Swann
Phone/Cell: 301-291-2501 443-994-4327
Fax: 301-291-2599
Email : tommylong1856@hotmail.com

June M. Kearney E 08/03/2016
Principal VEN-AAA
Philadelphia Fire Department
240 Spring Garden Street
Philadelphia, PA 19123-2923
Phone/Cell: 215-686-1356 215-285-7985
Fax: 215-686-1167
Email : June.Kearney@phila.gov

David Larson U 04/02/2020
Principal VEN-AAA
Hoodz of Clackamas
310 Lola Avenue
Molalla, OR 97038
Phone/Cell: 971-804-4546 503-406-0812
Fax:
Email : davidlarson325@gmail.com

Steven F. Levin SE 1/15/1999
Principal VEN-AAA
1758 Cedar Glen Drive
Libertyville, IL 60048
Phone/Cell: 847-573-9020
Fax: 847-573-9027
Email : banjopicker93@yahoo.com

Brian McBain E 11/29/2023
Principal VEN-AAA
Russell Township Fire Services
1128 Route 300
Embrun, ON K0A 1W0 Canada
Phone/Cell: 613-443-4250 613-295-1617
Fax:
Email : brianmcbain@russell.ca

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoe
VEN-AAA

Ellen McFarland-Humphreys **E** 08/03/2016
Principal **VEN-AAA**
LA Office Of The Fire Marshal
8181 Independence Boulevard
Plan Review
Baton Rouge, LA 70808
Phone/Cell: 225-925-4920
Fax: 225-925-4414
Email : ellen.mcfarland@la.gov

Shaun Ray **M** 1/14/2005
Principal **VEN-AAA**
Metal-Fab, Inc.
PO Box 1138
Wichita, KS 67201-1138
Air-Conditioning, Heating, & Refrigeration Institute (AHRI)
Phone/Cell: 316-771-4134
Fax: 316-771-4135
Email : shaunr@mtlfab.com

Kevin Richards **M** 12/02/2020
Principal **VEN-AAA**
Carrier/Kidde Fire Systems
400 Main Street
Ashland, MA 01721
Alternate: Richard L. Lupien
Phone/Cell: 508-231-2747 508-596-9871
Fax:
Email : kevin.richards@carrier.com

Kurt A. Ruchala **SE** 3/1/2011
Principal **VEN-AAA**
Jensen Hughes
100 Quannapewitt Parkway
Suite 401
Wakefield, MA 01880
Alternate: Stefan Kraft
Phone/Cell: 781-270-5200
Fax: 781-229-2922
Email : kruchala@jensenhughes.com

Daryl Mirza **IM** 04/04/2017
Principal **VEN-AAA**
Roof Top Solutions
2019 Corporate Lane, Suite 119
Naperville, IL 60560
Power Washers of North America
Phone/Cell: 800-913-7034 847-309-9794
Fax:
Email : daryl.mirza@averus.com

M. D. "Doc" Reisman **IM** 12/08/2015
Principal **VEN-AAA**
Averus, Inc.
3851 Clearview Court
Gurnee, IL 60031-1247
Certified Hood & Duct Cleaners Association
Alternate: Tracy Ashmore
Phone/Cell: 800-393-8287 847-922-4921
Fax:
Email : doc.reisman@averus.com

Christopher A. Roth **E** 08/09/2012
Principal **VEN-AAA**
Town of Brighton
2300 Elmwood Avenue
Rochester, NY 14618-2145
Phone/Cell: 585-784-5220
Fax: 585-784-5207
Email : christopher.roth@townofbrighton.org

Timothy Dwain Schmidle **I** 08/11/2020
Principal **VEN-AAA**
Liberty Mutual Group Prop
489 S Smyser Rd
Wooster, OH 44691
Phone/Cell: 440-788-4269 330-466-7102
Fax: 603-334-8030
Email : timothy.schmidle@libertymutual.com

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoe
VEN-AAA

Gabriel Senechal M 04/09/2025
Principal VEN-AAA
Cercocable and CL4 Fire
9245 Ch Cote De Liesse
Dorval, QC H9P2N9 Canada
Phone/Cell: 514-718-9150 514-718-9150
Fax:
Email : gsenechal@cercocable.com

James F. Valentine, Jr. IM 4/16/1999
Principal VEN-AAA
James F. Valentine, Jr., Inc.
300 Thomas Ave. Building 401
PO Box 1160
Williamstown, NJ 08094
Alternate: Christopher Lee
Phone/Cell: 888-273-6644 X105 856-784-6077
Fax: 856-782-7031
Email : jvalentine@valentineassoc.com

Christopher M. Campion IM 12/04/2024
Voting Alternate VEN-AAA
Eastern Fire & Safety, LLC
914 Woodcrest Drive
Spring Lake Heights, NJ 07762-2250
American Fire Sprinkler Association
Phone/Cell: 732-681-0911 732-216-1878
Fax: 732-359-1571
Email : CCampion@EasternFireSafety.com

Tracy Ashmore IM 08/09/2012
Alternate VEN-AAA
Certified Hood & Duct Cleaners Association
12010 McGhee Road
PO Box 68
Apison, TN 37302
Principal: M. D. "Doc" Reisman
Phone/Cell: 423-236-5803
Fax: 423-236-5803
Email : hoodcleaners@gmail.com

Dwayne E. Sloan RT 8/9/2011
Principal VEN-AAA
UL Solutions
12 Laboratory Drive
PO Box 13995
Research Triangle Park, NC 27709-3995
Alternate: Blake M. Shugarman
Phone/Cell: 919-549-1676
Fax:
Email : Dwayne.E.Sloan@ul.com

Adam D. Walker M 04/11/2018
Principal VEN-AAA
Johnson Controls
One Stanton Street
Marinette, WI 54143-2542
National Fire Sprinkler Association
Alternate: Jeffery Charles Dunkel
Phone/Cell: 715-735-7411 x84156
Fax: 715-732-3479
Email : adam.walker@jci.com

Michael Rader E 07/29/2013
Voting Alternate VEN-AAA
Parkland Hospitals
300 Marshall Creek Road
Roanoke, TX 76262
Phone/Cell: 214-590-4771 817-692-4214
Fax: 214-590-2763
Email : Fireradar@duck.com

William (Chip) Cyrus Barnhart SE 08/24/2021
Alternate VEN-AAA
Barnhart Consulting Services
P.O. Box 40
Whitewood, SD 57793
International Association of Arson Investigators, Inc.
Principal: David A. de Vries
Phone/Cell: 585-690-5325 585-690-5325
Fax:
Email : chipbarnhart@gmail.com

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoë
VEN-AAA

Jeffery Charles Dunkel M 08/24/2021
Alternate VEN-AAA
National Fire Sprinkler Association (NFSA)
30775 Explorers Trail
Desoto, KS 66018
Principal: Adam D. Walker
Phone/Cell: 918-519-3481 918-519-3481
Fax:
Email : dunkel@nfsa.org

Ed Giles IM 12/07/2022
Alternate VEN-AAA
Certasite
510 Witbeck Drive
Clare, MI 48617
National Association of Fire Equipment Distributors:
Principal: Larry Angle
Phone/Cell: 989-289-1700 989-289-1700
Fax:
Email : egiles@certasitepro.com

Christopher Lee IM 08/29/2024
Alternate VEN-AAA
Valentine & Associates
100 Oakview Drive
Kerrville, TX 78028
Principal: James F. Valentine, Jr.
Phone/Cell: 830-890-0322 830-370-5806
Fax:
Email : Clee@valentineassoc.com

Richard L. Lupien M 08/24/2021
Alternate VEN-AAA
Carrier/Kidde-Fenwal, Inc.
400 Main Street
Ashland, MA 01721-2150
Principal: Kevin Richards
Phone/Cell: 508-231-2547 508-308-3756
Fax:
Email : richard.lupien@carrier.com

Paul Erickson M 04/12/2022
Alternate VEN-AAA
Heiser Logistics/ Beco Holding Company (BHC)
5238 CR-37
Hemlock, NY 14466
Principal: Mark T. Conroy
Phone/Cell: 585-738-8634 585-738-8634
Fax:
Email : pce5238@gmail.com

Stefan Kraft SE 11/29/2023
Alternate VEN-AAA
Jensen Hughes
2020 Kraft Drive, Suite 3020
Blacksburg, VA 24060
Principal: Kurt A. Ruchala
Phone/Cell: 540-808-2800 540-386-9057
Fax:
Email : skraft@jensenhughes.com

Bruce Lukens M 03/05/2012
Alternate VEN-AAA
Gaylord Industries
10900 SW Avery Street
Tualatin, OR 97062-8578
Principal: Robert Carmichael, P.E
Phone/Cell: 971-223-1247
Fax: 503-692-6048
Email : bruce.lukens@gaylordventilation.com

Frank Mitarotonda IM 08/17/2018
Alternate VEN-AAA
Chief Fire Prevention
3815 Wahoo Drive
St. Augustine, FL 32084-1770
International Kitchen Exhaust Cleaning Association
Principal: W. Nelson Dilg
Phone/Cell: 914-699-3557 917-559-6032
Fax: 914-699-0707
Email : frankm@powerhousefundings.com

Address List

Venting Systems for Cooking Appliances

08/07/2025
Stephen Ganoë
VEN-AAA

Adam Olijnyk I 04/09/2025
Alternate VEN-AAA
Society Insurance
2340 Fir Street
Janesville, WI 53546
Principal: Brian Anderson
Phone/Cell: 262-510-7348 262-510-7348
Fax:
Email : aolijnyk@societyinsurance.com

Michael A. Schlatman SE 04/05/2016
Alternate VEN-AAA
FCII
10049 Lakeview Avenue
Lenexa, KS 66219
Principal: Phil Ackland
Phone/Cell: 913-262-5200
Fax: 913-262-5202
Email : mschlatman@fcifire.com

Joshua Swann SE 12/04/2024
Alternate VEN-AAA
Exponent, Inc.
17000 Science Drive, Suite 200
Bowie, MD 20715
Principal: Richard T. Long, Jr.
Phone/Cell: 301-291-2561 410-300-6696
Fax:
Email : jswann@exponent.com

Russell P. Fleming IM 03/05/2012
Nonvoting Member VEN-AAA
Northeast Fire Suppression Associates, LLC
157 School Street
Keene, NH 03431
Phone/Cell: 914-282-5081
Fax:
Email : fleming.nfsa@gmail.com

John W. Rudd E 10/4/2001
Alternate VEN-AAA
Delaware State Fire Marshal Office
2307 MacArthur Road
New Castle, DE 19720
International Fire Marshals Association (IFMA)
Principal: R. T. Leicht
Phone/Cell: 302-323-5365
Fax: 302-323-5366
Email : jrudd@state.de.us

Blake M. Shugarman RT 8/9/2011
Alternate VEN-AAA
UL LLC
333 Pfingsten Road
Northbrook, IL 60062-2096
Principal: Dwayne E. Sloan
Phone/Cell: 847-664-2022
Fax:
Email : blake.m.shugarman@ul.com

Derek P. Wester M 12/07/2021
Alternate VEN-AAA
Amerex Corporation
7595 Gadsden Highway
PO Box 81
Trussville, AL 35173-0081
Fire Equipment Manufacturers' Association
Principal: Bruce J. Euler
Phone/Cell: 205-655-3271 x269 205-577-6984
Fax: 205-661-4142
Email : derek.wester@amerex-fire.com

Stephen Ganoë 10/14/2020
Staff Liaison VEN-AAA
National Fire Protection Association
1 Batterymarch Park
Quincy, MA 02169-7471
Phone/Cell:
Fax:
Email : sganoë@nfpa.org



NATIONAL FIRE PROTECTION ASSOCIATION

The leading information and knowledge resource on fire, electrical and related hazards

MEETING MINUTES

NFPA Technical Committee on Venting Systems for Cooking Appliances (VEN-AAA) NFPA 96 First Draft Meeting (A2026)

September 9-10, 2024
8:00 am – 5:00 pm (ET)

NFPA Headquarters, Quincy, MA

1. **Call to order.** Steve Hill, chair, called the meeting to order at 8:00 am on 9/9/2024.
2. **Introductions.** Attendees introduced themselves and identified their affiliation and staff took attendance.
3. **Chair report.** Steve Hill welcomed attendees and provided an overview of the meeting.
4. **Staff liaison report.** Stephen Ganoë provided an overview of the standards development process and the revision cycle schedule and reviewed the scope of both the committee and NFPA 96.
 - a. The following members declared that they had been retained to represent the interest of an entity that would be classified in an interest category different from their own with respect to a specific issue or issues that were addressed by the committee.

Kurt Ruchala – Restaurant Technologies Inc.
5. **Previous meeting minutes.** The minutes from September 2022, Microsoft Teams were approved with the following revisions: Doc Reisman did attend but was shown as not attending.
6. **NFPA 96 First Draft.**
 - a. **Review of Public Inputs.** The Technical Committee reviewed the Public Inputs and developed Committee Inputs and First Revisions as necessary. These will be available in the First Draft Report at www.nfpa.org/96.
 - b. **Reconstituted Task Group(s).** The following task groups provided their reports and recommendations and have been reconstituted to continue their work:
 - i. **High Rise Exhaust Duct Requirements Review.**
 1. Review rooftop and wall termination clearance requirements and determine if the use of ecology units can reduce the clearances.
 2. TG Chair: Chip Barnhart. Members: Jim Valentine, Frank Mitarotonda, Mark Skierkiewicz, Rob Carmichael, Chris Heiner, Ellen McFarland-Humphreys, Matt Gorrell.

These minutes are considered preliminary until approved at the next committee meeting.

3. The committee did not have anything to report.
- c. **New Task groups.** The following task groups were appointed to work subsequent to the meeting:
 - i. **Meat Smoking Task Group.**
 1. Review the PI's associated with Meat Smoking as submitted by Society Insurance and create requirements for solid fuel meat smoking appliances.
 2. TG Chair: Dave de Vries Members: Chip Barnhart, Doc Reisman, Rob Carmichael, Derek Wester, Frank Norton, Mark Skierkiewicz, Kevin Richards
 - ii. **CO Detector and Alarm in Kitchens and Food Trucks.**
 1. Review PI-47 and PI-49 and determine the appropriateness of detectors and alarms in kitchens and food trucks, adjust any requirements, and create annex material as needed.
 2. Chair: Kurt Ruchala Members: Derek Wester, R. T. Leicht, Mark Skierkiewicz, Dave de Vries
- d. **Discharged Task Groups.** The following task groups provided a report and have been discharged with thanks:
 - i. **Responsibility for Inspection, Testing, Maintenance, and Cleanliness from Owner to Another Party.**
 1. Review and clarify requirements in regard to inspection, testing, cleaning, and repairs of systems and equipment.
 2. TG Chair: Dave de Vries. Members: Frank Mitarotonda, Chip Barnhart, David Hensel, Derek Wester, Doc Reisman, James Valentine, Nelson Dilg, Phil Ackland, R. T. Leicht, Stephen Hill.
- e. **Presentation(s).** The committee heard presentations from the following individuals.
 - i. **Cleaning Detergents and Water Wash Hoods.** Kurt Ruchala. Presentation attached.
7. **Other Business.**

Frank Mitarotonda discussed how IKECA standards are presented in the standard, the TC did not make any changes document.

The committee would like to solicit members of the restaurant industry to apply to the technical committee.
8. **Future meetings.** The next committee meeting will be Summer 2025. A meeting notification will be posted at www.nfpa.org/96next when the meeting is scheduled.

9. **Adjournment.** The meeting was adjourned at 12:00 pm on 9/10.

Attendees

Committee Members:

✓	Stephen M. Hill	Chair	Hillfire Forensics, Inc.
✓	Phil Ackland*	Principal	Phillip Ackland Holdings Ltd.
✓	Shaun Ray*	Principal	Metal-Fab, Inc.
✓	Mark T. Conroy	Principal	Brooks Equipment Company
·	Dwayne E. Sloan	Principal	UL LLC
·	James F. Valentine, Jr.	Principal	James F. Valentine, Jr., Inc.
·	Christopher M. Hiener	Principal	Union Fire District of South Kingstown
✓	M. D. "Doc" Reisman	Principal	Averus, Inc.
✓	Ellen McFarland-Humphreys*	Principal	LA Office Of The Fire Marshal
✓	June M. Kearney*	Principal	Philadelphia Fire Department
·	Daryl Mirza	Principal	Roof Top Solutions
✓	Adam D. Walker*	Principal	Johnson Controls
✓	Steven F. Levin	Principal	
·	David Lee Hensel	Principal	SSA Foodservice Consultants
·	W. Nelson Dilg	Principal	Nelbud Services Group
✓	Larry Angle	Principal	M. Jacks Fire & Safety
✓	Bruce Lukens*	Principal	Gaylord Industries
✓	Zainul Abedeen*	Principal	WSP Middle East
·	David Larson	Principal	Hoodz of Clackamas
·	Timothy Dwain Schmidle	Principal	Liberty Mutual Group Prop
✓	Kevin Richards	Principal	Carrier/Kidde Fire Systems
✓	Tom Long, Jr.*	Principal	Exponent, Inc.
✓	David A. de Vries	Principal	Firetech Engineering Inc.
✓	Kurt A. Ruchala	Principal	JENSEN HUGHES
✓	R. T. Leicht	Principal	Springfield Township
✓	Ted Cabaniss*	Principal	QBE Insurance
·	Joseph W. Kuesis	Principal	Flame Guard USA
✓	Scott Futrell	Principal	KFI Engineers
✓	Brian McBain*	Principal	Russell Township Fire Services
·	Christopher A. Roth	Principal	Town of Brighton
·	Corey Bartlett	Principal	Van-Packer Company
·	Michael Rader	Voting Alternate	Parkland Hospitals
✓	Derek P. Wester	Voting	Amerex Corporation

Attendees

Committee Members:

		Alternate	
·	Blake M. Shugarman	Alternate	UL LLC
·	Tracy Ashmore	Alternate	Certified Hood & Duct Cleaners Association
·	Michael A. Schlatman	Alternate	FCII
✓	Frank Mitarotonda	Alternate	Chief Fire Prevention
✓	Robert Carmichael, P.E.*	Alternate	Gaylord Industries
✓	William (Chip) Cyrus Barnhart*	Alternate	Barnhart Consulting Services
✓	Richard L. Lupien	Alternate	Carrier/Kidde-Fenwal, Inc.
·	Jeffery Charles Dunkel	Alternate	National Fire Sprinkler Association (NFSA)
✓	Paul Erickson*	Alternate	Heiser Logistics/ Beco Holding Company (BHC)
·	John W. Rudd	Alternate	Delaware State Fire Marshal Office
✓	Ed Giles*	Alternate	Certasite
✓	Kevin R. Hall*	Alternate	American Fire Sprinkler Association (AFSA)
✓	Stefan Kraft*	Alternate	Jensen Hughes
·	Christopher Lee	Alternate	Valentine & Associates
·	Russell P. Fleming	Nonvoting Member	Northeast Fire Suppression Associates, LLC
✓	Stephen Ganoe	Staff Liaison	NFPA

Guests:

Jamie Gardner	Restaurant Technologies
Nathan Meyer	Restaurant Technologies
Brian Anderson*	Society Insurance
Frank Norton*	Society Insurance
Speedy Laster*	Phillip Ackland Holdings Ltd.
Charlie Thomas*	Society Insurance
Pat O'Brien*	Society Insurance
David Pelton*	NAFED
Mark Skierkiewicz*	UL
Miguel Aguilera*	NYFD
Thomas Kolman*	Restaurant Technologies

*Participated by teleconference

Total number in attendance: 41



Public Comment No. 3-NFPA 96-2025 [Section No. 2.3.3]

2.3.3 UL Publications.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

CAN/UL 144, *Standard for Safety LP-Gas Regulators*, 2024.

UL 197, *Commercial Electric Cooking Appliances*, 2010, revised 2023.

UL 263, *Fire Tests of Building Construction and Materials*, 2011, revised 2022.

ANSI/CAN/UL/ULC 300, *Fire Testing of Fire Extinguishing Systems for Protection of Commercial Cooking Equipment*, 2024.

UL 499, *Electric Heating Appliances*, 2014.

UL 705, *Power Ventilators*, 2022 revised 2024 .

UL 710, *Exhaust Hoods for Commercial Cooking Equipment*, 2024.

UL 710A, *Safety for Rooftop Grease and Oil Collection and Containment Systems*, 2015.

UL 710B, *Recirculating Systems*, 2011, revised 2021.

UL 723, *Test for Surface Burning Characteristics of Building Materials*, 2023.

UL 1046, *Grease Filters for Exhaust Ducts*, 2010, revised 2022.

UL 1479, *Fire Tests of Through-Penetration Firestops*, 2015, revised 2024.

UL 1484, *Residential Gas Detectors*, 2016, revised 2022.

UL 1889, *Commercial Filters for Cooking Oil*, 2024.

UL 1978, *Grease Ducts*, 2010, revised 2024.

UL 2221, *Tests of Fire Resistive Grease Duct Enclosure Assemblies*, 2010, revised 2014.

UL 8782, *Outline of Investigation for Pollution Control Units for Commercial Cooking Operations*, 2017.

Statement of Problem and Substantiation for Public Comment

latest revision ANSI approved is dated September 16, 2024 per UL website. https://www.shopulstandards.com/ProductDetail.aspx?productId=UL705_7_S_20170719

Related Item

- Public Input No. 36-NFPA 96-2024 [Section No. 8.1.1]

Submitter Information Verification

Submitter Full Name: Alfonso Doblado

Organization: Marriott

Street Address:

City:

State:

Zip:

Submission Date: Thu Mar 06 14:10:54 EST 2025

Committee:

VEN-AAA



Public Comment No. 14-NFPA 96-2025 [Section No. 2.3.6]

2.3.6 Other Publications.

ASME, *Boiler and Pressure Vessel Code*, 2023.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2020.

[ANSI / IKECA C10, Standard for Methodology for Cleaning of Commercial Cooking Exhaust Systems 2nd Edition 2021](#)

[ANSI / IKECA I10, Standard for the Methodogy for Inspection of Commercial Exhaust Systems 2nd Edition 2020](#)

[International Kitchen Exhaust Cleaning Association](#)

[2331 Rock Spring Road](#)

[Forest Hill, MD 21050](#)

[USA](#)

Statement of Problem and Substantiation for Public Comment

The included publications are referenced in the Annex with a Public Input provided to move them from the Annex to the body of the Standard. The ANSI / IKECA C10 and I10 are both Nationally recognized accredited publications accepted by Authority Having Jurisdiction (AHJ). The Standards provide guidance in the execution of minimum safety standards for Industry when performing cleaning and inspections.

Related Item

- 12.4.4, 12.6.1

Submitter Information Verification

Submitter Full Name: Frank Mitarotonda

Organization:

Affiliation: International Exhaust Cleaning Association (IKECA)

Street Address:

City:

State:

Zip:

Submittal Date: Tue May 20 11:29:10 EDT 2025

Committee: VEN-AAA



Public Comment No. 17-NFPA 96-2025 [Section No. 2.3.6]

2.3.6 Other Publications.

ASME, *Boiler and Pressure Vessel Code*, 2023.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2020.

SMACNA, HVAC Systems Testing, Adjusting & Balancing Manual, 4th Edition, 2023

Statement of Problem and Substantiation for Public Comment

The addition of the SMACNA HVAC Systems Testing, Adjusting & Balancing (TAB) Manual, 4th Edition into NFPA 96 will provide a nationally recognized, technically validated resource to support code users, contractors, and Authorities Having Jurisdiction (AHJs) in meeting the airflow and ventilation performance requirements prescribed throughout the standard.

NFPA 96 establishes preventive and operational fire safety requirements for commercial cooking operations, including critical requirements for airflow balance, replacement air, exhaust performance, and safety interlocks that directly impact fire safety. These functions are dependent on proper system balancing and verification at commissioning, after cleaning, and during ongoing maintenance.

The newly revised 4th edition of the SMACNA HVAC Systems Testing, Adjusting & Balancing Manual incorporates up-to-date procedures for modern HVAC systems, including hydronic, forced air, and hybrid designs that are increasingly utilized in commercial kitchens and associated spaces. The manual provides:

Standardized TAB procedures for verifying airflow volumes and velocities.

Sample forms for reporting TAB results that support documentation for AHJs.

Updated practices for adjustment of dampers, diffusers, and airflow control devices critical to ventilation fire safety.

Defined skill level requirements for trained and qualified TAB technicians, ensuring competency in balancing work affecting fire protection systems.

Incorporating the SMACNA TAB Manual as a referenced resource will directly support and clarify compliance with the following NFPA 96 sections where airflow performance directly affects safety outcomes:

8.2.1 – Air Velocity

8.2.2 – Air Volume

8.3 – Replacement Air

12.6.11 – Dampers and Diffusers shall be positioned for proper airflow

12.6.12 – Restoration of system components to operable state after cleaning

15.6 – Air Movement for Solid Fuel Cooking

16.3 – Airflow Switch or Transducer

By referencing the SMACNA TAB Manual, NFPA 96 will strengthen its technical foundation, support uniform enforcement by AHJs, and improve safety outcomes by ensuring that airflow-dependent fire safety measures are tested, adjusted, and documented using nationally accepted practices.

Related Item

- 4.1.4.1 Pubic Input No 56

Submitter Information Verification

Submitter Full Name: Christopher Ruch

Organization: SMART, SMW Local Union No. 104

Affiliation: SMART, SMW Local Union No. 104

Street Address:

City:

State:

Zip:

Submittal Date: Fri May 30 13:00:01 EDT 2025

Committee: VEN-AAA



Public Comment No. 18-NFPA 96-2025 [Section No. 2.3.6]

2.3.6 Other Publications.

ASME, *Boiler and Pressure Vessel Code*, 2023.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2020.

[ANSI/SMACNA, HVAC Air Duct Leakage Test Manual, 2nd Edition, 2012](#)

Statement of Problem and Substantiation for Public Comment

Section 7.5.2.1.2 requires performing a leakage test prior to concealment of any portion of a grease duct system, this standard reference would provide the AHJ and installing contractor relevant guidance on how to perform such a test. The Annex section (A.7.5.2.1.2) suggests referring to ASHRAE 154 for guidance, however that standard no longer provides guidance on the light test or other approved equivalent tests, such as pressure testing.

Related Item

- FR-51

Submitter Information Verification

Submitter Full Name: Jeremy Zeedyk

Organization: Western States Council of SMART

Street Address:

City:

State:

Zip:

Submission Date: Fri May 30 13:00:21 EDT 2025

Committee: VEN-AAA



Public Comment No. 19-NFPA 96-2025 [New Section after 3.3.41]

3.3.41.1 Qualified Person. A person who, by possession of a recognized degree, certificate, professional standing, or skill, and who, by knowledge, training, and experience, has demonstrated the ability to deal with the subject matter, the work, or the project as acceptable to the AHJ.

Statement of Problem and Substantiation for Public Comment

Clarification of the definition of a “Qualified Person” is necessary to support consistent enforcement and assist the Authority Having Jurisdiction (AHJ) in evaluating whether an individual possesses the necessary credentials, experience, and technical expertise. Clear criteria are critical to ensure that individuals performing installation, operation, inspection, testing, and maintenance of commercial cooking ventilation systems are competent to do so, given the direct fire and life safety risks involved. NFPA 80 and NFPA 105 both provide this definition to assist AHJs in determining qualification requirements for personnel performing inspections and maintenance of fire and smoke dampers. Incorporating similar language into NFPA 96 promotes consistency across related NFPA standards and aligns the expectations for personnel qualifications.

The addition of the phrase “as acceptable to the AHJ” ensures that enforceable minimum qualifications can be established while preserving the AHJ’s authority to consider regional licensing, certification, or competency programs that meet the intent of the standard. This approach balances national consistency with local flexibility, ultimately improving safety, compliance, and clarity for all stakeholders involved.

Related Item

- Public Input No. 50-NFPA 96-2024 [Section No. 3.3]

Submitter Information Verification

Submitter Full Name: Christopher Ruch
Organization: SMART, SMW Local Union No. 104
Affiliation: SMART, SMW Local Union No. 104
Street Address:
City:
State:
Zip:
Submittal Date: Fri May 30 13:24:41 EDT 2025
Committee: VEN-AAA



Public Comment No. 20-NFPA 96-2025 [New Section after 4.1.2]

4.1.2.1 The required rate of airflow, as determined by the most recently approved design documents, of the associated ventilation systems shall be physically verified by a certified qualified person at least every 5 years.

Statement of Problem and Substantiation for Public Comment

The addition of a requirement to physically verify the required rate of airflow at least every five years is necessary to ensure that the ventilation system continues to perform in accordance with its original design intent and to maintain the safety functions directly addressed throughout NFPA 96. While Section 4.1.3 states that various equipment, including fans, shall be kept in working condition and Section 4.1.4 states that airflows shall be maintained, this language alone does not provide sufficient procedural direction for verifying whether systems are still in working condition and operating as originally designed.

Multiple provisions within NFPA 96 are explicitly dependent on proper airflow functioning:

8.2.2.1: Exhaust air volumes must be sufficient to capture and remove grease-laden vapors.

8.2.2.3: Exhaust air volumes may be reduced during no-load conditions, but still must maintain capture of flue gases and vapors.

8.3.1: Replacement air must prevent excessive negative pressure (greater than 0.02 in. w.c.).

12.6.11 Dampers and diffusers shall be positioned for proper airflow

12.6.12 Upon completion of exhaust system inspection and cleaning, all electrical switches and components shall be returned to an operable state

15.6.2 A replacement or makeup air system shall be provided to ensure a positive supply of replacement air at all times during cooking operations.

16.3.2 The airflow switch or transducer shall open the interlock circuit when the airflow falls 25 percent below the system's normal operating flow or 10 percent below its listed minimum rating, whichever is first.

If airflow rates diminish over time due to equipment degradation, changes in system settings, or improper maintenance, these sections may no longer be satisfied, increasing the risk of grease accumulation, combustion hazards, poor indoor air quality, and impaired fire safety performance.

The proposed five-year verification requirement aligns with existing periodic inspection and

maintenance requirements already established in NFPA 96 for other critical fire protection components. For example:

12.2.1 Maintenance of the fire-extinguishing systems and listed exhaust hoods containing a constant or fire-activated water system that is listed to extinguish a fire in the grease removal devices, hood exhaust plenums, and exhaust ducts shall be made by properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction at least every 6 months.

12.3.3 Replacement of Fusible Links.

12.3.3.1 Fusible links on fire damper assemblies shall be replaced at least semiannually or more frequently as necessary.

12.3.3.2 Replacement shall be made by a certified person acceptable to the authority having jurisdiction.

12.4 Inspection for Grease Buildup.

The entire exhaust system shall be inspected for grease buildup by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction and in accordance with Table 12.4.

12.6.1 If, upon inspection, the exhaust system is found to be contaminated with deposits from grease-laden vapors, the contaminated portions of the exhaust system shall be cleaned by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction.

12.7 Cooking Equipment Maintenance.

12.7.1 Inspection and servicing of the cooking equipment shall be made at least annually by properly trained and qualified persons.

14.6.5 Inspection and testing of the total operation and all safety interlocks in accordance with the manufacturer's instructions shall be performed by qualified service personnel a minimum of once every 6 months or more frequently if required.

This proposal simply provides equivalent periodicity for verifying the mechanical ventilation performance that directly supports and interacts with these safety features.

The requirement for a certified, qualified person would provide the AHJ much needed guidance on what level of expertise the individual(s) making measurement of critical airflows should have. It also aligns with many existing sections of NFPA 96 utilizing such criteria for critical life safety tasks, such as:

4.2.4.2 In the event of a fire within a kitchen exhaust system, the duct and its enclosure (rated shaft, factory-built grease duct enclosure, or field-applied grease duct enclosure) shall be inspected by qualified personnel to determine whether the duct and protection method are structurally sound, capable of maintaining their fire protection function, and in compliance with this standard for continued operation.

7.7.3.3 In the event of a fire within a kitchen exhaust system, the duct, the enclosure, and the covering directly applied to the duct shall be inspected by qualified personnel to determine whether the duct, the enclosure, and the covering directly applied to the duct are structurally sound, capable of maintaining their fire protection functions, suitable for continued operation, and acceptable to the authority having jurisdiction.

10.2.7.4 Changes or modifications to the hazard area including cooking appliances after installation of the fire-extinguishing systems shall result in re-evaluation of the system design by a properly trained, qualified, and certified person(s).

10.8.2.1 Installation of systems shall be performed only by persons properly trained and qualified to install the specific system being provided.

11.2.3.4 Changes or modifications to the hazard after installation of the fire-extinguishing systems shall result in re-evaluation of the system design by a properly trained, qualified, and certified person(s).

11.6.2.1 Installation of systems shall be performed only by persons properly trained and qualified to install the specific system being provided.

12.1.8 Inspection and maintenance of "other equipment" as allowed in 9.3.1 shall be conducted by properly trained and qualified persons at a frequency determined by the manufacturer's instructions or the equipment listing.

12.2.1 Maintenance of the fire-extinguishing systems and listed exhaust hoods containing a constant or fire-activated water system that is listed to extinguish a fire in the grease removal devices, hood exhaust plenums, and exhaust ducts shall be made by properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction at least every 6 months

12.3.3.2 Replacement shall be made by a certified person acceptable to the authority having jurisdiction.

12.4 Inspection for Grease Buildup. The entire exhaust system shall be inspected for grease buildup by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction and in accordance with Table 12.4.

12.5 Inspection, Testing, and Maintenance of listed Hoods Containing Mechanical, Water Spray, or Ultraviolet Devices.

Listed hoods containing mechanical or fire-actuated dampers, internal washing components, or other mechanically operated shall be inspected and tested by properly trained, qualified, and certified persons every 6 months or at frequencies recommended by the manufacturer in accordance with their listings.

12.6.1 If, upon inspection, the exhaust system is found to be contaminated with deposits from grease-laden vapors, the contaminated portions of the exhaust system shall be cleaned by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction.

12.6.5 Fire-extinguishing systems shall be permitted to be rendered inoperable during the cleaning process where serviced by properly trained and qualified persons.

12.7.1 Inspection and servicing of the cooking equipment shall be made at least annually by properly trained and qualified persons.

12.7.2 Cooking equipment that collects grease below the surface, behind the equipment, or in cooking

equipment flue gas exhaust, such as griddles, deep-fat fryers, or charbroilers, shall be inspected and, if found with grease accumulation, cleaned by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction.

14.6.5 Inspection and testing of the total operation and all safety interlocks in accordance with the manufacturer's instructions shall be performed by qualified service personnel a minimum of once every 6 months or more frequently if required.

In response to the Committee Statement that airflow verification after every cleaning could be impractical (particularly for systems cleaned at very short intervals), this proposal eliminates any requirement for post-cleaning airflow verification. Instead, a fixed 5-year interval balances practicality with safety and system integrity.

The proposed five-year interval is consistent with ASHRAE Standard 62.1, Ventilation for Acceptable Indoor Air Quality, Chapter 8 — Operations and Maintenance, Table 8-1, which establishes a minimum maintenance frequency for verifying ventilation system airflow every five years. Aligning NFPA 96 with this nationally recognized standard ensures technical consistency across related codes and reflects best practices for maintaining the ongoing performance of critical ventilation systems.

Finally, the concern that airflow deficiencies would be evident through visible smoke misses the larger fire safety and health hazard presented by undetected accumulation of grease-laden vapors, which may not always manifest as visible smoke but still present elevated fire risks, occupational exposure hazards, and code non-compliance.

This proposal ensures that airflow performance—a foundational component of commercial kitchen fire safety—is systematically verified on a routine basis, consistent with the thorough and balanced approach NFPA 96 already takes for other system components.

Related Item

- Public Input No. 56-NFPA 96-2024 [New Section after 4.1.4]

Submitter Information Verification

Submitter Full Name: Christopher Ruch
Organization: SMART, SMW Local Union No. 104
Affiliation: SMART, SMW Local Union No. 104
Street Address:
City:
State:
Zip:
Submittal Date: Fri May 30 16:49:58 EDT 2025
Committee: VEN-AAA



Public Comment No. 15-NFPA 96-2025 [Section No. 4.1.5.1]

4.1.5.1*

The responsibility for inspection, testing, maintenance, and cleanliness of the ventilation control, fire protection, and cooking appliances of the commercial cooking operations shall be that of the equipment owner.

4.1.5.2

Owner visual inspection for cooking operations shall comply with the minimum safety guidelines as detailed in the International Kitchen Exhaust Cleaning Association M10 Standard, Standard for the Methodology for Maintenance of Commercial Cooking Operations, 2nd Edition 2023

Statement of Problem and Substantiation for Public Comment

The International kitchen Exhaust Cleaners Association is an ANSI Accredited National Standards Developer that develops Standards for the Maintenance, Cleaning, and Inspection of Commercial Cooking Operations. Working in conjunction with the National Fire Codes these Standards provide minimum safety guidelines on how to perform the requirements as prescribed in NFPA 96. The M10 Standard was developed as a minimum safety guideline for owners and operators requiring visual inspection of operating systems prior to, during, and after cooking shifts or operations. It is currently a National Safety Standard addressing guidelines and provides a reference source to owners, operators, shift personnel, and other interested parties

Related Item

- 4.1.5.2

Submitter Information Verification

Submitter Full Name: Frank Mitarotonda

Organization:

Affiliation: International Exhaust Cleaning Association (IKECA)

Street Address:

City:

State:

Zip:

Submission Date: Tue May 20 11:51:22 EDT 2025

Committee: VEN-AAA



Public Comment No. 4-NFPA 96-2025 [Section No. 9.3.7]

9.3.7

If the heat source is non-electric and open flames are used, at least one listed carbon monoxide alarm shall be installed in both the kitchen and dining areas.

A.9.3.7 Listing requirements for carbon monoxide alarms are contained in UL 2034 Single or Multiple Station Carbon Monoxide Alarms and UL 2075 Gas and Vapor Detector s and Sensors for carbon monoxide detectors . Installations should be in accordance with the product's installation instructions and NFPA 72. The kitchen operator should work with the building owner and review all relevant local codes and laws, such as the fire and plumbing codes, to determine the type of CO detection device to be used. At a minimum an AC powered battery backed up CO alarm should be considered.

Statement of Problem and Substantiation for Public Comment

This was a task group request to review the language of the annex materials.

The main code sections 9.3.7 and 17.10.1 should be revisited to modify the language from the word “detector” to include other types of Carbon Monoxide detection devices such as alarms. The word “detector” is defined by NFPA 72 (2025 edition - Section 3.3.79.5). This definition includes the ability to connect to a signaling circuit. This in essence requires a complete system with a control panel. “CO Alarms” on the other hand have a different NFPA 72 definition (2025 edition - Section 3.3.11.1). The CO alarm can be single or multiple station. This allows the alarms to be a standalone device with a dedicated power supply either battery, AC power, or a combination of both.

Related Item

- FR39

Submitter Information Verification

Submitter Full Name: Kurt Ruchala
Organization: JENSEN HUGHES
Street Address:
City:
State:
Zip:
Submittal Date: Mon Mar 31 14:34:41 EDT 2025
Committee: VEN-AAA



Public Comment No. 13-NFPA 96-2025 [Section No. 12.4]

12.4* Inspection for Grease Buildup.

The entire exhaust system shall be inspected for grease buildup by a properly trained, qualified, and certified person(s) acceptable to the authority having jurisdiction and in accordance with Table 12.4.

Table 12.4 Schedule of Inspection for Grease Buildup

<u>Type or Volume</u> <u>of Cooking</u>	<u>Inspection</u> <u>Frequency</u>
Systems serving solid fuel cooking operations	Monthly
*Systems serving high-volume cooking operations	Quarterly
Systems serving moderate-volume cooking operations	Semiannually
†Systems serving low-volume cooking operations	Annually

*High-volume cooking operations include 24-hour cooking, charbroiling, and wok cooking.

†Low-volume cooking operations include churches, day camps, seasonal businesses, and senior centers.


12.4.1 New and renumber remaining

Inspection for Grease Buildup shall Comply with ANSI / IKECA I10 Standard for the Methodolgy for Inspection of Commercial Cooking Exhaust Systems

12.4.1

A grease depth gauge comb, as shown in Figure 12.4.1, shall be placed on the surface to measure grease depth.

Figure 12.4.1 Depth Gauge Comb.



12.4.2

Where a measured depth of 0.078 in. (2000 μm) is observed on a surface other than in fan housings, the surfaces shall be cleaned in accordance with 12.6.1.

12.4.3

Where a measured depth of 0.125 in. (3175 μm) is observed in a fan housing, the surfaces shall be cleaned in accordance with 12.6.1.

Statement of Problem and Substantiation for Public Comment

A move should be made to have the following sections moved from the Annex to the body of the NFPA 96 to clearly accommodate AHJ's and other interested parties seeking guidance. Often we get inquiries from AHJ's and other interested parties in possession of the standard but don't know to seek this guidance from the Annex section. The I10 Standard is a Nationally recognized accredited standard widely adopted by Authorities Having Jurisdiction (AHJ)

Related Item

- 12.4

Submitter Information Verification

Submitter Full Name: Frank Mitarotonda

Organization:

Affiliation: International Exhaust Cleaning Association (IKECA)

Street Address:

City:

State:

Zip:

Submittal Date: Tue May 20 11:08:45 EDT 2025

Committee: VEN-AAA



Public Comment No. 8-NFPA 96-2025 [New Section after 12.6.1.1]

TITLE OF NEW CONTENT

Commercial Cooking Exhaust Systems shall be cleaned in compliance with ANSI/ IKECA C10, Standard for the Methodology for Cleaning of Commercial Cooking Exhaust Systems or Equivalent Standard

Statement of Problem and Substantiation for Public Comment

A move should be made to have the following sections moved from the Annex to the body of the NFPA 96 to clearly accommodate AHJ's and other interested parties seeking guidance. Often we get inquiries from AHJ's and other interested parties in possession of the standard but don't know to seek this guidance from the Annex section. The C10 Standard is a Nationally recognized accredited standard widely adopted by Authorities Having Jurisdiction (AHJ)

Related Item

- 12.6.1.1

Submitter Information Verification

Submitter Full Name: Frank Mitarotonda

Organization:

Affiliation: International Exhaust Cleaning Association (IKECA)

Street Address:

City:

State:

Zip:

Submittal Date: Wed May 07 11:31:33 EDT 2025

Committee: VEN-AAA



Public Comment No. 5-NFPA 96-2025 [Section No. 17.10.1]

17.10.1

If the heat source is non-electric and open flames are used, at least one listed carbon monoxide alarm shall be installed in the kitchen area.

A.17.10.1 Listing requirements for carbon monoxide alarms are contained in UL 2034 Single or Multiple Station Carbon Monoxide Alarms and UL 2075 Gas and Vapor Detector s and Sensors for carbon monoxide d etectors . Installations should be in accordance with the product's installation instructions and NFPA 72. The kitchen operator should review all relevant local codes and laws, such as the fire and plumbing codes, to determine the type of CO detection device to be used. Due to the nature of the mobile and temporary cooking operations, a minimum battery powered CO alarm should be considered.

Statement of Problem and Substantiation for Public Comment

Task Group was tasked to review the Annex language.

The main code sections 9.3.7 and 17.10.1 should be revisited to modify the language from the word “detector” to include other types of Carbon Monoxide detection devices such as alarms. The word “detector” is defined by NFPA 72 (2025 edition - Section 3.3.79.5). This definition includes the ability to connect to a signaling circuit. This in essence requires a complete system with a control panel. “CO Alarms” on the other hand have a different NFPA 72 definition (2025 edition - Section 3.3.11.1). The CO alarm can be single or multiple station. This allows the alarms to be a standalone device with a dedicated power supply either battery, AC power, or a combination of both.

Related Item

- FR40

Submitter Information Verification

Submitter Full Name: Kurt Ruchala

Organization: JENSEN HUGHES

Street Address:

City:

State:

Zip:

Submittal Date: Mon Mar 31 14:43:32 EDT 2025

Committee: VEN-AAA



Committee Input No. 28-NFPA 96-2024 [Global Input]

Review the document of where the requirements call out "or Canada"

Submitter Information Verification

Committee: VEN-AAA

Submittal Date: Mon Sep 09 16:38:01 EDT 2024

Committee Statement

Committee Statement: The "or Canada" statements in the requirements are only found NFPA 96, the technical committee would like feedback on if the phrase can be removed.

Response Message: CI-28-NFPA 96-2024

Ballot Results

 This item has not been balloted